


NOTES:

1. THE EXISTING WATER BOX SHALL BE RELOCATED BY CONTRACTOR. LOCATION SHOWN IN PLAN IS INDICATIVE AND FOR REFERENCE ONLY. FINAL LOCATION TO BE COORDINATED BY THE CONTRACTOR WITH NCDOT. SEE SHEETS D-101 AND M-101 FOR ADDITIONAL INFORMATION.
2. BELOW GRADE PIPING SHALL BE SOLVENT WELD 2" SCH. 80 PVC MEETING NSF/ANSI STANDARD 61.
3. ABOVE GRADE WATER PIPING AND FITTINGS SHALL BE SCH. 80 304 STAINLESS STEEL MEETING NSF/ANSI STANDARD 61.
4. PLANS DO NOT PURPORT THAT ALL REQUIRED FITTINGS OR PIPING CONFIGURATIONS ARE SHOWN. CONTRACTOR SHALL INVESTIGATE EXISTING WATER SYSTEM AND PROVIDE ALL PIPING AND/OR FITTINGS NECESSARY TO MAKE LINE AND GRADE ADJUSTMENTS TO CONNECT TO THE EXISTING WATER SYSTEM AND TO PROVIDE A COMPLETE AND FUNCTIONAL WATER SERVICE/HOSE BIBB.

1 WATER SERVICE DETAILS
1" = 2'

Digitally signed by Kristopher P
Pagan-Cruz
Date: 2026.02.17 11:31:03-05'00'

MOTT MACDONALD
930 Main Campus Drive,
Suite 200
Raleigh, NC 27606
License No. F-0669
T +1 (919) 552 2253
F +1 (919) 552 2254
www.mottmacamericas.com



PROJECT ENGINEER
NORTH CAROLINA
PROFESSIONAL
SEAL
044825
KRISTOPHER PAGAN-CRUZ

Designed By	STEVEN WHITE	County	DARE COUNTY		
Entered By	GORDON EDWARDS	Division	FERRY DIVISION		
Project Engineer	KRISTOPHER PAGAN	Plan Date	1-14-26		
Project Manager	ALLISON THORBURN				
Rev.	Date	Drawn	Description	Ch'k'd	App'd

**NCDOT HATTERAS FERRY DOCK
REPLACEMENT**

C-102 WATER SERVICE DETAILS