



STATE OF NORTH CAROLINA
DEPARTMENT OF TRANSPORTATION

ROY COOPER
GOVERNOR

J. ERIC BOYETTE
SECRETARY

April 18, 2022

WBS No: 47884.3.1
Contract No: DJ00409
County: Union
Description: Construction of a Roundabout at the Intersection of Tilley Morris Rd (SR 1345) and Weddington Matthews Rd (SR 1344)

Addendum No. 1
May 4, 2022 Letting

To: Prospective Bidders

The Department has received questions concerning the above-mentioned project. Please note the question and answer provided below:

- Q. Sheet UC-3, Project Specific Notes, Item 2, states "All proposed water lines shall be Ductile Iron Pipe PC350 Restrained Joint." Union County Public Works Sanitary Sewer & Water Specifications allows PVC Pipe, C900, SDR 18 for 6" and 8" water lines. Will this be acceptable for this project? We understand bell restraints would be required to meet the restrained joint requirement.
- A. Yes, C900 is acceptable. Union County specifications require PC 350 DIP for all water mains above 8-inch diameter. We allow PC 250 DIP for 16-inch pipe in certain cases based on expected operating pressures.
- Q. Would PVC Pipe, C900, SDR 18 with bell restraints be acceptable for the 16" water line?
- A. No
- Q. If PVC Pipe, C900, SDR 18 with bell restraints is not acceptable for the 16" water line, can Ductile Iron Pipe PC250 restrained with push-on joints (i.e., Fast-Grip, or Field Lok Gasket) be used?
- A. In accordance with the notes on Sheet UC-3 of the plans, PC 250 DI pipe is allowable – See Project Specific Notes – Note 2. Additionally, Union County allows use of field-locking gaskets for restraint.

The changes and attachments included with this addendum will become part of contract DJ00409.

The electronic bidding file has been updated to reflect this revision. Please download the Addendum File and follow the instructions for applying the addendum. Bid Express will not accept your bid unless the addendum has been applied.

Mailing Address:
NC DEPARTMENT OF TRANSPORTATION
HIGHWAY DIVISION 10
716 WEST MAIN ST.
ALBEMARLE, NC 28001


Telephone: (704) 983-4400
Fax: (704) 982-3146
Customer Service: 1-877-368-4968

Location:
716 WEST MAIN ST.
ALBEMARLE, NC 28001

Website: www.ncdot.gov

If you have any questions, please contact me at (704) 983-4400.

Sincerely,

DocuSigned by:

5169D778708C4B7...

Terry Burleson
Contracts Engineer

cc: File