



STATE OF NORTH CAROLINA
DEPARTMENT OF TRANSPORTATION

JOSH STEIN
GOVERNOR

DANIEL H. JOHNSON
SECRETARY

February 12, 2026

NOTICE TO PROSPECTIVE BIDDERS

Subject: Addendum 1

Contract No.: PRB.32276
Federal Aid No.: Helene Relief
TIP No.: N/A
WBS Element: 51830.2.13.56
Letting Date: February 18, 2026

This letter is to advise all prospective bidders of the following contract addendum:

Proposal Changes:

- On sheet S-35 (bid form), updated Line No 13 Temporary Mulching to reflect Unit in Acres.
- Replaced PRB.32276 Proposal document with PRB.32276 Proposal_Addendum 1.

Additional Questions Submitted:

1. 404 Permit list restrictions. Do we follow and what applies on page 157?
Answer: 404 must be followed. Nos. 1 thru 4 do not apply. Trout does not apply
2. Rock removal is referred to in plans for work with piers. What is the pay item?
Answer: Payment for removal is incidental to work of construction of piers.
3. Construction signs placed on Hwy 19 W, how will they be paid?
Answer: Traffic Control Special Provision is included in proposal. See TC-1 thru TC-3.

“Except for the specific pay items included in this provision, no separate or direct payment will be made for supplying traffic control, traffic control devices, or signing as all such work will be considered incidental to the various other pay items included in this contract.”

(Continued on next page)

4. The plans indicate causeways extending around both new piers and back to each abutment. Since there is currently no access from the west side, would it be permissible to install temporary pipes and connect the two causeways to create an all-weather crossing? At this time, it is not feasible to access the west side with dump trucks, concrete trucks, or girder deliveries. Upon completion of the project, all temporary access materials would be fully removed and the area restored in accordance with project requirements.

Answer: This would be considered a modification of the approved plans and would need to be approved by the permitting agency. This question will be submitted to the permitting agency for further clarification.

5. What is the proposed unit of payment for temporary mulching?

Answer: Acre

Please make sure that you download and submit the new proposal document titled PRB.32276 Proposal_Addendum 1 in your bid package. You will also be required to sign page S-1 Addenda to acknowledge the issued addendum. Failure to submit the correct proposal document and not signing page S-1 Addenda may result in the rejection of your bid

Sincerely,

DocuSigned by:
Chad Loftis
F1DB06E580E946A...

Chad Loftis
Division Contracts Engineer

cc: Tim Anderson, P.E., Division 13 Engineer
Michael Poe, P.E., Division 11 Engineer
Kristin Moyle, NCDPS/NCEM
Chris Deyton, P.E., Deputy Division 13 Engineer
Nathan Moneyham, P.E., Division 13 Construction Engineer
Gabriel Johnson, P.E., Division 13 Project Manager
Steve Cannon, P.E., Division 13 Project Development Engineer
Brendan Merithew, P.E., Division 13 Project Team Lead