DocuSign Envelope ID: 3B615230-0FA7-487D-B70E-8767A7FD7945

5/14/99

PROJECT REFERENCE NO.	SHEET NO.
SM-6114C	2C-2



TYPE 2A MOD



TYPE 2



TYPE 2B



TYPE 2A

1. 8.33% (12:1) MAX RAMP SLOPE
2. CROSS SLOPE: 2.00%
3. CURB RAMPS REQUIRE A (4'-0") MINIMUM LANDING WITH A MAXIMUM CROSS SLOPE AND LONGITUDINAL SLOPE OF 2.00% WHERE PEDESTRIANS PERFORM TURNING MANEUVERS. SLOPE TO DRAIN TO CURB.

PAY LIMITS FOR 1 CURB RAMP

9/1/2022

NORTH CAROLINA PROFESSIONAL SEAL 022071 ENGINEER

DOCUMENT NOT CONSIDERED FINAL UNLESS ALL SIGNATURES COMPLETED

CONTRACT STANDARDS AND DEVELOPMENT UNIT
Office 919-707-6950 FAX 919-250-4119

CURB RAMPS

ORIGINAL BY: J.S. HOWERTON DATE: 7/7/11
MODIFIED BY: DATE:
CHECKED BY: DATE:
FILE SPEC.: stds/2012CurbRamp/CurbRampDetails.dgn

SYSTIME$$$$
CONS$$$$
USERNAME$$$$