



BURNETTE • CHALK ARCHITECTURE & PLANNING P.A.

105 BANKS STREET MOREHEAD CITY, NORTH CAROLINA 28557
252 726-5387 252 726-3099 FAX 252 726-1250 info@burnchalk.com www.burnchalk.com

NCDOT DIVISION III MULTI-UNIT OFFICE BUILDING 5501 BARBADOS BLVD., CASTLE HAYNE, NC

SCO ID# 15-12499-02A

MARCH 8, 2018

ADDENDUM NO. 2

The following addendum supersedes all previous information and does hereby become a part of the Contract Documents.

1. Sheet E5, Fixture Type "S", Note #1, is corrected to read: **"mount on 30 ft. steel pole and provide photocell."** NCDOT will lease all poles and fixtures labeled "S" from Duke Energy Progress (DEP). DEP will provide and install the poles, fixtures, and the power to the fixtures. The drawing layout is provided to show intent of DEP, the Owner, and to the State Construction Office. The only requirement of the Contractor regarding fixture "S" will be to coordinate DEP's installation of the pole, fixtures, and power to the fixtures with the Contractor's site work.
2. Contractor shall be responsible for paying the following Impact Fees to Cape Fear Public Utility Authority (CFPUA):
 - a. New Customer Fee \$ 55.00
 - b. Water System Development Charge \$ 7,950.00
 - c. Sewer System Development Charge \$ 10,650.00
 - d. Meter Set Fee \$ 1,600.00
 - e. Water Tap Witness Fee \$ 55.00
3. Specifications Section 10 6730 "Metal Shelving": High Capacity Boltless shelving is to be 84" high, not 96" high.
4. Specifications Section 07 41 13, Part 2:
 - 2.01 A. Acceptable Manufacturers:
 - B. Metal Roofing Systems, Inc: www.metalroofingsystems.biz, is added to the list of acceptable manufacturers.

- End of Addendum No.2 -