



STATE OF NORTH CAROLINA  
DEPARTMENT OF TRANSPORTATION


JOSH STEIN  
GOVERNOR

J.R. "JOEY" HOPKINS  
SECRETARY

June 12, 2025

**To: Prospective Bidders**

**From: Jonathan W. Mitchell**  
**Division Contract Engineer**

Signed by:  
  
02B404268BC84C2...

**Contract ID#:** DC00483  
**County:** Pender  
**WBS Element:** 15BPR.138.3  
**Subject: Addendum #1:** Bridge 16 Repair Lighting Re-Let 3

The Subject contract proposal contains the following addendum:

Add the following notes to contractor –

- Regarding the existing backbox repair, the expectation is that all accessible areas of the backbox be coated. Areas of particular concern are the locations on the backbox that already exhibit corrosion. Where accessible, the areas of corrosion should be prepared with power tools, like small grinders or sanders. Other areas with difficult access should be prepared as best as can be done with hand tools to remove loose corrosion, paint, etc. After all preparation is complete, the entire accessible area of the box should be painted with organic zinc repair paint as specified in 1080-7 of the Standard Specifications.
- Based on limited random observations in the field, it appears the existing PVC fittings in the backboxes are female adapters. However, not each of the backboxes has been field verified to confirm that female adapters are consistent in all backboxes; there may be some variability. It is also unknown if the adapters are glued or threaded.

**\*\*\*An Addendum has been added to Bid Express & the NCDOT Letting Site.**

*Mailing Address:*  
NC DEPARTMENT OF TRANSPORTATION  
DIVISION OF HIGHWAYS  
5501 BARBADOS BOULEVARD  
CASTLE HAYNE, NC 28429-5647

*Telephone:* (910) 341-2000  
*Fax:* (910) 675-0143  
*Customer Service:* 1-877-368-4968

*Website:* [www.ncdot.gov](http://www.ncdot.gov)

*Location:*  
5501 BARBADOS BOULEVARD  
CASTLE HAYNE, NC 28429-5647