

December 7, 2022

SCO ID# 22-25609-01A

**WINDOW REPLACEMENT for
NCDMV-State Highway Patrol Communications & Logistics Building
1300 Blue Ridge Road, Raleigh, North Carolina 27607**

ADDENDUM No. 2

<u>Item No.</u>	<u>Reference</u>	<u>Description</u>
-----------------	------------------	--------------------

GENERAL:

Item No. 1:		Sealed proposals shall be received until 2:00 PM on Thursday, January 5, 2023 , in the Conference Room of the NCDMV-State Highway Patrol C&L <u>Maintenance Office</u> at 1300 Blue Ridge Road, Raleigh, NC 27607.
-------------	--	---

DRAWINGS:

Item No. 1	Drawing A1	Refer to window details on Drawing A1. Panning systems produced by the window manufacturer shall be used in lieu of break metal perimeter flashing. Panning system shall have square profiles and permit the installation of backer rod and sealant around the exterior window perimeter. Finish of panning system shall match window. Receptors or snap trim systems produced by the window manufacturer may be used for window frame attachment to substrates as necessary.
------------	------------	---

SPECIFICATIONS:

Item No. 1	Section 084313	Refer to Specification Section 084313 – Aluminum-Framed Storefronts, Paragraph 2.07 A. The color and finish for storefront framing and doors shall be dark bronze anodized, Architectural Class I, 0.7 mil thickness.
Item No. 2	Section 085113	Refer to Specification Section 085113 – Aluminum Windows, Paragraph 2.02 B. The basis of design shall be YKK America Inc. Series YOW 350 TU. Similar products from Kawneer Corporation and Wausau Window and Wall Systems are acceptable.
Item No. 3	Section 085113	Refer to Specification Section 085113 – Aluminum Windows, Paragraph 2.07 A. The color and finish for window framing, panning, attachment components, and exposed accessories shall be dark bronze anodized, Architectural Class I, 0.7 mil thickness.

Mark D. Gibson RA
Architectural Supervisor
NCDOT Facilities Design Unit