


GIRDER REPAIR LOCATIONS					
SPAN	GIRDER	DISTANCE ALONG SPAN	LOCATION	REPAIR SIZE (L X W)	LABEL
3	4	28'-10"	BTM. OF GDR.	13'-0" X 2'-2"	A
3	4	40'-7"	BTM. OF GDR.	6" X 6"	B
3	4	42'-7"	BTM. OF GDR.	2'-0" X 10"	C
3	4	44'-7"	BTM. OF GDR.	8" X 6"	D
3	4	46'-7"	BTM. OF GDR.	1'-4" X 2'-2"	E
3	4	48'-7"	BTM. OF GDR.	1'-0" X 6"	F
3	4	51'-7"	BTM. OF GDR.	9" X 6"	G

GIRDER POPOUT LOCATIONS					
SPAN	GIRDER	BAY	LOCATION	REPAIR NUMBER/SIZE	
3	1	1	WEB	6 @ 3" X 3"	
3	2	1	WEB	14 @ 3" X 3"	
3	3	2	WEB	10 @ 3" X 3"	
3	3	3	WEB	1 @ 3" X 3"	
3	4	3	WEB	2 @ 3" X 3"	
3	4	4	WEB	5 @ 3" X 3"	
3	5	4	WEB	1 @ 3" X 1'-0"	
3	5	5	WEB	19 @ 3" X 3"	
3	6	5	WEB	7 @ 3" X 3"	

(FOR CLARITY, POPOUTS ARE NOT SHOWN IN PLAN VIEW)

NOTE:
FOR GIRDER REPAIR DETAILS AND SEQUENCE, SEE "PRESTRESSED GIRDER REPAIR DETAILS AND SUMMARY" SHEET.
FOR EPOXY COATING POPOUTS, SEE SPECIAL PROVISION.

PROJECT NO. B-5942
HYDE COUNTY
BRIDGE NO. 20
SHEET 3 OF 11



REVISIONS						SHEET NO.
NO.	BY:	DATE:	NO.	BY:	DATE:	
1			3			S-6
2			4			TOTAL SHEETS 30

DRAWN BY : P.C. BREWER DATE : 10-16
CHECKED BY : B. L. GREEN DATE : 10-16

DOCUMENT NOT CONSIDERED FINAL UNLESS ALL SIGNATURES COMPLETED