



STATE OF NORTH CAROLINA
DEPARTMENT OF TRANSPORTATION

ROY COOPER
GOVERNOR

J.R. "JOEY" HOPKINS
SECRETARY

August 14, 2024

WBS No: 10.10611.1
Contract No: DJ00460
County: Mecklenburg
Description: Grading, Drainage, Paving, and Concrete Islands on the North Side of Wilkinson Blvd. (US Hwy 29/74) Between Sam Wilson Road (SR 1625) and Parrott Drive

Addendum No. 1
August 21, 2024 Letting

To: Prospective Bidders

The Department has received questions concerning the above-mentioned project. Please note the question and answer provided below:

- Q. Will Trench Boxes be allowed to construct drainage structures 403 & 406 and associated pipe?
- A. No. With drainage structures being so close to the road, temporary shoring will be required.
- Q. Will the fence on parcel 2 be relocated?
- A. No. However, we are adding the line-item(s) for Chain Link Fence if the fence needs to be relocated.
- Q. What is the size of the water service line?
- A. 1"
- Q. Will the water service line connect to a water service main?
- A. No. The water service line will connect to the existing water service line.
- Q. Where will the temporary guardrail and temporary guardrail end units go?
- A. These items have been removed from the itemized proposal.
- Q. Where does the Portable Concrete Barrier go?
- A. It will be installed in accordance with section 1101.04 of the Roadway Standard Drawings.

Please note the following revision to the proposal for the above referenced project.

- Line-Item 6 the quantity has been updated from 860 SF to 2600 SF.
- Line-Item(s) 33, 34, & 35 have been removed.
- Line-item(s) 62 (Chain Link Fence, 72" Fabric), 63 (Metal Line Post for 72" Chain Link Fence), & 64 (Metal Terminal Post for 72" Chain Link Fence) have been added to the itemized proposal.

Mailing Address:
NC DEPARTMENT OF TRANSPORTATION
DIVISION 10
716 W. MAIN ST.
ALBEMARLE, NC, 28001

Telephone: 704-983-4400
Fax: 704-982-3146
Customer Service: 1-877-368-4968

Location:
716 W. MAIN ST.
ALBEMARLE, NC,

28001


Website: ncdot.gov

The changes and attachments included with this addendum will become part of contract DJ00460.

The electronic bidding file has been updated to reflect this revision. Please download the Addendum File and follow the instructions for applying the addendum. Bid Express will not accept your bid unless the addendum has been applied.

If you have any questions, please contact me at (704) 983-4400.

Sincerely,

DocuSigned by:

8DD1CB4DB58F4FC...

Jared S. Mathis, PE
Division Contract Engineer