

ADDENDUM No. 7

TO: Prospective Bidders

FROM: Donna Johnson, Contracts Administrator

DATE: August 19, 2022

PROJECT: I-85 North Bridge
Project No.: 512-15-003
Bid Number: HC2020-2040

The following items are being issued herein for modification and clarification to the Bid Requirements for the project referenced above. All Bidders shall acknowledge this Addendum within their submittal.

MODIFICATIONS

PROJECT MANUAL

- 1) On Section 00 10 00 – Invitation to Bid (page 00 10 00 – 1), change the “**BID SUBMITTAL DATE**” to the following:

BID SUBMITTAL DATE: ~~AUGUST 23, 2022~~
AUGUST 30, 2022

- 2) On Section 00 10 00 – Invitation to Bid (page 00 10 00 – 1), delete the “**BID OPENING LOCATION**” in its entirety and replace with the following:

BID OPENING LOCATION: Webex Only
Direct Video Conference Link:

<https://charlotte.webex.com/charlotte/j.php?MTID=md71f9c0026620ae229fb1b1d43a8dca9>

OR

Website: <https://charlotte.webex.com/charlotte/>
Meeting Number (access code): 2310 460 8617
Meeting Password: uQxgJNsV489

1-650-479-3207 Call-in number (US/Canada)

CLARIFICATIONS:

- a) Bid submittal location is the same as before (City of Charlotte, Property & Maintenance [Building Services] Department, 531 Spratt Street, Charlotte, NC 28206).
- b) No additional questions are being accepted beyond August 16, 2022.

QUESTIONS & ANSWERS

1. Sheet 2E calls out a 1” debris screen to be installed on top of the sand filter layer. Can the owner please specify what material is to be used for the debris screen?

Answer: The debris screen should be made of a non-corrosive material and have ample weight to prevent floatation or otherwise be able to be secured and removed for maintenance.

1. So far we have not found any companies willing to precast the four storm water control devices. Will the contractor be allowed to cast these boxes in place if no one is willing to provide the precast components?

Answer: This is the contractor's means and methods. The City has no issue with cast in place.

END OF ADDENDUM NO. 7