



STATE OF NORTH CAROLINA
DEPARTMENT OF TRANSPORTATION

ROY COOPER
GOVERNOR

J. ERIC BOYETTE
SECRETARY

ADDENDUM NO. 1

June 4, 2021

Contract No.: 11-00-147
WBS Element: 11RE.108638
County: Surry
Description: I-77 Welcome Center Wastewater Treatment Plant Rehabilitation

June 17, 2021 Bid Letting

To Whom It May Concern:

Reference is made to the proposal and plans for the above-mentioned project. During the course of the Pre-Bid Conference held on June 3, 2017, the following revisions to the scope of the project were discussed in detail:

- Replace all existing concrete around the two 15-gallon tanks, the concrete steps, and the concrete sidewalk with concrete having the same dimensions. See plan sheet C101 for dimensions.
- Replace existing 1½" PVC carrier pipe and 4" PVC encasement pipe from building exterior wall to contact tank. The new carrier and encasement pipe shall be installed below grade.
- All replacement air lines shall be Schedule 40 stainless with threaded joints.
- During periods when the chlorine contact tank is offline, provide temporary bypass piping and connections such that all plant effluent is chlorinated and dechlorinated prior to discharge.

Please acknowledge receipt of Addendum No. 1 on the addendum sheet in the contract proposal.

If you have any questions regarding this matter, please feel free to contact me at 336-903-9115.

Sincerely,

A handwritten signature in cursive script that reads "Kenny H. Heavner".

Kenny H. Heavner, PE
Division Contract Engineer

cc: M. A. Pettyjohn, PE, Division Engineer
W. O. Atkins, PE, Division Project Development Engineer
J. D. Wood, Division Roadside Environmental Engineer

Mailing Address:
NC DEPARTMENT OF TRANSPORTATION
DIVISION 11
P. O. BOX 250
NORTH WILKESBORO, NC 28659

Telephone: (336) 667-9111
Fax: (336) 667-4549
Customer Service: 1-877-368-4968

Location:
801 STATESVILLE ROAD
NORTH WILKESBORO, NC 28659

Website: www.ncdot.gov