



PAT McCRORY
Governor

NICHOLAS J. TENNYSON
Secretary

February 9, 2016

ADDENDUM # 1

To: Plan Holders

From: Jeffrey E. Alspaugh
Proposal Engineer

DS
jea

RE: **Question & Answer**
Contract ID: DN11569482
County: Cherokee, Clay, Graham, Haywood, Henderson, Jackson, Macon, Polk,
Swain, And Transylvania
Letting Date: February 23, 2016

A bidder has raised the following question:

“What size are the pipes that are to be repaired?”

The engineer’s response is as follows:

“We do not restrict the pipe size that could be repaired. There are provisions for confined space entry if a pipe was deemed to be so due to small diameter, length, etc. Small pipe repairs will be restricted by how small a contractor feels they could adequately work inside of. At some point a person just couldn’t enter and work inside very small pipes. Generally, however, Bridge Maintenance Unit is only responsible for pipes larger than 54”, so that is most likely the size and larger that a contractor would find themselves working in.”

These revisions do not change bid items or the associated quantities.

Please insert this letter into the addendum section of the proposal and sign the verification. Thank you for your attention to this matter.

