

## Austin, Wanda H

---

**From:** Austin, Wanda H  
**Sent:** Thursday, May 23, 2013 8:42 AM  
**To:** Enloe Bill (APAC - Harrison) (benloe@wvpaving.com); HMC.PAVING@aol.com  
**Cc:** Austin, Wanda H; Anderson, W Trent; Rogers, Keith L  
**Subject:** DN00244

**Importance:** High

A question has been asked about the milling on Map #2. Map #2 has spot locations that will require 2 ½" milling. The typical is in error and does not indicate this milling. Also the milling on Map #1 is to bring the asphalt below the curb line elevation.

Please sign the addendum section of the proposal as verification of the addendum.

Wanda H. Austin, P.E.  
Division 14 Proposals Engineer  
253 Webster Road  
Sylva, NC 28779  
(828) 586-2141

---

Email correspondence to and from this sender is subject to the N.C. Public Records Law and may be disclosed to third parties.