



STATE OF NORTH CAROLINA
DEPARTMENT OF TRANSPORTATION

PAT MCCRORY
GOVERNOR

ANTHONY J. TATA
SECRETARY

January 13, 2015

CONTRACT: DB00211
TIP: K-5101
WBS ELEMENT: 42229.3.FS1
FEDERAL-AID NO: NHPP-0070(173)
COUNTY: Craven
DESCRIPTION: Rest Area

RESPONSE TO REQUEST FOR INFORMATION 1

Our office was contacted by a contractor regarding a question on the above referenced project. In order to allow all bidders the same information regarding this project, we are providing the question (as received) and answer in this response. The following is the question and answer:

“From what I Understand, Taylor and Statesville do not make pavers, only face brick. Belden only do 8x8 pavers. Can we verify that you are asking for 12x12’ and if so, can we substitute Pavestone out of Charlotte for the 12x12. We would need to specify color, Thank you.”

Yes, you can use 12”x 12” (Pavestone). Color should match building.

Sincerely,

A handwritten signature in black ink, appearing to read "Sarah Lentine".

Sarah Lentine
Division Contract Officer

cc: Ed Eatmon, PE
Bill Kincannon, PE
Betty Caldwell, PE