



STATE OF NORTH CAROLINA
DEPARTMENT OF TRANSPORTATION

PAT MCCRORY
GOVERNOR

ANTHONY J. TATA
SECRETARY

January 16, 2015

CONTRACT: DB00211
TIP: K-5101
WBS ELEMENT: 42229.3.FS1
FEDERAL-AID NO: NHPP-0070(173)
COUNTY: Craven
DESCRIPTION: Rest Area

RESPONSE TO REQUEST FOR INFORMATION 2

Our office was contacted by a contractor regarding questions on the above referenced project. In order to allow all bidders the same information regarding this project, we are providing the questions (as received) and answers in this response. The following are the questions and answers:

"Is Mc cable acceptable wiring method per specs?"

No.

"Sheet E1.3 riser diagram shows pvc conduit, specs call for rigid which is acceptable?"

Rigid conduit must be used.

"Sheet E1.3 riser diagram note # 4. Can the existing conduit feeding the storage shed be used and new wire pulled in lieu of running new conduit under parking lot?"

Yes, the existing conduit can be used to feed to the storage shed.

Sincerely,

A handwritten signature in black ink, appearing to read "Sarah Lentine".

Sarah Lentine
Division Contract Officer

cc: Ed Eatmon, PE
Bill Kincannon, PE
Betty Caldwell, PE

MAILING ADDRESS:
DIVISION TWO - OPERATIONS
P.O. BOX 1587
GREENVILLE, NC 27835

TELEPHONE: (252) 439-2800
FAX: (252) 830-3325
WEBSITE: WWW.NCDOT.GOV

LOCATION:
1704 N GREENE ST
GREENVILLE, NC