

STATE OF NORTH CAROLINA
DEPARTMENT OF TRANSPORTATION
HIGHWAY DIVISION 3

PROPOSAL

DATE AND TIME OF BID OPENING: July 28, 2022 AT 2:00 PM

CONTRACT ID: DC00404

WBS ELEMENT NO.: 15RE.13.3

FEDERAL AID NO.: STATE FUNDED

COUNTY: Brunswick County

TIP NO.: N/A

MILES: N/A

ROUTE NO.: US 17

LOCATION: US 17 AT NC 130

TYPE OF WORK: SHALLOTTE REST AREA RENOVATION

NOTICE:

ALL BIDDERS SHALL COMPLY WITH ALL APPLICABLE LAWS REGULATING THE PRACTICE OF GENERAL CONTRACTING AS CONTAINED IN CHAPTER 87 OF THE GENERAL STATUTES OF NORTH CAROLINA WHICH REQUIRES THE BIDDER TO BE LICENSED BY THE N.C. LICENSING BOARD FOR CONTRACTORS WHEN BIDDING ON ANY NON-FEDERAL AID PROJECT WHERE THE BID IS \$30,000 OR MORE, EXCEPT FOR CERTAIN SPECIALTY WORK AS DETERMINED BY THE LICENSING BOARD. BIDDERS SHALL ALSO COMPLY WITH ALL OTHER APPLICABLE LAWS REGULATING THE PRACTICES OF ELECTRICAL, PLUMBING, HEATING AND AIR CONDITIONING AND REFRIGERATION CONTRACTING AS CONTAINED IN CHAPTER 87 OF THE GENERAL STATUTES OF NORTH CAROLINA. NOTWITHSTANDING THESE LIMITATIONS ON BIDDING, THE BIDDER WHO IS AWARDED ANY FEDERAL - AID FUNDED PROJECT SHALL COMPLY WITH CHAPTER 87 OF THE GENERAL STATUTES OF NORTH CAROLINA FOR LICENSING REQUIREMENTS WITHIN 60 CALENDAR DAYS OF BID OPENING.

THIS IS A REST AREA RENOVATION PROJECT.

BID BONDS ARE REQUIRED.

NAME OF BIDDER

ADDRESS OF BIDDER

**PROPOSAL FOR THE CONSTRUCTION OF
CONTRACT No. DC00404 IN BRUNSWICK COUNTY, NORTH CAROLINA**

Date _____ 20 _____

**DEPARTMENT OF TRANSPORTATION,
RALEIGH, NORTH CAROLINA**

The Bidder has carefully examined the location of the proposed work to be known as Contract No. **DC00404**; has carefully examined the plans and specifications, which are acknowledged to be part of the proposal, the special provisions, the proposal, the form of contract, and the forms of contract payment bond and contract performance bond; and thoroughly understands the stipulations, requirements and provisions. The undersigned bidder agrees to bound upon his execution of the bid and subsequent award to him by the Department of Transportation in accordance with this proposal to provide the necessary contract payment bond and contract performance bond within fourteen days after the written notice of award is received by him. The undersigned Bidder further agrees to provide all necessary machinery, tools, labor, and other means of construction; and to do all the work and to furnish all materials, except as otherwise noted, necessary to perform and complete the said contract in accordance with *the 2018 Standard Specifications for Roads and Structures* by the dates(s) specified in the Project Special Provisions and in accordance with the requirements of the Engineer, and at the unit or lump sum prices, as the case may be, for the various items given on the sheets contained herein.

The Bidder shall provide and furnish all the materials, machinery, implements, appliances and tools, and perform the work and required labor to construct and complete State Highway Contract No. **DC00404** in **Brunswick County**, for the unit or lump sum prices, as the case may be, bid by the Bidder in his bid and according to the proposal, plans, and specifications prepared by said Department, which proposal, plans, and specifications show the details covering this project, and hereby become a part of this contract.

The published volume entitled *North Carolina Department of Transportation, Raleigh, Standard Specifications for Roads and Structures, January 2018* with all amendments and supplements thereto, is by reference incorporated into and made a part of this contract; that, except as herein modified, all the construction and work included in this contract is to be done in accordance with the specifications contained in said volume, and amendments and supplements thereto, under the direction of the Engineer.

If the proposal is accepted and the award is made, the contract is valid only when signed either by the Contract Officer or such other person as may be designated by the Secretary to sign for the Department of Transportation. The conditions and provisions herein cannot be changed except over the signature of the said Contract Officer or Division Engineer.

The quantities shown in the itemized proposal for the project are considered to be approximate only and are given as the basis for comparison of bids. The Department of Transportation may increase or decrease the quantity of any item or portion of the work as may be deemed necessary or expedient.

An increase or decrease in the quantity of an item will not be regarded as sufficient ground for an increase or decrease in the unit prices, nor in the time allowed for the completion of the work, except as provided for the contract.

Accompanying this bid is a bid bond secured by a corporate surety, or certified check payable to the order of the Department of Transportation, for five percent of the total bid price, which deposit is to be forfeited as liquidated damages in case this bid is accepted and the Bidder shall fail to provide the required payment and performance bonds with the Department of Transportation, under the condition of this proposal, within 14 calendar days after the written notice of award is received by him, as provided in the Standard Specifications; otherwise said deposit will be returned to the Bidder.

TABLE OF CONTENTS

THIS CONTRACT IS FOR CONTRACT ID **DC00404** FOR **REST AREA RENOVATION** TYPE OF WORK IN **Brunswick County**.

SPECIAL PROVISIONS

PROJECT SPECIAL PROVISIONS..... 1

GENERAL..... 1

INTERESTED PARTIES LIST: 1

BOND REQUIREMENTS:..... 1

CONTRACT TIME AND LIQUIDATED DAMAGES: 2

NO MAJOR CONTRACT ITEMS: 2

NO SPECIALTY ITEMS:..... 2

FUEL PRICE ADJUSTMENT:..... 2

SCHEDULE OF ESTIMATED COMPLETION PROGRESS:..... 3

MINORITY BUSINESS ENTERPRISE AND WOMEN BUSINESS ENTERPRISE (DIVISIONS):..... 3

CONTRACTOR'S LICENSE REQUIREMENTS:..... 17

RESTRICTIONS ON ITS EQUIPMENT AND SERVICES:..... 17

USE OF UNMANNED AIRCRAFT SYSTEM (UAS):..... 18

EQUIPMENT IDLING GUIDELINES:..... 18

ELECTRONIC BIDDING:..... 19

AWARD LIMITS:..... 19

TWELVE MONTH GUARANTEE:..... 19

OUTSOURCING OUTSIDE THE USA:..... 20

PROJECT SPECIAL PROVISIONS..... 21

ROADWAY..... 21

NOTES TO CONTRACTOR: 21

SUPPLEMENTAL SURVEYING: 21

PORTLAND CEMENT CONCRETE PRODUCTION AND DELIVERY:..... 21

MATERIALS FOR PORTLAND CEMENT CONCRETE:..... 23

MATERIAL AND EQUIPMENT STORAGE & PARKING OF PERSONAL VEHICLES: 23

WORK ZONE INSTALLER:..... 24

STANDARD SPECIAL PROVISION 25

AVAILABILITY OF FUNDS – TERMINATION OF CONTRACTS 25

ERRATA 26

PLANT AND PEST QUARANTINES 28

MINIMUM WAGES 29

TITLE VI AND NONDISCRIMINATION: 30

ON-THE-JOB TRAINING..... 37

LISTING OF MBE/WBE SUBCONTRACTORS 40

CONTRACT PAYMENT BOND 42

CONTRACT PERFORMANCE BOND 51

BID BOND 60

ADDENDUM(S) 67

EXECUTION OF BID..... 69

DEBARMENT CERTIFICATION 75

PROPOSAL ITEM SHEET AND SIGNATURE SHEET

INSTRUCTIONS TO BIDDERS

**PLEASE READ ALL INSTRUCTIONS CAREFULLY
BEFORE PREPARING AND SUBMITTING YOUR BID.**

All bids shall be prepared and submitted in accordance with the following requirements. Failure to comply with any requirement may cause the bid to be considered irregular and may be grounds for rejection of the bid.

For preparing and submitting the bid electronically, refer to Article 102-8(B) of the *2018 Standard Specifications*.

Bidders that bid electronically on Raleigh Central-Let projects will need a separate Digital Signature from the approved electronic bidding provider for Division Contracts.

ELECTRONIC ON-LINE BID:

1. Download entire proposal from Connect NCDOT website. Download the electronic submittal file from the approved electronic bidding provider website.
2. If the *Interested Parties List* provision SP01 G02 is part of the proposal prior to submitting a bid on a project, the bidder shall sign up on the *Interested Parties List* in conformance with Interested Parties List provision SP01 G02.
3. Prepare and submit the electronic submittal file using the approved electronic bidding provider software.
4. Electronic bidding software necessary for electronic bid preparation may be downloaded from the Connect NCDOT website at: <https://connect.ncdot.gov/letting/Pages/Electronic-Bidding.aspx> or from the approved electronic bidding provider website.

PROJECT SPECIAL PROVISIONS

GENERAL

INTERESTED PARTIES LIST:

(6-21-22)(Rev. 7-19-22)

102

SP1 G02

Revise the *2018 Standard Specifications* as follows:

Page 1-12, Article 102-3 PROPOSALS AND PLAN HOLDER LISTS, lines 45-49, delete and replace with the following:

102-3 PROPOSALS AND INTERESTED PARTIES LIST

On Department projects advertised, the prospective bidder shall sign up on the *Interested Parties List* no later than one business day prior to the Letting day of that project, for which he intends to submit a bid. There is no cost for signing up on the *Interested Parties List* that can be found on the Department's website at connect.ncdot.gov/letting.

Page 1-12, Article 102-3 PROPOSALS AND PLAN HOLDER LISTS, lines 1-3, delete and replace the first sentence of the second paragraph with the following:

The proposal will state the location of the contemplated construction and show a schedule of contract items with the approximate quantity of each of these items for which bid prices are invited.

Page 1-14, Article 102-8 PREPARATION AND SUBMISSION OF BIDS, lines 30-31, delete and replace the first paragraph with the following:

Prior to submitting a bid on a project, the bidder shall sign up on the *Interested Parties List* in conformance with Article 102-3. The bidder shall submit a unit or lump sum price for every item in the proposal other than items that are authorized alternates to those items for which a bid price has been submitted.

BOND REQUIREMENTS:

(06-01-16)

102-8, 102-10

SPD 01-420A

A Bid Bond is required in accordance with Article 102-10 of the *2018 Standard Specifications for Roads and Structures*.

Contract Payment and Performance Bonds are required in accordance with Article 103-7 of the *2018 Standard Specifications for Roads and Structures*.

CONTRACT TIME AND LIQUIDATED DAMAGES:

(7-1-95) (Rev. 12-18-07)

108

SP1 G10 A

The date of availability for this contract is **September 19, 2022**.

The completion date for this contract is **April 21, 2023**.

Except where otherwise provided by the contract, observation periods required by the contract will not be a part of the work to be completed by the completion date and/or intermediate contract times stated in the contract. The acceptable completion of the observation periods that extend beyond the final completion date shall be a part of the work covered by the performance and payment bonds.

The liquidated damages for this contract are **Six Hundred Dollars (\$ 600.00)** per calendar day.

NO MAJOR CONTRACT ITEMS:

(2-19-02) (Rev. 8-21-07)

104

SP1 G31

None of the items included in this contract will be major items.

NO SPECIALTY ITEMS:

(7-1-95)

108-6

SP1 G34

None of the items included in this contract will be specialty items (see Article 108-6 of the *2018 Standard Specifications*).

FUEL PRICE ADJUSTMENT:

(11-15-05) (Rev. 7-20-21)

109-8

SP1 G43

Revise the *2018 Standard Specifications* as follows:

Page 1-87, Article 109-8, Fuel Price Adjustments, add the following:

The base index price for DIESEL #2 FUEL is **\$ 4.5239** per gallon. Where any of the following are included as pay items in the contract, they will be eligible for fuel price adjustment.

The pay items and the fuel factor used in calculating adjustments to be made will be as follows:

Description	Units	Fuel Usage Factor Diesel
Unclassified Excavation	Gal/CY	0.29
Borrow Excavation	Gal/CY	0.29
Class IV Subgrade Stabilization	Gal/Ton	0.55
Aggregate Base Course	Gal/Ton	0.55
Sub-Ballast	Gal/Ton	0.55
Asphalt Concrete Base Course, Type _____	Gal/Ton	0.90 or 2.90
Asphalt Concrete Intermediate Course, Type _____	Gal/Ton	0.90 or 2.90
Asphalt Concrete Surface Course, Type _____	Gal/Ton	0.90 or 2.90
Open-Graded Asphalt Friction Course	Gal/Ton	0.90 or 2.90
Permeable Asphalt Drainage Course, Type _____	Gal/Ton	0.90 or 2.90
Sand Asphalt Surface Course, Type _____	Gal/Ton	0.90 or 2.90
Aggregate for Cement Treated Base Course	Gal/Ton	0.55
Portland Cement for Cement Treated Base Course	Gal/Ton	0.55

" Portland Cement Concrete Pavement	Gal/SY	0.245
Concrete Shoulders Adjacent to " Pavement	Gal/SY	0.245

For the asphalt items noted in the chart as eligible for fuel adjustments, the bidder may include the *Fuel Usage Factor Adjustment Form* with their bid submission if they elect to use the fuel usage factor. The *Fuel Usage Factor Adjustment Form* is found at the following link:

<https://connect.ncdot.gov/letting/LetCentral/Fuel%20Usage%20Factor%20Adjustment%20Form.pdf>

Select either 2.90 Gal/Ton fuel factor or 0.90 Gal/Ton fuel factor for each asphalt line item on the *Fuel Usage Factor Adjustment Form*. The selected fuel factor for each asphalt item will remain in effect for the duration of the contract.

Failure to complete the *Fuel Usage Factor Adjustment Form* will result in using 2.90 gallons per ton as the Fuel Usage Factor for Diesel for the asphalt items noted above. The contractor will not be permitted to change the Fuel Usage Factor after the bids are submitted.

SCHEDULE OF ESTIMATED COMPLETION PROGRESS:

(7-15-08) (Rev. 5-13-19)

108-2

SP1 G58

The Contractor's attention is directed to the Standard Special Provision entitled *Availability of Funds Termination of Contracts* included elsewhere in this proposal. The Department of Transportation's schedule of estimated completion progress for this project as required by that Standard Special Provision is as follows:

	<u>Fiscal Year</u>	<u>Progress (% of Dollar Value)</u>
2022	(7/01/21 - 6/30/22)	0% of Total Amount Bid
2023	(7/01/22 - 6/30/23)	100% of Total Amount Bid
2024	(7/01/23 - 6/30/24)	0% of Total Amount Bid
2025	(7/01/24 - 6/30/25)	0% of Total Amount Bid
2026	(7/01/25 - 6/30/26)	0% of Total Amount Bid

The Contractor shall also furnish his own progress schedule in accordance with Article 108-2 of the *2018 Standard Specifications*. Any acceleration of the progress as shown by the Contractor's progress schedule over the progress as shown above shall be subject to the approval of the Engineer.

MINORITY BUSINESS ENTERPRISE AND WOMEN BUSINESS ENTERPRISE (DIVISIONS):

(10-16-07)(Rev. 8-17-21)

102-15(J)

SP1 G67

Description

The purpose of this Special Provision is to carry out the North Carolina Department of Transportation's policy of ensuring nondiscrimination in the award and administration of contracts financed in whole or in part with State funds.

Definitions

Additional MBE/WBE Subcontractors - Any MBE/WBE submitted at the time of bid that will not be used to meet the Combined MBE/WBE goal. No submittal of a Letter of Intent is required.

Combined MBE/WBE Goal: A portion of the total contract, expressed as a percentage that is to be performed by committed MBE/WBE subcontractors.

Committed MBE/WBE Subcontractor - Any MBE/WBE submitted at the time of bid that is being used to meet the Combined MBE / WBE goal by submission of a Letter of Intent. Or any MBE or WBE used as a replacement for a previously committed MBE or WBE firm.

Contract Goal Requirement - The approved participation at time of award, but not greater than the advertised Combined MBE/WBE contract goal.

Goal Confirmation Letter - Written documentation from the Department to the bidder confirming the Contractor's approved, committed participation along with a listing of the committed MBE and WBE firms.

Manufacturer - A firm that operates or maintains a factory or establishment that produces on the premises, the materials or supplies obtained by the Contractor.

MBE Participation (Anticipated) - A portion of the total contract, expressed as a percentage that is anticipated to be performed by committed MBE subcontractor(s).

Minority Business Enterprise (MBE) - A firm certified as a Disadvantaged Minority-Owned Business Enterprise through the North Carolina Unified Certification Program.

Regular Dealer - A firm that owns, operates, or maintains a store, warehouse, or other establishment in which the materials or supplies required for the performance of the contract are bought, kept in stock, and regularly sold to the public in the usual course of business. A regular dealer engages in, as its principal business and in its own name, the purchase and sale or lease of the products in question. A regular dealer in such bulk items as steel, cement, gravel, stone, and petroleum products need not keep such products in stock, if it owns and operates distribution equipment for the products. Brokers and packagers are not regarded as manufacturers or regular dealers within the meaning of this section.

Replacement / Substitution – A full or partial reduction in the amount of work subcontracted to a committed (or an approved substitute) MBE/WBE firm.

North Carolina Unified Certification Program (NCUCP) - A program that provides comprehensive services and information to applicants for MBE/WBE certification. The MBE/WBE program follows the same regulations as the federal Disadvantaged Business Enterprise (DBE) program in accordance with 49 CFR Part 26.

United States Department of Transportation (USDOT) - Federal agency responsible for issuing regulations (49 CFR Part 26) and official guidance for the DBE program.

WBE Participation (Anticipated) - A portion of the total contract, expressed as a percentage that is anticipated to be performed by committed WBE subcontractor(s).

Women Business Enterprise (WBE) - A firm certified as a Disadvantaged Women-Owned Business Enterprise through the North Carolina Unified Certification Program.

Forms and Websites Referenced in this Provision

Payment Tracking System - On-line system in which the Contractor enters the payments made to MBE and WBE subcontractors who have performed work on the project.
<https://apps.dot.state.nc.us/Vendor/PaymentTracking/>

DBE-IS Subcontractor Payment Information - Form for reporting the payments made to all MBE/WBE firms working on the project. This form is for paper bid projects only.
<https://connect.ncdot.gov/business/Turnpike/Documents/Form%20DBE-IS%20Subcontractor%20Payment%20Information.pdf>

RF-1 MBE/WBE Replacement Request Form - Form for replacing a committed MBE or WBE.
<http://connect.ncdot.gov/projects/construction/Construction%20Forms/DBE%20MBE%20WBE%20Replacement%20Request%20Form.pdf>

SAF Subcontract Approval Form - Form required for approval to sublet the contract.
<http://connect.ncdot.gov/projects/construction/Construction%20Forms/Subcontract%20Approval%20Form%20Rev.%202012.zip>

JC-1 Joint Check Notification Form - Form and procedures for joint check notification. The form acts as a written joint check agreement among the parties providing full and prompt disclosure of the expected use of joint checks.
<http://connect.ncdot.gov/projects/construction/Construction%20Forms/Joint%20Check%20Notification%20Form.pdf>

Letter of Intent - Form signed by the Contractor and the MBE/WBE subcontractor, manufacturer or regular dealer that affirms that a portion of said contract is going to be performed by the signed MBE/WBE for the estimated amount (based on quantities and unit prices) listed at the time of bid.
<http://connect.ncdot.gov/letting/LetCentral/Letter%20of%20Intent%20to%20Perform%20as%20a%20Subcontractor.pdf>

Listing of MBE and WBE Subcontractors Form - Form for entering MBE/WBE subcontractors on a project that will meet the Combined MBE/WBE goal. This form is for paper bids only.
[http://connect.ncdot.gov/municipalities/Bid%20Proposals%20for%20LGA%20Content/09%20MBE-WBE%20Subcontractors%20\(State\).docx](http://connect.ncdot.gov/municipalities/Bid%20Proposals%20for%20LGA%20Content/09%20MBE-WBE%20Subcontractors%20(State).docx)

Subcontractor Quote Comparison Sheet - Spreadsheet for showing all subcontractor quotes in the work areas where MBEs and WBEs quoted on the project. This sheet is submitted with good faith effort packages.
<http://connect.ncdot.gov/business/SmallBusiness/Documents/DBE%20Subcontractor%20Quote%20Comparison%20Example.xls>

Combined MBE/WBE Goal

The Combined MBE/WBE Goal for this project is **0.0 %**

The Combined Goal was established utilizing the following anticipated participation for Minority Business Enterprises and Women Business Enterprises:

(A) Minority Business Enterprises **0.0 %**

- (1) *If the anticipated MBE participation is more than zero*, the Contractor shall exercise all necessary and reasonable steps to ensure that MBEs participate in at least the percent of the contract as set forth above.
- (2) *If the anticipated MBE participation is zero*, the Contractor shall make an effort to recruit and use MBEs during the performance of the contract. Any MBE participation obtained shall be reported to the Department.

(B) Women Business Enterprises **0.0 %**

- (1) *If the anticipated WBE participation is more than zero*, the Contractor shall exercise all necessary and reasonable steps to ensure that WBEs participate in at least the percent of the contract as set forth above.
- (2) *If the anticipated WBE participation is zero*, the Contractor shall make an effort to recruit and use WBEs during the performance of the contract. Any WBE participation obtained shall be reported to the Department.

The Bidder is required to submit only participation to meet the Combined MBE/WBE Goal. The Combined Goal may be met by submitting all MBE participation, all WBE participation, or a combination of MBE and WBE participation.

Directory of Transportation Firms (Directory)

Real-time information is available about firms doing business with the Department and firms that are certified through NCUCP in the Directory of Transportation Firms. Only firms identified in the Directory as MBE and WBE certified shall be used to meet the Combined MBE / WBE goal. The Directory can be found at the following link.

<https://www.ebs.nc.gov/VendorDirectory/default.html>

The listing of an individual firm in the directory shall not be construed as an endorsement of the firm's capability to perform certain work.

Listing of MBE/WBE Subcontractors

At the time of bid, bidders shall submit all MBE and WBE participation that they anticipate to use during the life of the contract. Only those identified to meet the Combined MBE/WBE goal will be considered committed, even though the listing shall include both committed MBE/WBE subcontractors and additional MBE/WBE subcontractors. Any additional MBE/WBE subcontractor participation above the goal will follow the banking guidelines found elsewhere in this provision. All other additional MBE/WBE subcontractor participation submitted at the time of bid will be used toward the Department's overall race-neutral goals. Only those firms with current MBE and WBE certification at the time of bid

opening will be acceptable for listing in the bidder's submittal of MBE and WBE participation. The Contractor shall indicate the following required information:

(A) Electronic Bids

Bidders shall submit a listing of MBE and WBE participation in the appropriate section of the electronic submittal file.

- (1) Submit the names and addresses of MBE and WBE firms identified to participate in the contract. If the bidder uses the updated listing of MBE and WBE firms shown in the electronic submittal file, the bidder may use the dropdown menu to access the name and address of the firms.
- (2) Submit the contract line numbers of work to be performed by each MBE and WBE firm. When no figures or firms are entered, the bidder will be considered to have no MBE or WBE participation.
- (3) The bidder shall be responsible for ensuring that the MBE and WBE are certified at the time of bid by checking the Directory of Transportation Firms. If the firm is not certified at the time of the bid-letting, that MBE's or WBE's participation will not count towards achieving the Combined MBE/WBE goal.

(B) Paper Bids

- (1) *If the Combined MBE/ WBE goal is more than zero,*
 - (a) Bidders, at the time the bid proposal is submitted, shall submit a listing of MBE/WBE participation, including the names and addresses on *Listing of MBE and WBE Subcontractors* contained elsewhere in the contract documents in order for the bid to be considered responsive. Bidders shall indicate the total dollar value of the MBE and WBE participation for the contract.
 - (b) If bidders have no MBE or WBE participation, they shall indicate this on the *Listing of MBE and WBE Subcontractors* by entering the word "None" or the number "0." This form shall be completed in its entirety. **Blank forms will not be deemed to represent zero participation.** Bids submitted that do not have MBE and WBE participation indicated on the appropriate form will not be read publicly during the opening of bids. The Department will not consider these bids for award and the proposal will be rejected.
 - (c) The bidder shall be responsible for ensuring that the MBE/WBE is certified at the time of bid by checking the Directory of Transportation Firms. If the firm is not certified at the time of the bid-letting, that MBE's or WBE's participation will not count towards achieving the Combined MBE/WBE goal.
- (2) *If the Combined MBE/WBE Goal is zero,* entries on the *Listing of MBE and WBE Subcontractors* are not required for the zero goal, however any MBE or WBE participation that is achieved during the project shall be reported in accordance with requirements contained elsewhere in the special provision.

MBE or WBE Prime Contractor

When a certified MBE or WBE firm bids on a contract that contains a Combined MBE/WBE Goal, the firm is responsible for meeting the goal or making good faith efforts to meet the goal, just like any other bidder. In most cases, a MBE or WBE bidder on a contract will meet the Combined MBE/WBE goal by virtue of the work it performs on the contract with its own forces. However, all the work that is performed by the MBE or WBE bidder and any other similarly certified subcontractors will count toward the goal. The MBE or WBE bidder shall list itself along with any MBE or WBE subcontractors, if any, in order to receive credit toward the goals.

MBE/WBE prime contractors shall also follow Sections A or B listed under *Listing of MBE/WBE Subcontractors* just as a non-MBE/WBE bidder would.

Written Documentation – Letter of Intent

The bidder shall submit written documentation for each MBE/WBE that will be used to meet the Combined MBE/WBE goal of the contract, indicating the bidder's commitment to use the MBE/WBE in the contract. This documentation shall be submitted on the Department's form titled *Letter of Intent*.

The documentation shall be received in the office of the Engineer no later than 2:00 p.m. of the fifth calendar day following opening of bids, unless the fifth day falls on Saturday, Sunday or an official state holiday. In that situation, it is due in the office of the Engineer no later than 10:00 a.m. on the next official state business day.

If the bidder fails to submit the Letter of Intent from each committed MBE and WBE to be used toward the Combined MBE/WBE goal, or if the form is incomplete (i.e. both signatures are not present), the MBE/WBE participation will not count toward meeting the Combined MBE/WBE goal. If the lack of this participation drops the commitment below the Combined MBE/WBE goal, the Contractor shall submit evidence of good faith efforts for the goal not met, completed in its entirety, to the Engineer no later than 2:00 p.m. of the eighth calendar day following opening of bids, unless the eighth day falls on Saturday, Sunday or an official state holiday. In that situation, it is due in the office of the Engineer no later than 10:00 a.m. on the next official state business day.

Banking MBE/WBE Credit

If the committed MBE/WBE participation submitted exceeds the algebraic sum of the Combined MBE/WBE goal by \$1,000 or more, the excess will be placed on deposit by the Department for future use by the bidder. Separate accounts will be maintained for MBE and WBE participation and these may accumulate for a period not to exceed 24 months.

When the apparent lowest responsive bidder fails to submit sufficient participation by MBE and WBE firms to meet the advertised goal, as part of the good faith effort, the Department will consider allowing the bidder to withdraw funds to meet the Combined MBE/WBE goal as long as there are adequate funds available from the bidder's MBE and WBE bank accounts.

Submission of Good Faith Effort

If the bidder fails to meet or exceed the Combined MBE/WBE goal, the apparent lowest responsive bidder shall submit to the Department documentation of adequate good faith efforts made to reach that specific goal.

One complete set and 4 copies of this information shall be received in the office of the Engineer no later than 2:00 p.m. of the fifth calendar day following opening of bids, unless the fifth day falls on Saturday, Sunday or an official state holiday. In that situation, it is due in the office of the Engineer no later than 10:00 a.m. on the next official state business day.

Note: Where the information submitted includes repetitious solicitation letters, it will be acceptable to submit a representative letter along with a distribution list of the firms that were solicited. Documentation of MBE/WBE quotations shall be a part of the good faith effort submittal. This documentation may include written subcontractor quotations, telephone log notations of verbal quotations, or other types of quotation documentation.

Consideration of Good Faith Effort for Projects with a Combined MBE/WBE Goal More Than Zero

Adequate good faith efforts mean that the bidder took all necessary and reasonable steps to achieve the goal which, by their scope, intensity, and appropriateness, could reasonably be expected to obtain sufficient MBE/WBE participation. Adequate good faith efforts also mean that the bidder actively and aggressively sought MBE/WBE participation. Mere *pro forma* efforts are not considered good faith efforts.

The Department will consider the quality, quantity, and intensity of the different kinds of efforts a bidder has made. Listed below are examples of the types of actions a bidder will take in making a good faith effort to meet the goals and are not intended to be exclusive or exhaustive, nor is it intended to be a mandatory checklist.

- (A) Soliciting through all reasonable and available means (e.g. attendance at pre-bid meetings, advertising, written notices, use of verifiable electronic means through the use of the NCDOT Directory of Transportation Firms) the interest of all certified MBEs/WBEs that are also prequalified subcontractors. The bidder must solicit this interest within at least 10 days prior to bid opening to allow the MBEs/WBEs to respond to the solicitation. Solicitation shall provide the opportunity to MBEs/WBEs within the Division and surrounding Divisions where the project is located. The bidder must determine with certainty if the MBEs/WBEs are interested by taking appropriate steps to follow up initial solicitations.
- (B) Selecting portions of the work to be performed by MBEs/WBEs in order to increase the likelihood that the Combined MBE/WBE goal will be achieved.
 - (1) Where appropriate, break out contract work items into economically feasible units to facilitate MBE/WBE participation, even when the prime contractor might otherwise prefer to perform these work items with its own forces.
 - (2) Negotiate with subcontractors to assume part of the responsibility to meet the advertised goal when the work to be sublet includes potential for MBE/WBE participation (2nd and 3rd tier subcontractors).
- (C) Providing interested certified MBEs/WBEs that are also prequalified subcontractors with adequate information about the plans, specifications, and requirements of the contract in a timely manner to assist them in responding to a solicitation.
- (D)
 - (1) Negotiating in good faith with interested MBEs/WBEs. It is the bidder's responsibility to make a portion of the work available to MBE/WBE subcontractors and suppliers and to select those portions of the work or material needs consistent with the available MBE/WBE subcontractors and suppliers, so as to facilitate MBE/WBE

participation. Evidence of such negotiation includes the names, addresses, and telephone numbers of MBEs/WBEs that were considered; a description of the information provided regarding the plans and specifications for the work selected for subcontracting; and evidence as to why additional agreements could not be reached for MBEs/WBEs to perform the work.

- (2) A bidder using good business judgment would consider a number of factors in negotiating with subcontractors, including MBE/WBE subcontractors, and would take a firm's price and capabilities as well as the advertised goal into consideration. However, the fact that there may be some additional costs involved in finding and using MBEs/WBEs is not in itself sufficient reason for a bidder's failure to meet the advertised goal, as long as such costs are reasonable. Also, the ability or desire of a prime contractor to perform the work of a contract with its own organization does not relieve the bidder of the responsibility to make good faith efforts. Bidding contractors are not, however, required to accept higher quotes from MBEs/WBEs if the price difference is excessive or unreasonable.
- (E) Not rejecting MBEs/WBEs as being unqualified without sound reasons based on a thorough investigation of their capabilities. The bidder's standing within its industry, membership in specific groups, organizations, or associates and political or social affiliations (for example, union vs. non-union employee status) are not legitimate causes for the rejection or non-solicitation of bids in the bidder's efforts to meet the project goal.
- (F) Making efforts to assist interested MBEs/WBEs in obtaining bonding, lines of credit, or insurance as required by the recipient or bidder.
- (G) Making efforts to assist interested MBEs/WBEs in obtaining necessary equipment, supplies, materials, or related assistance or services.
- (H) Effectively using the services of available minority/women community organizations; minority/women contractors' groups; Federal, State, and local minority/women business assistance offices; and other organizations as allowed on a case-by-case basis to provide assistance in the recruitment and placement of MBEs/WBEs. Contact within 7 days from the bid opening the Business Opportunity and Work Force Development Unit at BOWD@ncdot.gov to give notification of the bidder's inability to get MBE or WBE quotes.
- (I) Any other evidence that the bidder submits which shows that the bidder has made reasonable good faith efforts to meet the advertised goal.

In addition, the Department may take into account the following:

- (1) Whether the bidder's documentation reflects a clear and realistic plan for achieving the Combined MBE/WBE goal.
- (2) The bidders' past performance in meeting the contract goal.
- (3) The performance of other bidders in meeting the advertised goal. For example, when the apparent successful bidder fails to meet the goal, but others meet it, you may reasonably raise the question of whether, with additional reasonable efforts the apparent successful bidder could have met the goal. If the apparent successful bidder fails to meet the advertised goal, but meets or exceeds the average MBE and WBE participation obtained

by other bidders, the Department may view this, in conjunction with other factors, as evidence of the apparent successful bidder having made a good faith effort.

If the Department does not award the contract to the apparent lowest responsive bidder, the Department reserves the right to award the contract to the next lowest responsive bidder that can satisfy to the Department that the Combined MBE/WBE goal can be met or that an adequate good faith effort has been made to meet the advertised goal.

Non-Good Faith Appeal

The Engineer will notify the contractor verbally and in writing of non-good faith. A contractor may appeal a determination of non-good faith made by the Goal Compliance Committee. If a contractor wishes to appeal the determination made by the Committee, they shall provide written notification to the Engineer. The appeal shall be made within 2 business days of notification of the determination of non-good faith.

Counting MBE/WBE Participation Toward Meeting the Combined MBE/WBE Goal

(A) Participation

The total dollar value of the participation by a committed MBE/WBE will be counted toward the contract goal requirements. The total dollar value of participation by a committed MBE/WBE will be based upon the value of work actually performed by the MBE/WBE and the actual payments to MBE/WBE firms by the Contractor.

(B) Joint Checks

Prior notification of joint check use shall be required when counting MBE/WBE participation for services or purchases that involves the use of a joint check. Notification shall be through submission of Form JC-1 (*Joint Check Notification Form*) and the use of joint checks shall be in accordance with the Department's Joint Check Procedures.

(C) Subcontracts (Non-Trucking)

A MBE/WBE may enter into subcontracts. Work that a MBE subcontracts to another MBE firm may be counted toward the anticipated MBE participation. The same holds for work that a WBE subcontracts to another WBE firm. Work that a MBE/WBE subcontracts to a non-MBE/WBE firm does not count toward the contract goal requirement. It should be noted that every effort shall be made by MBE and WBE contractors to subcontract to the same certification (i.e., MBEs to MBEs and WBEs to WBEs), in order to fulfill the MBE or WBE participation breakdown. This, however, may not always be possible due to the limitation of firms in the area. If the MBE or WBE firm shows a good faith effort has been made to reach out to similarly certified firms and there is no interest or availability, and they can get assistance from other certified firms, the Engineer will not hold the prime responsible for meeting the individual MBE or WBE breakdown. If a MBE or WBE contractor or subcontractor subcontracts a significantly greater portion of the work of the contract than would be expected on the basis of standard industry practices, it shall be presumed that the MBE or WBE is not performing a commercially useful function.

(D) Joint Venture

When a MBE or WBE performs as a participant in a joint venture, the Contractor may count toward its contract goal requirement a portion of the total value of participation with the MBE or WBE in

the joint venture, that portion of the total dollar value being a distinct clearly defined portion of work that the MBE or WBE performs with its forces.

(E) Suppliers

A contractor may count toward its MBE /WBE requirement 60 percent of its expenditures for materials and supplies required to complete the contract and obtained from a MBE or WBE regular dealer and 100 percent of such expenditures from a MBE or WBE manufacturer.

(F) Manufacturers and Regular Dealers

A contractor may count toward its MBE /WBE requirement the following expenditures to MBE/WBE firms that are not manufacturers or regular dealers:

- (1) The fees or commissions charged by a MBE/WBE firm for providing a *bona fide* service, such as professional, technical, consultant, or managerial services, or for providing bonds or insurance specifically required for the performance of a DOT-assisted contract, provided the fees or commissions are determined to be reasonable and not excessive as compared with fees and commissions customarily allowed for similar services.
- (2) With respect to materials or supplies purchased from a MBE/WBE, which is neither a manufacturer nor a regular dealer, count the entire amount of fees or commissions charged for assistance in the procurement of the materials and supplies, or fees or transportation charges for the delivery of materials or supplies required on a job site (but not the cost of the materials and supplies themselves), provided the fees are determined to be reasonable and not excessive as compared with fees customarily allowed for similar services.

Commercially Useful Function

(A) MBE/WBE Utilization

The Contractor may count toward its contract goal requirement only expenditures to MBEs and WBEs that perform a commercially useful function in the work of a contract. A MBE/WBE performs a commercially useful function when it is responsible for execution of the work of the contract and is carrying out its responsibilities by actually performing, managing, and supervising the work involved. To perform a commercially useful function, the MBE/WBE shall also be responsible with respect to materials and supplies used on the contract, for negotiating price, determining quality and quantity, ordering the material and installing (where applicable) and paying for the material itself. To determine whether a MBE/WBE is performing a commercially useful function, the Department will evaluate the amount of work subcontracted, industry practices, whether the amount the firm is to be paid under the contract is commensurate with the work it is actually performing and the MBE/WBE credit claimed for its performance of the work, and any other relevant factors. If it is determined that a MBE or WBE is not performing a Commercially Useful Function, the contractor may present evidence to rebut this presumption to the Department.

(B) MBE/WBE Utilization in Trucking

The following factors will be used to determine if a MBE or WBE trucking firm is performing a commercially useful function:

- (1) The MBE/WBE shall be responsible for the management and supervision of the entire trucking operation for which it is responsible on a particular contract, and there shall not be a contrived arrangement for the purpose of meeting the Combined MBE/WBE goal.
- (2) The MBE/WBE shall itself own and operate at least one fully licensed, insured, and operational truck used on the contract.
- (3) The MBE/WBE receives credit for the total value of the transportation services it provides on the contract using trucks it owns, insures, and operates using drivers it employs.
- (4) The MBE may subcontract the work to another MBE firm, including an owner-operator who is certified as a MBE. The same holds true that a WBE may subcontract the work to another WBE firm, including an owner-operator who is certified as a WBE. When this occurs, the MBE or WBE who subcontracts work receives credit for the total value of the transportation services the subcontracted MBE or WBE provides on the contract. It should be noted that every effort shall be made by MBE and WBE contractors to subcontract to the same certification (i.e., MBEs to MBEs and WBEs to WBEs), in order to fulfill the participation breakdown. This, however, may not always be possible due to the limitation of firms in the area. If the MBE or WBE firm shows a good faith effort has been made to reach out to similarly certified transportation service providers and there is no interest or availability, and they can get assistance from other certified providers, the Engineer will not hold the prime responsible for meeting the individual MBE or WBE participation breakdown.
- (5) The MBE/WBE may also subcontract the work to a non-MBE/WBE firm, including from an owner-operator. The MBE/WBE who subcontracts the work to a non-MBE/WBE is entitled to credit for the total value of transportation services provided by the non-MBE/WBE subcontractor not to exceed the value of transportation services provided by MBE/WBE-owned trucks on the contract. Additional participation by non-MBE/WBE subcontractors receives credit only for the fee or commission it receives as a result of the subcontract arrangement. The value of services performed under subcontract agreements between the MBE/WBE and the Contractor will not count towards the MBE/WBE contract requirement.
- (6) A MBE/WBE may lease truck(s) from an established equipment leasing business open to the general public. The lease must indicate that the MBE/WBE has exclusive use of and control over the truck. This requirement does not preclude the leased truck from working for others during the term of the lease with the consent of the MBE/WBE, so long as the lease gives the MBE/WBE absolute priority for use of the leased truck. This type of lease may count toward the MBE/WBE's credit as long as the driver is under the MBE/WBE's payroll.
- (7) Subcontracted/leased trucks shall display clearly on the dashboard the name of the MBE/WBE that they are subcontracted/leased to and their own company name if it is not identified on the truck itself. Magnetic door signs are not permitted.

MBE/WBE Replacement

When a Contractor has relied on a commitment to a MBE or WBE subcontractor (or an approved substitute MBE or WBE subcontractor) to meet all or part of a contract goal requirement, the contractor shall not terminate the MBE/WBE subcontractor for convenience. This includes, but is not limited to, instances in which the Contractor seeks to perform the work of the terminated subcontractor with another MBE/WBE subcontractor, a non-MBE/WBE subcontractor, or with the Contractor's own forces or those of an affiliate.

The Contractor must give notice in writing both by certified mail and email to the MBE/WBE subcontractor, with a copy to the Engineer of its intent to request to terminate and/or substitute, and the reason for the request. The Contractor must give the MBE/WBE subcontractor five (5) business days to respond to the Contractor's Notice of Intent to Request Termination and/or Substitution. If the MBE/WBE subcontractor objects to the intended termination/substitution, the MBE/WBE, within five (5) business days must advise the Contractor and the Department of the reasons why the action should not be approved. The five-day notice period shall begin on the next business day after written notice is provided to the MBE/WBE subcontractor.

A committed MBE/WBE subcontractor may only be terminated after receiving the Department's written approval based upon a finding of good cause for the proposed termination and/or substitution. For purposes of this section, good cause shall include the following circumstances:

- (a) The listed MBE/WBE subcontractor fails or refuses to execute a written contract;
- (b) The listed MBE/WBE subcontractor fails or refuses to perform the work of its subcontract in a way consistent with normal industry standards. Provided, however, that good cause does not exist if the failure or refusal of the MBE/WBE subcontractor to perform its work on the subcontract results from the bad faith or discriminatory action of the prime contractor;
- (c) The listed MBE/WBE subcontractor fails or refuses to meet the prime contractor's reasonable, nondiscriminatory bond requirements;
- (d) The listed MBE/WBE subcontractor becomes bankrupt, insolvent, or exhibits credit unworthiness;
- (e) The listed MBE/WBE subcontractor is ineligible to work on public works projects because of suspension and debarment proceedings pursuant to 2 CFR Parts 180, 215 and 1,200 or applicable state law;
- (f) The listed MBE/WBE subcontractor is not a responsible contractor;
- (g) The listed MBE/WBE voluntarily withdraws from the project and provides written notice of withdrawal;
- (h) The listed MBE/WBE is ineligible to receive MBE/WBE credit for the type of work required;
- (i) A MBE/WBE owner dies or becomes disabled with the result that the listed MBE/WBE contractor is unable to complete its work on the contract;
- (j) Other documented good cause that compels the termination of the MBE/WBE subcontractor. Provided, that good cause does not exist if the prime contractor seeks to terminate a MBE/WBE it relied upon to obtain the contract so that the prime contractor can self-perform the work for which the MBE/WBE contractor was engaged or so that the prime contractor can substitute another MBE/WBE or non-MBE/WBE contractor after contract award.

The Contractor shall comply with the following for replacement of a committed MBE/WBE:

(A) Performance Related Replacement

When a committed MBE/WBE is terminated for good cause as stated above, an additional MBE/WBE that was submitted at the time of bid may be used to fulfill the MBE/WBE commitment to meet the Combined MBE/WBE Goal. A good faith effort will only be required for removing a committed MBE/WBE if there were no additional MBE/WBEs submitted at the time of bid to cover the same amount of work as the MBE/WBE that was terminated.

If a replacement MBE/WBE is not found that can perform at least the same amount of work as the terminated MBE/WBE, the Contractor shall submit a good faith effort documenting the steps taken. Such documentation shall include, but not be limited to, the following:

- (1) Copies of written notification to MBE/WBEs that their interest is solicited in contracting the work defaulted by the previous MBE/WBE or in subcontracting other items of work in the contract.
- (2) Efforts to negotiate with MBE/WBEs for specific subbids including, at a minimum:
 - (a) The names, addresses, and telephone numbers of MBE/WBEs who were contacted.
 - (b) A description of the information provided to MBE/WBEs regarding the plans and specifications for portions of the work to be performed.
- (3) A list of reasons why MBE/WBE quotes were not accepted.
- (4) Efforts made to assist the MBE/WBEs contacted, if needed, in obtaining bonding or insurance required by the Contractor.

(B) Decertification Replacement

- (1) When a committed MBE/WBE is decertified by the Department after the SAF (*Subcontract Approval Form*) has been received by the Department, the Department will not require the Contractor to solicit replacement MBE/WBE participation equal to the remaining work to be performed by the decertified firm. The participation equal to the remaining work performed by the decertified firm will count toward the contract goal requirement.
- (2) When a committed MBE/WBE is decertified prior to the Department receiving the SAF (*Subcontract Approval Form*) for the named MBE/WBE firm, the Contractor shall take all necessary and reasonable steps to replace the MBE/WBE subcontractor with another MBE/WBE subcontractor to perform at least the same amount of work to meet the Combined MBE/WBE goal requirement. If a MBE/WBE firm is not found to do the same amount of work, a good faith effort must be submitted to NCDOT (see A herein for required documentation).
- (3) Exception: If the MBE/WBE's ineligibility is caused solely by its having exceeded the size standard during the performance of the contract, the Department will not require the Contractor to solicit replacement MBE/WBE participation equal to the remaining work to be performed by the decertified firm. The participation equal to the remaining work

performed by the decertified firm will count toward the contract goal requirement and overall goal.

All requests for replacement of a committed MBE/WBE firm shall be submitted to the Engineer for approval on Form RF-1 (*DBE Replacement Request*). If the Contractor fails to follow this procedure, the Contractor may be disqualified from further bidding for a period of up to 6 months.

Changes in the Work

When the Engineer makes changes that result in the reduction or elimination of work to be performed by a committed MBE/WBE, the Contractor will not be required to seek additional participation. When the Engineer makes changes that result in additional work to be performed by a MBE/WBE based upon the Contractor's commitment, the MBE/WBE shall participate in additional work to the same extent as the MBE/WBE participated in the original contract work.

When the Engineer makes changes that result in extra work, which has more than a minimal impact on the contract amount, the Contractor shall seek additional participation by MBEs/WBEs unless otherwise approved by the Engineer.

When the Engineer makes changes that result in an alteration of plans or details of construction, and a portion or all of the work had been expected to be performed by a committed MBE/WBE, the Contractor shall seek participation by MBEs/WBEs unless otherwise approved by the Engineer.

When the Contractor requests changes in the work that result in the reduction or elimination of work that the Contractor committed to be performed by a MBE/WBE, the Contractor shall seek additional participation by MBEs/WBEs equal to the reduced MBE/WBE participation caused by the changes.

Reports and Documentation

A SAF (*Subcontract Approval Form*) shall be submitted for all work which is to be performed by a MBE/WBE subcontractor. The Department reserves the right to require copies of actual subcontract agreements involving MBE/WBE subcontractors.

When using transportation services to meet the contract commitment, the Contractor shall submit a proposed trucking plan in addition to the SAF. The plan shall be submitted prior to beginning construction on the project. The plan shall include the names of all trucking firms proposed for use, their certification type(s), the number of trucks owned by the firm, as well as the individual truck identification numbers, and the line item(s) being performed.

Within 30 calendar days of entering into an agreement with a MBE/WBE for materials, supplies or services, not otherwise documented by the SAF as specified above, the Contractor shall furnish the Engineer a copy of the agreement. The documentation shall also indicate the percentage (60% or 100%) of expenditures claimed for MBE/WBE credit.

Reporting Minority and Women Business Enterprise Participation

The Contractor shall provide the Engineer with an accounting of payments made to all MBE and WBE firms, including material suppliers and contractors at all levels (prime, subcontractor, or second tier subcontractor). This accounting shall be furnished to the Engineer for any given month by the end of the following month. Failure to submit this information accordingly may result in the following action:

- (A) Withholding of money due in the next partial pay estimate; or
- (B) Removal of an approved contractor from the prequalified bidders' list or the removal of other entities from the approved subcontractors list.

While each contractor (prime, subcontractor, 2nd tier subcontractor) is responsible for accurate accounting of payments to MBEs/WBEs, it shall be the prime contractor's responsibility to report all monthly and final payment information in the correct reporting manner.

Failure on the part of the Contractor to submit the required information in the time frame specified may result in the disqualification of that contractor and any affiliate companies from further bidding until the required information is submitted.

Failure on the part of any subcontractor to submit the required information in the time frame specified may result in the disqualification of that contractor and any affiliate companies from being approved for further work on future projects until the required information is submitted.

Contractors reporting transportation services provided by non-MBE/WBE lessees shall evaluate the value of services provided during the month of the reporting period only.

At any time, the Engineer can request written verification of subcontractor payments. The Contractor shall report the accounting of payments through the Department's DBE Payment Tracking System.

Failure to Meet Contract Requirements

Failure to meet contract requirements in accordance with Subarticle 102-15(J) of the *2018 Standard Specifications* may be cause to disqualify the Contractor.

CONTRACTOR'S LICENSE REQUIREMENTS:

(7-1-95)

102-14

SP1 G88

If the successful bidder does not hold the proper license to perform any plumbing, heating, air conditioning, or electrical work in this contract, he will be required to sublet such work to a contractor properly licensed in accordance with *Article 2 of Chapter 87 of the General Statutes* (licensing of heating, plumbing, and air conditioning contractors) and *Article 4 of Chapter 87 of the General Statutes* (licensing of electrical contractors).

RESTRICTIONS ON ITS EQUIPMENT AND SERVICES:

(11-17-20)

SP01 G090

All telecommunications, video or other ITS equipment or services installed or utilized on this project must be in conformance with UNIFORM ADMINISTRATIVE REQUIREMENTS, COST PRINCIPLES, AND AUDIT REQUIREMENTS FOR FEDERAL AWARDS 2 CFR, § 200.216 **Prohibition on certain telecommunications and video surveillance services or equipment.**

USE OF UNMANNED AIRCRAFT SYSTEM (UAS):

(8-20-19)

SP1 G092

The Contractor shall adhere to all Federal, State and Local regulations and guidelines for the use of Unmanned Aircraft Systems (UAS). This includes but is not limited to US 14 CFR Part 107 *Small UAS Rule*, NC GS 15A-300.2 *Regulation of launch and recovery sites*, NC GS 63-95 *Training required for the operation of unmanned aircraft systems*, NC GS 63-96 *Permit required for commercial operation of unmanned aircraft system*, and NCDOT UAS Policy. The required operator certifications include possessing a current Federal Aviation Administration (FAA) Remote Pilot Certificate, a NC UAS Operator Permit as well as operating a UAS registered with the FAA.

Prior to beginning operations, the Contractor shall complete the NCDOT UAS – Flight Operation Approval Form and submit it to the Engineer for approval. All UAS operations shall be approved by the Engineer prior to beginning the operations.

All contractors or subcontractors operating UAS shall have UAS specific general liability insurance to cover all operations under this contract.

The use of UAS is at the Contractor's discretion. No measurement or payment will be made for the use of UAS. In the event that the Department directs the Contractor to utilize UAS, payment will be in accordance with Article 104-7 Extra Work.

EQUIPMENT IDLING GUIDELINES:

(1-19-21)

107

SP1 G096

Exercise reduced fuel consumption and reduced equipment emissions during the construction of all work associated with this contract. Employees engaged in the construction of this project should turn off vehicles when stopped for more than thirty (30) minutes and off-highway equipment should idle no longer than fifteen (15) consecutive minutes.

These guidelines for turning off vehicles and equipment when idling do not apply to:

1. Idling when queuing.
2. Idling to verify the vehicle is in safe operating condition.
3. Idling for testing, servicing, repairing or diagnostic purposes.
4. Idling necessary to accomplish work for which the vehicle was designed (such as operating a crane, mixing concrete, etc.).
5. Idling required to bring the machine system to operating temperature.
6. Emergency vehicles, utility company, construction, and maintenance vehicles where the engines must run to perform needed work.
7. Idling to ensure safe operation of the vehicle.
8. Idling when the propulsion engine is providing auxiliary power for other than heating or air conditioning. (such as hydraulic systems for pavers)
9. When specific traffic, safety, or emergency situations arise.
10. If the ambient temperature is less than 32 degrees Fahrenheit. Limited idling to provide for the safety of vehicle occupants (e.g. to run the heater).
11. If the ambient temperature is greater than 90 degrees Fahrenheit. Limited idling to provide for the safety of vehicle occupants of off-highway equipment (e.g. to run the air conditioning) no more than 30 minutes.

12. Diesel powered vehicles may idle for up to 30 minutes to minimize restart problems. Any vehicle, truck, or equipment in which the primary source of fuel is natural gas or electricity is exempt from the idling limitations set forth in this special provision.

ELECTRONIC BIDDING:

(2-19-19)

101, 102, 103

SP1 G140

Revise the *2018 Standard Specifications* as follows:

Page 1-4, Article 101-3, DEFINITIONS, BID (OR PROPOSAL) *Electronic Bid*, line 1, replace “Bid Express®” with “the approved electronic bidding provider”.

Page 1-15, Subarticle 102-8(B), *Electronic Bids*, lines 39-40, replace “to Bid Express®” with “via the approved electronic bidding provider”.

Page 1-15, Subarticle 102-8(B)(1), *Electronic Bids*, line 41, delete “from Bid Express®”

Page 1-17, Subarticle 102-9(C)(2), *Electronic Bids*, line 21, replace “Bid Express® miscellaneous folder within the .ebs” with “electronic submittal”.

Page 1-29, Subarticle 103-4(C)(2), *Electronic Bids*, line 32, replace “.ebs miscellaneous data file of Expedite” with “electronic submittal file”

AWARD LIMITS:

(4-19-22)

103

SP1 G141

Revise the *2018 Standard Specifications* as follows:

Page 1-29, Subarticle 103-4(C), *Award Limits*, line 4-8, delete and replace the first sentence in the first paragraph with the following:

A bidder who desires to bid on more than one project on which bids are to be opened in the same letting and who desires to avoid receiving an award of more projects than he is equipped to handle, may bid on any number of projects but may limit the total amount of work awarded to him on selected projects by completing the form Award Limits on Multiple Projects for each project subject to the award limit.

TWELVE MONTH GUARANTEE:

(7-15-03)

108

SP1 G145

- (A) The Contractor shall guarantee materials and workmanship against latent and patent defects arising from faulty materials, faulty workmanship or negligence for a period of twelve months following the date of final acceptance of the work for maintenance and shall replace such defective materials and workmanship without cost to the Department. The Contractor will not be responsible for damage due to faulty design, normal wear and tear, for negligence on the part of the Department, and/or for use in excess of the design.
- (B) Where items of equipment or material carry a manufacturer’s guarantee for any period in excess of twelve months, then the manufacturer’s guarantee shall apply for that particular piece of equipment or material. The Department’s first remedy shall be through the manufacturer although the Contractor is responsible for invoking the warranted repair work with the manufacturer. The

Contractor's responsibility shall be limited to the term of the manufacturer's guarantee. NCDOT would be afforded the same warranty as provided by the Manufacturer.

This guarantee provision shall be invoked only for major components of work in which the Contractor would be wholly responsible for under the terms of the contract. Examples would include pavement structures, bridge components, and sign structures. This provision will not be used as a mechanism to force the Contractor to return to the project to make repairs or perform additional work that the Department would normally compensate the Contractor for. In addition, routine maintenance activities (i.e. mowing grass, debris removal, ruts in earth shoulders,) are not parts of this guarantee.

Appropriate provisions of the payment and/or performance bonds shall cover this guarantee for the project.

To ensure uniform application statewide the Division Engineer will forward details regarding the circumstances surrounding any proposed guarantee repairs to the Chief Engineer for review and approval prior to the work being performed.

OUTSOURCING OUTSIDE THE USA:

(9-21-04) (Rev. 5-16-06)

SP1 G150

All work on consultant contracts, services contracts, and construction contracts shall be performed in the United States of America. No work shall be outsourced outside of the United States of America.

Outsourcing for the purpose of this provision is defined as the practice of subcontracting labor, work, services, staffing, or personnel to entities located outside of the United States.

The North Carolina Secretary of Transportation shall approve exceptions to this provision in writing.

PROJECT SPECIAL PROVISIONS

ROADWAY

NOTES TO CONTRACTOR:

- The Shallotte Rest Area shall remain closed for the duration of the project until final acceptance. Please coordinate with Keith Groves at (910) 259-4919; bkgrones@ncdot.gov to close the rest area prior to the date of availability.

SUPPLEMENTAL SURVEYING:

(4-20-21)

801

SP8 R03

Revise the *2018 Standard Specifications* as follows:

Page 8-7, Article 801-3 MEASUREMENT AND PAYMENT, lines 10-11, replace with the following:

Supplemental Surveying Office Calculations will be paid at the stated price of \$85.00 per hour. *Supplemental Field Surveying* will be paid at the stated price of \$145.00 per hour. The

PORTLAND CEMENT CONCRETE PRODUCTION AND DELIVERY:

(9-15-20)

1000, 1014, 1024

SP10 R01

Revise the *2018 Standard Specifications* as follows:

Page 10-6, Table 1000-1, REQUIREMENTS FOR CONCRETE, replace with the following:

TABLE 1000-1 REQUIREMENTS FOR CONCRETE											
Class of Concrete	Min. Compressive Strength at 28 days	Maximum Water-Cement Ratio				Consistency Maximum Slump		Cement Content			
		Air-Entrained Concrete		Non-Air- Entrained Concrete		Vibrated	Non- Vibrated	Vibrated		Non-Vibrated	
		Rounded Aggregate	Angular Aggregate	Rounded Aggregate	Angular Aggregate			Min.	Max.	Min.	Max.
		<i>Units</i>	<i>psi</i>					<i>inch</i>	<i>inch</i>	<i>lb/cy</i>	<i>lb/cy</i>
AA	4500	0.381	0.426	---	---	3.5 ^A	---	639	715	---	---
AA Slip Form	4500	0.381	0.426	---	---	1.5	---	639	715	---	---
Drilled Pier	4500	---	---	0.450	0.450	---	5 – 7 dry	---	---	640	800
A	3000	0.488	0.532	0.550	0.594	3.5 ^A	4.0	564	---	602	---

B	2500	0.488	0.567	0.559	0.630	1.5 machine placed 2.5 ^A hand placed	4.0	508	---	545	---
Sand Light-weight	4500	---	0.420	---	---	4.0 ^A	---	715	---	---	---
Latex Modified	3000 (at 7 days)	0.400	0.400	---	---	6.0	---	658	---	---	---
Flowable Fill excavatable	150 max. (at 56 days)	as needed	as needed	as needed	as needed	---	Flowable	---	---	40	100
Flowable Fill non- excavatable	125	as needed	as needed	as needed	as needed	---	Flowable	---	---	100	as needed
Pavement	4500 Design, field 650 flexural, design only	0.559	0.559	---	---	1.5 slip form 3.0 hand placed	---	526	---	---	---
Precast	See Table 1077-1	as needed	as needed	---	---	6.0	as needed	as needed	as needed	as needed	as needed
Prestressed	per contract	See Table 1078-1	See Table 1078-1	---	---	8.0	---	564	as needed	---	---

- A. The slump may be increased to 6 inches, provided the increase in slump is achieved by adding a chemical admixture conforming to Section 1024-3. In no case shall the water-cement ratio on the approved design be exceeded. Concrete exhibiting segregation and/or excessive bleeding will be rejected. Utilizing an Admixture to modify slump does not relinquish the contractor's responsibility to ensure the final product quality and overall configuration meets design specifications. Caution should be taken when placing these modified mixes on steep grades to prevent unintended changes to the set slope.

MATERIALS FOR PORTLAND CEMENT CONCRETE:

(9-15-20)

1000, 1024

SP10 R24

Revise the *2018 Standard Specifications* as follows:

Page 10-52, Article 1024-4, WATER, lines 3-6, delete and replace with the following:

Test water from wells at all locations. Test public water supplies from all out of state locations and in the following counties: Beaufort, Bertie, Brunswick, Camden, Carteret, Chowan, Craven, Currituck, Dare, Gates, Hyde, New Hanover, Onslow, Pamlico, Pasquotank, Pender, Perquimans, Tyrell and Washington unless the Engineer waives the testing requirements.

Page 10-52, Table 1024-2, PHYSICAL PROPERTIES OF WATER, replace with the following:

Property	Requirement	Test Method
Compression Strength, minimum percent of control at 3 and 7 days	90%	ASTM C1602
Time of set, deviation from control	From 1:00 hr. earlier to 1:30 hr. later	ASTM C1602
pH	4.5 to 8.5	ASTM D1293 *
Chloride Ion Content, Max.	250 ppm	ASTM D512 *
Total Solids Content (Residue), Max.	1,000 ppm	SM 2540B *
Resistivity, Min.	0.500 kohm-cm	ASTM D1125 *

*Denotes an alternate method is acceptable. Test method used shall be referenced in the test report.

MATERIAL AND EQUIPMENT STORAGE & PARKING OF PERSONAL VEHICLES:

11-17-21

1101

SP11 R03

Revise the *2018 Standard Specifications* as follows:

Page 11-2, Article 1101-8 MATERIAL AND EQUIPMENT STORAGE, line 35-38, delete and replace with the following:

When work is not in progress, keep all personnel, equipment, machinery, tools, construction debris, materials and supplies away from active travel lanes that meets Table 1101-1.

TABLE 1101-1 MATERIAL AND EQUIPMENT STORAGE FROM ACTIVE TRAVEL LANES	
Posted Speed Limit (mph)	Distance (ft)
40 or less	≥ 18

45-50	≥ 28
55	≥ 32
60 or higher	≥ 40

When vehicles, equipment and materials are protected by concrete barrier or guardrail, they shall be offset at least 5 feet from the barrier or guardrail.

Page 11-2, Article 1101-9 PARKING OF PERSONAL VEHICLES, line 40-41, delete and replace with the following:

Provide staging areas for personal vehicle parking in accordance with section 1101-8 or as directed by the Engineer before use.

WORK ZONE INSTALLER:

(7-20-21)(Rev. 7-19-22)

1101, 1150

SP11 R04

Provide the service of at least one qualified work zone installer during the setup, installation, and removal of temporary traffic control within the highway right of way. The qualified work zone installer shall serve as crew leader and shall be on site and directing the installation and removal of temporary traffic control. If multiple temporary traffic control installations or removals are occurring simultaneously, then each shall have a qualified work zone installer.

The work zone installer shall be qualified by an NCDOT approved training agency or other approved training provider in the safe and competent set up of temporary traffic control. For a complete listing of approved training agencies, see the Work Zone Safety Training webpage.

A work zone supervisor, in accordance with Article 1101-13 of the *Standard Specifications*, may fulfill the role of the work zone installer during the setup, installation, and removal of temporary traffic control within the highway right of way provided they are on site and directing the installation and removal of temporary traffic control.

All other individuals participating in the setup, installation, and removal of temporary traffic control within the highway right of way shall be certified as a qualified flagger in accordance with Article 1150-3 of the *Standard Specifications*, even if flagging is not being performed as part of the traffic control.

Provide the name and contact information of all qualified work zone installers to the Engineer prior to or at the preconstruction conference. Additionally, provide a qualification statement that all other individuals participating in the setup, installation, and removal of temporary traffic control are qualified flaggers that have been properly trained through an NCDOT approved training agency.

All certification records for qualified work zone installers and flaggers shall be uploaded by the approved training agency or other approved training provider to the Department's Work Zone Education Verification App (WZ-EVA) prior to the qualified work zone installer or flagger performing any traffic control duties on the project. For more information about WZ-EVA, see the Work Zone Safety Training webpage.

STANDARD SPECIAL PROVISION
AVAILABILITY OF FUNDS – TERMINATION OF CONTRACTS

(5-20-08)

Z-2

General Statute 143C-6-11. (h) Highway Appropriation is hereby incorporated verbatim in this contract as follows:

(h) Amounts Encumbered. – Transportation project appropriations may be encumbered in the amount of allotments made to the Department of Transportation by the Director for the estimated payments for transportation project contract work to be performed in the appropriation fiscal year. The allotments shall be multiyear allotments and shall be based on estimated revenues and shall be subject to the maximum contract authority contained in *General Statute 143C-6-11(c)*. Payment for transportation project work performed pursuant to contract in any fiscal year other than the current fiscal year is subject to appropriations by the General Assembly. Transportation project contracts shall contain a schedule of estimated completion progress, and any acceleration of this progress shall be subject to the approval of the Department of Transportation provided funds are available. The State reserves the right to terminate or suspend any transportation project contract, and any transportation project contract shall be so terminated or suspended if funds will not be available for payment of the work to be performed during that fiscal year pursuant to the contract. In the event of termination of any contract, the contractor shall be given a written notice of termination at least 60 days before completion of scheduled work for which funds are available. In the event of termination, the contractor shall be paid for the work already performed in accordance with the contract specifications.

Payment will be made on any contract terminated pursuant to the special provision in accordance with Subarticle 108-13(D) of the *2018 Standard Specifications*.

STANDARD SPECIAL PROVISION**ERRATA**

(10-16-18) (Rev. 7-19-22)

Z-4

Revise the *2018 Standard Specifications* as follows:

Division 4

Page 4-84, Article 458-5 MEASUREMENT AND PAYMENT, line 31, replace article number “454-1” with “458-1”.

Division 6

Page 6-7, Article 609-1 DESCRIPTION, line 29, replace article number “609-10” with “609-9”.

Page 6-26, Subarticle 610-13(A)(1) Acceptance for New Construction, line 31, replace Table number “610-7” with “610-8”.

Page 6-29, Subarticle 610-13(B) North Carolina Hearne Straightedge, line 32, replace Table number “610-8” with “610-9”.

Page 6-31, Article 610-14 DENSITY ACCEPTANCE, Specified Density prior to line 30 and line 32, replace Table number “610-6” with “610-7”.

Division 7

Page 7-27, Article 725-1 MEASUREMENT AND PAYMENT, line 4, replace article number “725-1” with “724-4”.

Page 7-28, Article 725-1 MEASUREMENT AND PAYMENT, line 10, replace article number “725-1” with “725-3”.

Division 10

Page 10-78, Article 1056-4 GEOTEXTILES, TABLE 1056-1, Permittivity, Type 2, replace “Table 6^D” with “Table 7^D” and Permittivity, Type 3^B, replace “Table 7^D” with “Table 8^D”.

Page 10-121, Article 1076-7, REPAIR OF GALVANIZING, line 8, replace article number “1080-9” with “1080-7”.

Page 10-162, Article 1080-50 PAINT FOR VERTICAL MARKERS, line 1, replace article number “1080-50” with “1080-10”.

Page 10-162, Article 1080-61 EPOXY RESIN FOR REINFORCING STEEL, line 5, replace article number “1080-61” with “1080-11”.

Page 10-162, Article 1080-72 ABRASIVE MATERIALS FOR BLAST CLEANING STEEL, line 22, replace article number “1080-72” with “1080-12”.

Page 10-163, Article 1080-83 FIELD PERFORMANCE AND SERVICES, line 25, replace article number “1080-83” with “1080-13”.

Division 17

Page 17-15, Article 1715-4 MEASUREMENT AND PAYMENT, lines 42-44, replace the second sentence with the following:

An example is an installation of a single 1.25 inch HDPE conduit would be paid as:

Directional Drill (1)(1.25") Linear Foot

Page 17-15, Subarticle 1715-3(E) Bore and Jack, line 5, replace article number "1540-4" with "1550-4".

Page 17-15, Subarticle 1715-3(E) Bore and Jack, lines 10 & 11, replace "*NCDOT Policies and Procedures for Accommodating Utilities on Highway Rights of Way*" with "*NCDOT Utilities Accommodations Manual*".

STANDARD SPECIAL PROVISION**PLANT AND PEST QUARANTINES****(Imported Fire Ant, Gypsy Moth, Witchweed, Emerald Ash Borer, Guava Root Knot Nematode,
And Other Noxious Weeds)**

(3-18-03) (Rev. 5-21-19)

Z-04a

Within Quarantined Area

This project may be within a county regulated for plant and/or pests. If the project or any part of the Contractor's operations is located within a quarantined area, thoroughly clean all equipment prior to moving out of the quarantined area. Comply with federal/state regulations by obtaining a certificate or limited permit for any regulated article moving from the quarantined area.

Originating in a Quarantined County

Obtain a certificate or limited permit issued by the N.C. Department of Agriculture/United States Department of Agriculture. Have the certificate or limited permit accompany the article when it arrives at the project site.

Contact

Contact the N.C. Department of Agriculture/United States Department of Agriculture at 1-800-206-9333, 919-707-3730, or <https://www.ncagr.gov/plantindustry/Plant/quaran/table2.htm> to determine those specific project sites located in the quarantined area or for any regulated article used on this project originating in a quarantined county.

Regulated Articles Include

1. Soil, sand, gravel, compost, peat, humus, muck, and decomposed manure, separately or with other articles. This includes movement of articles listed above that may be associated with cut/waste, ditch pulling, and shoulder cutting.
2. Plants with roots including grass sod.
3. Plant crowns and roots.
4. Bulbs, corms, rhizomes, and tubers of ornamental plants.
5. Hay, straw, fodder, and plant litter of any kind.
6. Clearing and grubbing debris.
7. Used agricultural cultivating and harvesting equipment.
8. Used earth-moving equipment.
9. Any other products, articles, or means of conveyance, of any character, if determined by an inspector to present a hazard of spreading imported fire ant, gypsy moth, witchweed, emerald ash borer, guava root knot nematode, or other noxious weeds.

STANDARD SPECIAL PROVISION**MINIMUM WAGES**

(7-21-09)

Z-5

FEDERAL: The Fair Labor Standards Act provides that with certain exceptions every employer shall pay wages at the rate of not less than SEVEN DOLLARS AND TWENTY FIVE CENTS (\$7.25) per hour.

STATE: The North Carolina Minimum Wage Act provides that every employer shall pay to each of his employees, wages at a rate of not less than SEVEN DOLLARS AND TWENTY FIVE CENTS (\$7.25) per hour.

The minimum wage paid to all skilled labor employed on this contract shall be SEVEN DOLLARS AND TWENTY FIVE CENTS (\$7.25) per hour.

The minimum wage paid to all intermediate labor employed on this contract shall be SEVEN DOLLARS AND TWENTY FIVE CENTS (\$7.25) per hour.

The minimum wage paid to all unskilled labor on this contract shall be SEVEN DOLLARS AND TWENTY FIVE CENTS (\$7.25) per hour.

This determination of the intent of the application of this act to the contract on this project is the responsibility of the Contractor.

The Contractor shall have no claim against the Department of Transportation for any changes in the minimum wage laws, Federal or State. It is the responsibility of the Contractor to keep fully informed of all Federal and State Laws affecting his contract.

STANDARD SPECIAL PROVISION

TITLE VI AND NONDISCRIMINATION:

(6-28-77)(Rev 6/19/2018)

Z-6

Revise the *2018 Standard Specifications* as follows:

Replace Article 103-4(B) with the following:

The North Carolina Department of Transportation is committed to carrying out the U.S. Department of Transportation's policy of ensuring nondiscrimination in the award and administration of contracts.

The provisions of this section related to United States Department of Transportation (US DOT) Order 1050.2A, Title 49 Code of Federal Regulations (CFR) part 21, 23 United States Code (U.S.C.) 140 and 23 CFR part 200 (or 49 CFR 303, 49 U.S.C. 5332 or 49 U.S.C. 47123) are applicable to all North Carolina Department of Transportation (NCDOT) contracts and to all related subcontracts, material supply, engineering, architectural and other service contracts, regardless of dollar amount. Any Federal provision that is specifically required not specifically set forth is hereby incorporated by reference.

(1) Title VI Assurances (USDOT Order 1050.2A, Appendix A)

During the performance of this contract, the contractor, for itself, its assignees, and successors in interest (hereinafter referred to as the "contractor") agrees as follows:

(a) Compliance with Regulations

The contractor (hereinafter includes consultants) shall comply with the Acts and the Regulations relative to Nondiscrimination in Federally-assisted programs of the U.S. Department of Transportation, Federal Highway Administration (FHWA), as they may be amended from time to time, which are herein incorporated by reference and made a part of this contract.

(b) Nondiscrimination

The contractor, with regard to the work performed by it during the contract, shall not discriminate on the grounds of race, color, or national origin in the selection and retention of subcontractors, including procurements of materials and leases of equipment. The contractor shall not participate directly or indirectly in the discrimination prohibited by the Acts and the Regulations, including employment practices when the contract covers any activity, project, or program set forth in Appendix B of 49 CFR Part 21.

(c) Solicitations for Subcontractors, Including Procurements of Materials and Equipment

In all solicitations, either by competitive bidding, or negotiation made by the contractor for work to be performed under a subcontract, including procurements of materials, or leases of equipment, each potential subcontractor or supplier shall be notified by the contractor of the contractor's obligations under this contract and the Acts and the Regulations relative to Nondiscrimination on the grounds of race, color, or national origin.

(d) Information and Reports

The contractor shall provide all information and reports required by the Acts, the Regulations, and directives issued pursuant thereto and shall permit access to its books, records, accounts, other sources of information, and its facilities as may be determined by the Recipient or the FHWA to be pertinent to ascertain compliance with such Acts, Regulations, and instructions. Where any information required of a contractor is in the exclusive possession of another who fails or refuses to furnish the information, the contractor shall so certify to the Recipient or the FHWA, as appropriate, and shall set forth what efforts it has made to obtain the information.

(e) Sanctions for Noncompliance:

In the event of a contractor's noncompliance with the Non-discrimination provisions of this contract, the Recipient will impose such contract sanctions as it and/or the FHWA may determine to be appropriate, including, but not limited to:

- (i) Withholding payments to the contractor under the contract until the contractor complies; and/or
 - (ii) Cancelling, terminating, or suspending a contract, in whole or in part.
- (f) Incorporation of Provisions

The contractor shall include the provisions of paragraphs (a) through (f) in every subcontract, including procurements of materials and leases of equipment, unless exempt by the Acts, the Regulations and directives issued pursuant thereto. The contractor shall take action with respect to any subcontract or procurement as the Recipient or the FHWA may direct as a means of enforcing such provisions including sanctions for noncompliance. Provided, that if the contractor becomes involved in, or is threatened with litigation by a subcontractor, or supplier because of such direction, the contractor may request the Recipient to enter into any litigation to protect the interests of the Recipient. In addition, the contractor may request the United States to enter into the litigation to protect the interests of the United States.

(2) Title VI Nondiscrimination Program (23 CFR 200.5(p))

The North Carolina Department of Transportation (NCDOT) has assured the USDOT that, as a condition to receiving federal financial assistance, NCDOT will comply with Title VI of the Civil Rights Act of 1964 and all requirements imposed by Title 49 CFR part 21 and related nondiscrimination authorities to ensure that no person shall, on the ground of race, color, national origin, limited English proficiency, sex, age, or disability (including religion/creed or income-level, where applicable), be excluded from participation in, be denied the benefits of, or be subjected to discrimination under any programs, activities, or services conducted or funded by NCDOT. Contractors and other organizations under contract or agreement with NCDOT must also comply with Title VI and related authorities, therefore:

- (a) During the performance of this contract or agreement, contractors (e.g., subcontractors, consultants, vendors, prime contractors) are responsible for complying with NCDOT's Title VI Program. Contractors are not required to prepare or submit Title VI Programs. To comply with this section, the prime contractor shall:
 1. Post NCDOT's Notice of Nondiscrimination and the Contractor's own Equal Employment Opportunity (EEO) Policy in conspicuous locations accessible to all employees, applicants and subcontractors on the jobsite.
 2. Physically incorporate the required Title VI clauses into all subcontracts on federally-assisted and state-funded NCDOT projects, and ensure inclusion by subcontractors into all lower-tier subcontracts.
 3. Required Solicitation Language. The Contractor shall include the following notification in all solicitations for bids and requests for work or material, regardless of funding source:

“The North Carolina Department of Transportation, in accordance with the provisions of Title VI of the Civil Rights Act of 1964 (78 Stat. 252, 42 U.S.C. §§ 2000d to 2000d-4) and the Regulations, hereby notifies all bidders that it will affirmatively ensure that any contract entered into pursuant to this advertisement, disadvantaged business enterprises will be afforded full and fair opportunity to submit bids in response to this invitation and will not be discriminated against on the grounds of race, color, or national origin in consideration for an award. In accordance with other related nondiscrimination authorities, bidders and contractors will also not be discriminated against on the grounds of sex, age, disability, low-income level, creed/religion, or limited English proficiency in consideration for an award.”

4. Physically incorporate the FHWA-1273, in its entirety, into all subcontracts and subsequent lower tier subcontracts on Federal-aid highway construction contracts only.
 5. Provide language assistance services (i.e., written translation and oral interpretation), free of charge, to LEP employees and applicants. Contact NCDOT OCR for further assistance, if needed.
 6. For assistance with these Title VI requirements, contact the NCDOT Title VI Nondiscrimination Program at 1-800-522-0453.
- (b) Subrecipients (e.g. cities, counties, LGAs, planning organizations) may be required to prepare and submit a Title VI Plan to NCDOT, including Title VI Assurances and/or agreements. Subrecipients must also ensure compliance by their contractors and subrecipients with Title VI. (23 CFR 200.9(b)(7))
- (c) If reviewed or investigated by NCDOT, the contractor or subrecipient agrees to take affirmative action to correct any deficiencies found within a reasonable time period, not to exceed 90 calendar days, unless additional time is granted by NCDOT. (23 CFR 200.9(b)(15))
- (d) The Contractor is responsible for notifying subcontractors of NCDOT's External Discrimination Complaints Process.
1. **Applicability**
Title VI and related laws protect participants and beneficiaries (e.g., members of the public and contractors) from discrimination by NCDOT employees, subrecipients and contractors, regardless of funding source.
 2. **Eligibility**
Any person—or class of persons—who believes he/she has been subjected to discrimination based on race, color, national origin, Limited English Proficiency (LEP), sex, age, or disability (and religion in the context of employment, aviation, or transit) may file a written complaint. The law also prohibits intimidation or retaliation of any sort.
 3. **Time Limits and Filing Options**
Complaints may be filed by the affected individual(s) or a representative and must be filed no later than 180 calendar days after the following:
 - (i) The date of the alleged act of discrimination; or
 - (ii) The date when the person(s) became aware of the alleged discrimination; or
 - (iii) Where there has been a continuing course of conduct, the date on which that conduct was discontinued or the latest instance of the conduct.
 Title VI and related discrimination complaints may be submitted to the following entities:
 - North Carolina Department of Transportation, Office of Civil Rights, Title VI Program, 1511 Mail Service Center, Raleigh, NC 27699-1511; toll free 1-800-522-0453
 - Federal Highway Administration, North Carolina Division Office, 310 New Bern Avenue, Suite 410, Raleigh, NC 27601, 919-747-7010
 - US Department of Transportation, Departmental Office of Civil Rights, External Civil Rights Programs Division, 1200 New Jersey Avenue, SE, Washington, DC 20590; 202-366-4070
 4. **Format for Complaints**
Complaints must be in writing and signed by the complainant(s) or a representative, and include the complainant's name, address, and telephone number. Complaints received by fax or e-mail will be acknowledged and processed. Allegations received by telephone will be reduced to writing and provided to the complainant for confirmation or revision before processing. Complaints will be accepted in other languages, including Braille.
 5. **Discrimination Complaint Form**
Contact NCDOT Civil Rights to receive a full copy of the Discrimination Complaint Form and procedures.

6. Complaint Basis

Allegations must be based on issues involving race, color, national origin (LEP), sex, age, disability, or religion (in the context of employment, aviation or transit). “Basis” refers to the complainant’s membership in a protected group category.

TABLE 103-1 COMPLAINT BASIS			
Protected Categories	Definition	Examples	Applicable Nondiscrimination Authorities
Race and Ethnicity	An individual belonging to one of the accepted racial groups; or the perception, based usually on physical characteristics that a person is a member of a racial group	Black/African American, Hispanic/Latino, Asian, American Indian/Alaska Native, Native Hawaiian/Pacific Islander, White	Title VI of the Civil Rights Act of 1964; 49 CFR Part 21; 23 CFR 200; 49 U.S.C. 5332(b); 49 U.S.C. 47123. <i>(Executive Order 13166)</i>
Color	Color of skin, including shade of skin within a racial group	Black, White, brown, yellow, etc.	
National Origin <i>(Limited English Proficiency)</i>	Place of birth. Citizenship is not a factor. <i>(Discrimination based on language or a person’s accent is also covered)</i>	Mexican, Cuban, Japanese, Vietnamese, Chinese	
Sex	Gender. The sex of an individual. <i>Note: Sex under this program does not include sexual orientation.</i>	Women and Men	1973 Federal-Aid Highway Act; 49 U.S.C. 5332(b); 49 U.S.C. 47123.
Age	Persons of any age	21-year-old person	Age Discrimination Act of 1975 49 U.S.C. 5332(b); 49 U.S.C. 47123.
Disability	Physical or mental impairment, permanent or temporary, or perceived.	Blind, alcoholic, para-amputee, epileptic, diabetic, arthritic	Section 504 of the Rehabilitation Act of 1973; Americans with Disabilities Act of 1990
Religion (in the context of employment) <i>(Religion/ Creed in all aspects of any aviation or transit-related construction)</i>	An individual belonging to a religious group; or the perception, based on distinguishable characteristics that a person is a member of a religious group. In practice, actions taken as a result of the moral and ethical beliefs as to what is right and wrong, which are sincerely held with the strength of traditional religious views. <i>Note: Does not have to be associated with a recognized religious group or church; if an individual sincerely holds to the belief, it is a protected religious practice.</i>	Muslim, Christian, Sikh, Hindu, etc.	Title VII of the Civil Rights Act of 1964; 23 CFR 230; FHWA-1273 Required Contract Provisions. <i>(49 U.S.C. 5332(b); 49 U.S.C. 47123)</i>

(3) Pertinent Nondiscrimination Authorities

During the performance of this contract, the contractor, for itself, its assignees, and successors in interest agrees to comply with the following non-discrimination statutes and authorities, including, but not limited to:

- (a) Title VI of the Civil Rights Act of 1964 (42 U.S.C. § 2000d et seq., 78 stat. 252), (prohibits discrimination on the basis of race, color, national origin); and 49 CFR Part 21.
- (b) The Uniform Relocation Assistance and Real Property Acquisition Policies Act of 1970, (42 U.S.C. § 4601), (prohibits unfair treatment of persons displaced or whose property has been acquired because of Federal or Federal-aid programs and projects);
- (c) Federal-Aid Highway Act of 1973, (23 U.S.C. § 324 et seq.), (prohibits discrimination on the basis of sex);
- (d) Section 504 of the Rehabilitation Act of 1973, (29 U.S.C. § 794 et seq.), as amended, (prohibits discrimination on the basis of disability) and 49 CFR Part 27;
- (e) The Age Discrimination Act of 1975, as amended, (42 U.S.C. § 6101 et seq.), (prohibits discrimination on the basis of age);
- (f) Airport and Airway Improvement Act of 1982, (49 USC § 471, Section 47123), as amended, (prohibits discrimination based on race, creed, color, national origin, or sex);
- (g) The Civil Rights Restoration Act of 1987, (PL 100-209), (Broadened the scope, coverage and applicability of Title VI of the Civil Rights Act of 1964, The Age Discrimination Act of 1975 and Section 504 of the Rehabilitation Act of 1973, by expanding the definition of the terms "programs or activities" to include all of the programs or activities of the Federal-aid recipients, sub-recipients and contractors, whether such programs or activities are Federally funded or not);
- (h) Titles II and III of the Americans with Disabilities Act, which prohibit discrimination on the basis of disability in the operation of public entities, public and private transportation systems, places of public accommodation, and certain testing entities (42 U.S.C. §§ 12131-12189) as implemented by Department of Transportation regulations at 49 C.F.R. parts 37 and 38;
- (i) The Federal Aviation Administration's Nondiscrimination statute (49 U.S.C. § 47123) (prohibits discrimination on the basis of race, color, national origin, and sex);
- (j) Executive Order 12898, Federal Actions to Address Environmental Justice in Minority Populations and Low-Income Populations, which ensures Nondiscrimination against minority populations by discouraging programs, policies, and activities with disproportionately high and adverse human health or environmental effects on minority and low-income populations;
- (k) Executive Order 13166, Improving Access to Services for Persons with Limited English Proficiency, and resulting agency guidance, national origin discrimination includes discrimination because of Limited English proficiency (LEP). To ensure compliance with Title VI, you must take reasonable steps to ensure that LEP persons have meaningful access to your programs (70 Fed. Reg. at 74087 to 74100);
- (l) Title IX of the Education Amendments of 1972, as amended, which prohibits you from discriminating because of sex in education programs or activities (20 U.S.C. 1681 et seq).
- (m) Title VII of the Civil Rights Act of 1964 (42 U.S.C. § 2000e et seq., Pub. L. 88-352), (prohibits employment discrimination on the basis of race, color, religion, sex, or national origin).

(4) Additional Title VI Assurances

***The following Title VI Assurances (Appendices B, C and D) shall apply, as applicable*

- (a) Clauses for Deeds Transferring United States Property (1050.2A, Appendix B)
The following clauses will be included in deeds effecting or recording the transfer of real property, structures, or improvements thereon, or granting interest therein from the United States pursuant to the provisions of Assurance 4.

NOW, THEREFORE, the U.S. Department of Transportation as authorized by law and upon the condition that the North Carolina Department of Transportation (NCDOT) will accept title to the lands and maintain the project constructed thereon in accordance with the North Carolina General Assembly, the Regulations for the Administration of the Federal-Aid Highway Program, and the policies and procedures prescribed by the Federal Highway Administration of the U.S. Department of Transportation in accordance and in compliance with all requirements imposed by Title 49, Code of Federal Regulations, U.S. Department of Transportation, Subtitle A, Office of the Secretary, Part 21, Nondiscrimination in Federally-assisted programs of the U.S. Department of Transportation pertaining to and effectuating the provisions of Title VI of the Civil Rights Act of 1964 (78 Stat. 252; 42 U.S.C. § 2000d to 2000d-4), does hereby remise, release, quitclaim and convey unto the NCDOT all the right, title and interest of the U.S. Department of Transportation in and to said lands described in Exhibit A attached hereto and made a part hereof.

(HABENDUM CLAUSE)

TO HAVE AND TO HOLD said lands and interests therein unto the North Carolina Department of Transportation (NCDOT) and its successors forever, subject, however, to the covenants, conditions, restrictions and reservations herein contained as follows, which will remain in effect for the period during which the real property or structures are used for a purpose for which Federal financial assistance is extended or for another purpose involving the provision of similar services or benefits and will be binding on the NCDOT, its successors and assigns.

The NCDOT, in consideration of the conveyance of said lands and interests in lands, does hereby covenant and agree as a covenant running with the land for itself, its successors and assigns, that (1) no person will on the grounds of race, color, or national origin, be excluded from participation in, be denied the benefits of, or be otherwise subjected to discrimination with regard to any facility located wholly or in part on, over, or under such lands hereby conveyed [,] [and]* (2) that the NCDOT will use the lands and interests in lands and interests in lands so conveyed, in compliance with all requirements imposed by or pursuant to Title 49, Code of Federal Regulations, U.S. Department of Transportation, Subtitle A, Office of the Secretary, Part 21, Non-discrimination in Federally-assisted programs of the U.S. Department of Transportation, Effectuation of Title VI of the Civil Rights Act of 1964, and as said Regulations and Acts may be amended [, and (3) that in the event of breach of any of the above-mentioned nondiscrimination conditions, the Department will have a right to enter or re-enter said lands and facilities on said land, and that above described land and facilities will thereon revert to and vest in and become the absolute property of the U.S. Department of Transportation and its assigns as such interest existed prior to this instruction].*

(*Reverter clause and related language to be used only when it is determined that such a clause is necessary in order to make clear the purpose of Title VI.)

- (b) Clauses for Transfer of Real Property Acquired or Improved Under the Activity, Facility, or Program (1050.2A, Appendix C)

The following clauses will be included in deeds, licenses, leases, permits, or similar instruments entered into by the North Carolina Department of Transportation (NCDOT) pursuant to the provisions of Assurance 7(a):

1. The (grantee, lessee, permittee, etc. as appropriate) for himself/herself, his/her heirs, personal representatives, successors in interest, and assigns, as a part of the consideration hereof, does hereby covenant and agree [in the case of deeds and leases add "as a covenant running with the land"] that:

- (i.) In the event facilities are constructed, maintained, or otherwise operated on the property described in this (deed, license, lease, permit, etc.) for a purpose for which a U.S. Department of Transportation activity, facility, or program is extended or for another purpose involving the provision of similar services or benefits, the (grantee, licensee, lessee, permittee, etc.) will maintain and operate such facilities and services in compliance with all requirements imposed by the Acts and Regulations (as may be amended) such that no person on the grounds of race, color, or national origin, will be excluded from participation in, denied the benefits of, or be otherwise subjected to discrimination in the use of said facilities.
- 2. With respect to licenses, leases, permits, etc., in the event of breach of any of the above Nondiscrimination covenants, the NCDOT will have the right to terminate the (lease, license, permit, etc.) and to enter, re-enter, and repossess said lands and facilities thereon, and hold the same as if the (lease, license, permit, etc.) had never been made or issued. *
- 3. With respect to a deed, in the event of breach of any of the above Nondiscrimination covenants, the NCDOT will have the right to enter or re-enter the lands and facilities thereon, and the above described lands and facilities will there upon revert to and vest in and become the absolute property of the NCDOT and its assigns. *

(*Reverter clause and related language to be used only when it is determined that such a clause is necessary to make clear the purpose of Title VI.)

(c) Clauses for Construction/Use/Access to Real Property Acquired Under the Activity, Facility or Program (1050.2A, Appendix D)

The following clauses will be included in deeds, licenses, permits, or similar instruments/agreements entered into by the North Carolina Department of Transportation (NCDOT) pursuant to the provisions of Assurance 7(b):

- 1. The (grantee, licensee, permittee, etc., as appropriate) for himself/herself, his/her heirs, personal representatives, successors in interest, and assigns, as a part of the consideration hereof, does hereby covenant and agree (in the case of deeds and leases add, "as a covenant running with the land") that (1) no person on the ground of race, color, or national origin, will be excluded from participation in, denied the benefits of, or be otherwise subjected to discrimination in the use of said facilities, (2) that in the construction of any improvements on, over, or under such land, and the furnishing of services thereon, no person on the ground of race, color, or national origin, will be excluded from participation in, denied the benefits of, or otherwise be subjected to discrimination, (3) that the (grantee, licensee, lessee, permittee, etc.) will use the premises in compliance with all other requirements imposed by or pursuant to the Acts and Regulations, as amended, set forth in this Assurance.
- 2. With respect to (licenses, leases, permits, etc.), in the event of breach of any of the above Non-discrimination covenants, the NCDOT will have the right to terminate the (license, permit, etc., as appropriate) and to enter or re-enter and repossess said land and the facilities thereon, and hold the same as if said (license, permit, etc., as appropriate) had never been made or issued. *
- 3. With respect to deeds, in the event of breach of any of the above Nondiscrimination covenants, the NCDOT will there upon revert to and vest in and become the absolute property of the NCDOT and its assigns. *

(*Reverter clause and related language to be used only when it is determined that such a clause is necessary to make clear the purpose of Title VI.)

STANDARD SPECIAL PROVISION**ON-THE-JOB TRAINING**

(10-16-07) (Rev. 4-21-15)

Z-10

Description

The North Carolina Department of Transportation will administer a custom version of the Federal On-the-Job Training (OJT) Program, commonly referred to as the Alternate OJT Program. All contractors (existing and newcomers) will be automatically placed in the Alternate Program. Standard OJT requirements typically associated with individual projects will no longer be applied at the project level. Instead, these requirements will be applicable on an annual basis for each contractor administered by the OJT Program Manager.

On the Job Training shall meet the requirements of 23 CFR 230.107 (b), 23 USC – Section 140, this provision and the On-the-Job Training Program Manual.

The Alternate OJT Program will allow a contractor to train employees on Federal, State and privately funded projects located in North Carolina. However, priority shall be given to training employees on NCDOT Federal-Aid funded projects.

Minorities and Women

Developing, training and upgrading of minorities and women toward journeyman level status is a primary objective of this special training provision. Accordingly, the Contractor shall make every effort to enroll minority and women as trainees to the extent that such persons are available within a reasonable area of recruitment. This training commitment is not intended, and shall not be used, to discriminate against any applicant for training, whether a member of a minority group or not.

Assigning Training Goals

The Department, through the OJT Program Manager, will assign training goals for a calendar year based on the contractors' past three years' activity and the contractors' anticipated upcoming year's activity with the Department. At the beginning of each year, all contractors eligible will be contacted by the Department to determine the number of trainees that will be assigned for the upcoming calendar year. At that time the Contractor shall enter into an agreement with the Department to provide a self-imposed on-the-job training program for the calendar year. This agreement will include a specific number of annual training goals agreed to by both parties. The number of training assignments may range from 1 to 15 per contractor per calendar year. The Contractor shall sign an agreement to fulfill their annual goal for the year.\

Training Classifications

The Contractor shall provide on-the-job training aimed at developing full journeyman level workers in the construction craft/operator positions. Preference shall be given to providing training in the following skilled work classifications:

Equipment Operators	Office Engineers
Truck Drivers	Estimators
Carpenters	Iron / Reinforcing Steel Workers
Concrete Finishers	Mechanics
Pipe Layers	Welders

The Department has established common training classifications and their respective training requirements that may be used by the contractors. However, the classifications established are not all-inclusive. Where the training is oriented toward construction applications, training will be allowed in lower-level management positions such as office engineers and estimators. Contractors shall submit new classifications for specific job functions that their employees are performing. The Department will review and recommend for acceptance to FHWA the new classifications proposed by contractors, if applicable. New classifications shall meet the following requirements:

Proposed training classifications are reasonable and realistic based on the job skill classification needs, and

The number of training hours specified in the training classification is consistent with common practices and provides enough time for the trainee to obtain journeyman level status.

The Contractor may allow trainees to be trained by a subcontractor provided that the Contractor retains primary responsibility for meeting the training and this provision is made applicable to the subcontract. However, only the Contractor will receive credit towards the annual goal for the trainee.

Where feasible, 25 percent of apprentices or trainees in each occupation shall be in their first year of apprenticeship or training. The number of trainees shall be distributed among the work classifications on the basis of the contractor's needs and the availability of journeymen in the various classifications within a reasonable area of recruitment.

No employee shall be employed as a trainee in any classification in which they have successfully completed a training course leading to journeyman level status or in which they have been employed as a journeyman.

Records and Reports

The Contractor shall maintain enrollment, monthly and completion reports documenting company compliance under these contract documents. These documents and any other information as requested shall be submitted to the OJT Program Manager.

Upon completion and graduation of the program, the Contractor shall provide each trainee with a certification Certificate showing the type and length of training satisfactorily completed.

Trainee Interviews

All trainees enrolled in the program will receive an initial and Trainee/Post graduate interview conducted by the OJT program staff.

Trainee Wages

Contractors shall compensate trainees on a graduating pay scale based upon a percentage of the prevailing minimum journeyman wages (Davis-Bacon Act). Minimum pay shall be as follows:

60 percent	of the journeyman wage for the first half of the training period
75 percent	of the journeyman wage for the third quarter of the training period
90 percent	of the journeyman wage for the last quarter of the training period

In no instance shall a trainee be paid less than the local minimum wage. The Contractor shall adhere to the minimum hourly wage rate that will satisfy both the NC Department of Labor (NCDOL) and the Department.

Achieving or Failing to Meet Training Goals

The Contractor will be credited for each trainee employed by him on the contract work who is currently enrolled or becomes enrolled in an approved program and who receives training for at least 50 percent of the specific program requirement. Trainees will be allowed to be transferred between projects if required by the Contractor's scheduled workload to meet training goals.

If a contractor fails to attain their training assignments for the calendar year, they may be taken off the NCDOT's Bidders List.

Measurement and Payment

No compensation will be made for providing required training in accordance with these contract documents.

LISTING OF MBE/WBE SUBCONTRACTORS

			Sheet of		
Firm Name and Address	Circle One	Item No.	Item Description	* Agreed upon Unit Price	** Dollar Volume of Item
Name Address	MBE WBE				
Name Address	MBE WBE				
Name Address	MBE WBE				
Name Address	MBE WBE				
Name Address	MBE WBE				
Name Address	MBE WBE				

* The Dollar Volume shown in this column shall be the Actual Price Agreed Upon by the Prime Contractor and the MBE/WBE subcontractor, and these prices will be used to determine the percentage of the MBE/WBE participation in the contract.

** Dollar Volume of MBE/WBE Subcontractor Percentage of Total Contract Bid Price:

If firm is a Material Supplier Only, show Dollar Volume as 60% of Agreed Upon Amount from Letter of Intent.

If firm is a Manufacturer, show Dollar Volume as 100% of Agreed Upon Amount from Letter of Intent.

LISTING OF MBE/WBE SUBCONTRACTORS

Sheet of

Firm Name and Address	Circle One	Item No.	Item Description	* Agreed upon Unit Price	** Dollar Volume of Item
Name Address	MBE WBE				
Name Address	MBE WBE				
Name Address	MBE WBE				
Name Address	MBE WBE				
Name Address	MBE WBE				

**** Dollar Volume of MBE Subcontractor \$ _____**

MBE Percentage of Total Contract Bid Price _____%

**** Dollar Volume of WBE Subcontractor \$ _____**

WBE Percentage of Total Contract Bid Price _____%

***The Dollar Volume shown in this column shall be the Actual Price Agreed Upon by the Prime Contractor and the MBE/WBE subcontractor, and these prices will be used to determine the percentage of the MBE/WBE participation in the contract.**

**** Dollar Volume of MBE/WBE Subcontractor Percentage of Total Contract Bid Price.**

If firm is a Material Supplier Only, show Dollar Volume as 60% of Agreed Upon Amount from Letter of Intent.

If firm is a Manufacturer, show Dollar Volume as 100% of Agreed Upon Amount from Letter of Intent.

STATE OF NORTH CAROLINA
DEPARTMENT OF TRANSPORTATION
RALEIGH, NC

CONTRACT PAYMENT BOND

Date of Payment Bond Execution _____

Name of Principal Contractor _____

Name of Surety: _____

Name of Contracting Body: _____

Amount of Bond: _____

Contract ID No.: DC00404

County Name: Brunswick County

KNOW ALL MEN BY THESE PRESENTS, That we, the PRINCIPAL CONTRACTOR (hereafter, PRINCIPAL) and SURETY above named, are held and firmly bound unto the above named Contracting Body, hereinafter called the Contracting Body, in the penal sum of the amount stated above for the payment of which sum well and truly to be made, we bind ourselves, our heirs, executors, administrators, and successors, jointly and severally, firmly by these presents.

THE CONDITION OF THIS OBLIGATION IS SUCH, that whereas the principal entered into a certain contract with the Contracting Body, numbered as shown above and hereto attached:

NOW THEREFORE, if the principal shall promptly make payment to all persons supplying labor and material in the prosecution of the work provided for in said contract, and any and all duly authorized modifications of said contract that may hereafter be made, notice of which modifications to the surety being hereby waived, then this obligation to be void; otherwise to remain in full force and virtue.

IN WITNESS WHEREOF, the above-bound parties have executed this instrument under their several seals on the date indicated above, the name and corporate seal of each corporate party being hereto affixed and these presents duly signed by its undersigned representative, pursuant to authority of its governing body.

CONTRACT PAYMENT BOND

Affix Seal of Surety Company

Print or type Surety Company Name

By _____
Print, stamp or type name of Attorney-in-Fact

Signature of Attorney-in-Fact

Signature of Witness

Print or type Signer's name

Address of Attorney-in-Fact

CONTRACT PAYMENT BOND

CORPORATION

SIGNATURE OF CONTRACTOR (Principal)

Full name of Corporation

Address as prequalified

By

Signature of President, Vice President, Assistant Vice President
Select appropriate title

Print or type Signer's name

Affix Corporate Seal

Attest

Signature of Secretary, Assistant Secretary
Select appropriate title

Print or type Signer's name

CONTRACT PAYMENT BOND
LIMITED LIABILITY COMPANY

SIGNATURE OF CONTRACTOR (Principal)

Name of Contractor

Full name of Firm

Address as prequalified

By:

Signature of Member, Manager, Authorized Agent
Select appropriate title

Print or type Signer's name

CONTRACT PAYMENT BOND

INDIVIDUAL DOING BUSINESS UNDER A FIRM NAME

SIGNATURE OF CONTRACTOR (Principal)

Name of Contractor

Individual Name

Trading and doing business as

Full name of Firm

Address as prequalified

Signature of Contractor

Individually

Print or type Signer's name

Signature of Witness

Print or type Signer's name

CONTRACT PAYMENT BOND

INDIVIDUAL DOING BUSINESS IN HIS OWN NAME

SIGNATURE OF CONTRACTOR (Principal)

Name of Contractor

 Print or type Individual name

 Address as prequalified

Signature of Contractor

 Individually

 Print or type Signer's name

 Signature of Witness

 Print or type Signer's name

CONTRACT PAYMENT BOND

PARTNERSHIP

SIGNATURE OF CONTRACTOR (Principal)

Full name of Partnership

Address as prequalified

By

Signature of Partner

Print or type Signer's name

Signature of Witness

Print or type Signer's name

CONTRACT PAYMENT BOND

Attach certified copy of Power of Attorney to this sheet

**STATE OF NORTH CAROLINA
DEPARTMENT OF TRANSPORTATION
RALEIGH, NC**

CONTRACT PERFORMANCE BOND

Date of Performance Bond Execution: _____

Name of Principal Contractor: _____

Name of Surety: _____

Name of Contracting Body: _____

Amount of Bond: _____

Contract ID No.: DC00404

County Name: Brunswick County

KNOW ALL MEN BY THESE PRESENTS, That we, the PRINCIPAL CONTRACTOR (hereafter, PRINCIPAL) and SURETY above named, are held and firmly bound unto the above named Contracting Body, hereinafter called the Contracting Body, in the penal sum of the amount stated above for the payment of which sum well and truly to be made, we bind ourselves, our heirs, executors, administrators, and successors, jointly and severally, firmly by these presents.

THE CONDITION OF THIS OBLIGATION IS SUCH, that whereas the principal entered into a certain contract with the Contracting Body, numbered as shown above and hereto attached:

NOW THEREFORE, if the principal shall well and truly perform and fulfill all the undertakings, covenants, terms, conditions, and agreements of said contract during the original term of said contract and any extensions thereof that may be granted by the Contracting Body, with or without notice to the Surety, and during the life of any guaranty required under the contract, and shall also well and truly perform and fulfill all the undertakings, covenants, terms, conditions, and agreements of any and all duly authorized modifications of said contract that may hereafter be made, notice of which modifications to the surety being hereby waived, then this obligation to be void; otherwise to remain in full force and virtue.

IN WITNESS WHEREOF, the above-bound parties have executed this instrument under their several seals on the date indicated above, the name and corporate seal of each corporate party being hereto affixed and these presents duly signed by its undersigned representative, pursuant to authority of its governing body.

CONTRACT PERFORMANCE BOND

Affix Seal of Surety Company

Print or type Surety Company Name

By _____
Print, stamp or type name of Attorney-in-Fact

Signature of Attorney-in-Fact

Signature of Witness

Print or type Signer's name

Address of Attorney-in-Fact

CONTRACT PERFORMANCE BOND

CORPORATION

SIGNATURE OF CONTRACTOR (Principal)

Full name of Corporation

Address as prequalified

By

Signature of President, Vice President, Assistant Vice President
Select appropriate title

Print or type Signer's name

Affix Corporate Seal

Attest

Signature of Secretary, Assistant Secretary
Select appropriate title

Print or type Signer's name

CONTRACT PERFORMANCE BOND

LIMITED LIABILITY COMPANY

SIGNATURE OF CONTRACTOR (Principal)

Name of Contractor

Full name of Firm

Address as prequalified

By:

Signature of Member, Manager, Authorized Agent
Select appropriate title

Print or type Signer's name

CONTRACT PERFORMANCE BOND

INDIVIDUAL DOING BUSINESS UNDER A FIRM NAME

SIGNATURE OF CONTRACTOR (Principal)

Name of Contractor

Individual Name

Trading and doing business as

Full name of Firm

Address as prequalified

Signature of Contractor

Individually

Print or type Signer's name

Signature of Witness

Print or type Signer's name

CONTRACT PERFORMANCE BOND

INDIVIDUAL DOING BUSINESS IN HIS OWN NAME

SIGNATURE OF CONTRACTOR (Principal)

Name of Contractor

 Print or type Individual name

 Address as prequalified

Signature of Contractor

 Individually

 Print or type Signer's name

 Signature of Witness

 Print or type Signer's name

CONTRACT PERFORMANCE BOND

PARTNERSHIP

SIGNATURE OF CONTRACTOR (Principal)

Full name of Partnership

Address as prequalified

By

Signature of Partner

Print or type Signer's name

Signature of Witness

Print or type Signer's name

**CONTRACT PERFORMANCE BOND
JOINT VENTURE (2) OR (3)
SIGNATURE OF CONTRACTORS (Principal)**

Instructions to Bidders: 2 Joint Ventures, Fill in lines (1), (2) and (3) and execute. 3 Joint Venturers Fill in lines (1), (2), (3), (4) and execute. On Line (1), print or type the name of Joint Venture. On line (2), print or type the name of one of the joint venturers and execute below in the appropriate manner required by Article 102-8 of the *NCDOT Standard Specifications*. On Line (3), print or type the name of second joint venturer and execute below in the appropriate manner required by said article of the Specifications. On Line (4), print or type the name of the third joint venturer, if applicable and execute below in the appropriate manner required by said article of the Specifications. This form of execution must be strictly followed.

Signature of Witness or Attest

By

Signature of Contractor

Print or type Signer's name

Print or type Signer's name

and

Signature of Witness or Attest

By

Signature of Contractor

Print or type Signer's name

Print or type Signer's name

and

Signature of Witness or Attest

By

Signature of Contractor

Print or type Signer's name

Print or type Signer's name

CONTRACT PERFORMANCE BOND

Attach certified copy of Power of Attorney to this sheet

STATE OF NORTH CAROLINA
DEPARTMENT OF TRANSPORTATION
RALEIGH, NC

BID BOND

Contract Number: DC00404 County: Brunswick County

KNOW ALL MEN BY THESE PRESENTS, That we, the PRINCIPAL CONTRACTOR (hereafter, PRINCIPAL) and SURETY above named, are held and firmly bound unto the Department of Transportation in the full and just sum of five (5) percent of the total amount bid by the Principal for the project stated above, for the payment of which sum well and truly to be made, we bind ourselves, our heirs, executors, administrators, and successors, jointly and severally, firmly by these presents.

NOW, THEREFORE, the condition of this obligation is: the Principal shall not withdraw its bid within sixty (60) days after the opening of the bids, or within such other time period as may be provided in the proposal, and if the Board of Transportation shall award a contract to the Principal, the Principal shall, within fourteen (14) calendar days after written notice of award is received by him, provide bonds with good and sufficient surety, as required for the faithful performance of the contract and for the protection of all persons supplying labor, material, and equipment for the prosecution of the work. In the event the Principal requests permission to withdraw his bid due to mistake in accordance with the provisions of Article 103-3 of the *Standard Specifications for Roads and Structures*, the conditions and obligations of this Bid Bond shall remain in full force and effect until the Department of Transportation makes a final determination to either allow the bid to be withdrawn or to proceed with award of the contract. In the event a determination is made to award the contract, the Principal shall have fourteen (14) calendar days to comply with the requirements set forth above. In the event the Principal withdraws its bid after bids are opened except as provided in Article 103-3, or after award of the contract has been made fails to execute such additional documents as may be required and to provide the required bonds within the time period specified above, then the amount of the bid bond shall be immediately paid to the Department of Transportation as liquidated damages.

IN TESTIMONY WHEREOF, the Principal and Surety have caused these presents to be duly signed and sealed.

This the _____ day of _____, 20 _____

Surety

By _____
General Agent or Attorney-in-Fact Signature

Seal of Surety

Print or type Signer's Name

BID BOND
CORPORATION

SIGNATURE OF CONTRACTOR (Principal)

Full name of Corporation

Address as prequalified

By _____
Signature of **President, Vice President, Assistant Vice President**
Select appropriate title

Print or type Signer's name

Affix Corporate Seal

Attest _____
Signature of **Secretary, Assistant Secretary**
Select appropriate title

Print or type Signer's name

BID BOND

LIMITED LIABILITY COMPANY

SIGNATURE OF CONTRACTOR (Principal)

Name of Contractor

Full name of Firm

Address as prequalified

**Signature of Member/
Manager/Authorized Agent**

Individually

Print or type Signer's name

BID BOND

INDIVIDUAL DOING BUSINESS UNDER A FIRM NAME

SIGNATURE OF CONTRACTOR (Principal)

Name of Contractor

_____ Individual Name

Trading and doing business as

_____ Full name of Firm

_____ Address as prequalified

Signature of Contractor

_____ Individually

_____ Print or type Signer's name

_____ Signature of Witness

_____ Print or type Signer's name

BID BOND

INDIVIDUAL DOING BUSINESS IN HIS OWN NAME

SIGNATURE OF CONTRACTOR (Principal)

Name of Contractor

Print or type Individual Name

Address as prequalified

Signature of Contractor

Individually

Print or type Signer's name

Signature of Witness

Print or type Signer's name

BID BOND

PARTNERSHIP

SIGNATURE OF CONTRACTOR (Principal)

Full name of Partnership

Address as prequalified

By _____
Signature of Partner

Print or type Signer's name

Signature of Witness

Print or type Signer's name

BID BOND
JOINT VENTURE (2 or 3)
SIGNATURE OF CONTRACTORS (Principal)

Instructions to Bidders: **2 Joint Ventures**, Fill in lines (1), (2) and (3) and execute. **3 Joint Venturers** Fill in lines (1), (2), (3), (4) and execute. Line (1), print or type the name of Joint Venture. On line (2), print or type the name of one of the joint venturers and execute below in the appropriate manner required by Article 102-8 of the *Specifications*. On Line (3), print or type the name of second joint venturer and execute below in the appropriate manner required by said article of the *Specifications*. On Line (4), print or type the name of the third joint venturer, if applicable and execute below in the appropriate manner required by said article of the *Specifications*. This form of execution must be strictly followed.

Signature of Witness or Attest	By	Signature of Contractor
Print or type Signer's name		Print or type Signer's name

and

Signature of Witness or Attest	By	Signature of Contractor
Print or type Signer's name		Print or type Signer's name

and

Signature of Witness or Attest	By	Signature of Contractor
Print or type Signer's name		Print or type Signer's name

ADDENDUM(S)

ADDENDUM #1

I, _____
(SIGNATURE)

representing _____

Acknowledge receipt of Addendum #1.

ADDENDUM #2

I, _____
(SIGNATURE)

representing _____

Acknowledge receipt of Addendum #2.

ADDENDUM #3

I, _____
(SIGNATURE)

representing _____

Acknowledge receipt of Addendum #3.

AWARD LIMITS ON MULTIPLE PROJECTS

It is the desire of the Proposer to be awarded contracts, the value of which will not exceed a total of \$ _____, for those projects indicated below on which bids are being opened on the same date as shown in the Proposal Form. Individual projects shall be indicated by placing the project number and county in the appropriate place below. Projects not selected will not be subject to an award limit.

(Project Number)

(County)

(Project Number)

(County)

(Project Number)

(County)

(Project Number)

(County)

*If a Proposer desires to limit the total amount of work awarded to him in this letting, he shall state such limit in the space provided above in the second line of this form.

It is agreed that in the event that I am (we are) the successful bidder on indicated projects, the total value of which is more than the above stipulated award limits, the Board of Transportation will award me (us) projects from among those indicated which have a total value not exceeding the award limit and which will result in the best advantage to the Department of Transportation.

**Signature of Authorized Person

**Only those persons authorized to sign bids under the provisions of Article 102-8, Item 7, shall be authorized to sign this form.

EXECUTION OF BID

NON-COLLUSION, DEBARMENT AND GIFT BAN CERTIFICATION

CORPORATION

The prequalified bidder, declares (or certifies, verifies, or states) under penalty of perjury under the laws of the United States that neither he, nor any official, agent or employee has entered into any agreement, participated in any collusion, or otherwise taken any action which is in restraint of free competitive bidding in connection with any bid or contract, that the prequalified bidder has not been convicted of violating *N.C.G.S. §133-24* within the last three years, and that the prequalified bidder intends to do the work with his own bona fide employees or subcontractors and will not bid for the benefit of another contractor.

By submitting this non-collusion, debarment and gift ban certification, the Contractor is attesting his status under penalty of perjury under the laws of the United States in accordance with the Debarment Certification attached, provided that the Debarment Certification also includes any required statements concerning exceptions that are applicable.

N.C.G.S. §133-32 and Executive Order 24 prohibit the offer to, or acceptance by, any State Employee of any gift from anyone with a contract with the State, or from any person seeking to do business with the State. By execution of any response in this procurement, you attest, for your entire organization and its employees or agents, that you are not aware that any such gift has been offered, accepted, or promised by any employees of your organization.

SIGNATURE OF PREQUALIFIED BIDDER

Full name of Corporation

Address as Prequalified

Attest _____ By _____
Secretary/Assistant Secretary President/Vice President/Assistant Vice President
(Select appropriate title) (Select appropriate title)

Print or type Signer's name

Print or type Signer's name

CORPORATE SEAL

NON-COLLUSION, DEBARMENT AND GIFT BAN CERTIFICATION

PARTNERSHIP

The prequalified bidder, declares (or certifies, verifies, or states) under penalty of perjury under the laws of the United States that neither he, nor any official, agent or employee has entered into any agreement, participated in any collusion, or otherwise taken any action which is in restraint of free competitive bidding in connection with any bid or contract, that the prequalified bidder has not been convicted of violating *N.C.G.S. § 133-24* within the last three years, and that the prequalified bidder intends to do the work with its own bona fide employees or subcontractors and will not bid for the benefit of another contractor.

By submitting this non-collusion, debarment and gift ban certification, the Contractor is attesting his status under penalty of perjury under the laws of the United States in accordance with the Debarment Certification attached, provided that the Debarment Certification also includes any required statements concerning exceptions that are applicable.

N.C.G.S. § 133-32 and Executive Order 24 prohibit the offer to, or acceptance by, any State Employee of any gift from anyone with a contract with the State, or from any person seeking to do business with the State. By execution of any response in this procurement, you attest, for your entire organization and its employees or agents, that you are not aware that any such gift has been offered, accepted, or promised by any employees of your organization.

SIGNATURE OF PREQUALIFIED BIDDER

Full Name of
Partnership

Address as
Prequalified

Signature of Witness

Signature of Partner

Print or Type Signer's Name

Print or Type Signer's Name

NON-COLLUSION, DEBARMENT AND GIFT BAN CERTIFICATION

LIMITED LIABILITY COMPANY

The prequalified bidder, declares (or certifies, verifies, or states) under penalty of perjury under the laws of the United States that neither he, nor any official, agent or employee has entered into any agreement, participated in any collusion, or otherwise taken any action which is in restraint of free competitive bidding in connection with any bid or contract, that the prequalified bidder has not been convicted of violating *N.C.G.S. § 133-24* within the last three years, and that the prequalified bidder intends to do the work with its own bona fide employees or subcontractors and will not bid for the benefit of another contractor.

By submitting this non-collusion, debarment and gift ban certification, the Contractor is attesting his status under penalty of perjury under the laws of the United States in accordance with the Debarment Certification attached, provided that the Debarment Certification also includes any required statements concerning exceptions that are applicable.

N.C.G.S. § 133-32 and Executive Order 24 prohibit the offer to, or acceptance by, any State Employee of any gift from anyone with a contract with the State, or from any person seeking to do business with the State. By execution of any response in this procurement, you attest, for your entire organization and its employees or agents, that you are not aware that any such gift has been offered, accepted, or promised by any employees of your organization.

SIGNATURE OF PREQUALIFIED BIDDER

Full Name of Firm

Address as Prequalified

Signature of Witness

Signature of Member/Manager/Authorized Agent
(Select appropriate Title)

Print or Type Signer's Name

Print or Type Signer's Name

NON-COLLUSION, DEBARMENT AND GIFT BAN CERTIFICATION

JOINT VENTURE (2) or (3)

The prequalified bidder, declares (or certifies, verifies, or states) under penalty of perjury under the laws of the United States that neither he, nor any official, agent or employee has entered into any agreement, participated in any collusion, or otherwise taken any action which is in restraint of free competitive bidding in connection with any bid or contract, that the prequalified bidder has not been convicted of violating *N.C.G.S. § 133-24* within the last three years, and that the prequalified bidder intends to do the work with its own bona fide employees or subcontractors and will not bid for the benefit of another contractor.

By submitting this non-collusion, debarment and gift ban certification, the Contractor is attesting his status under penalty of perjury under the laws of the United States in accordance with the Debarment Certification attached, provided that the Debarment Certification also includes any required statements concerning exceptions that are applicable.

N.C.G.S. § 133-32 and Executive Order 24 prohibit the offer to, or acceptance by, any State Employee of any gift from anyone with a contract with the State, or from any person seeking to do business with the State. By execution of any response in this procurement, you attest, for your entire organization and its employees or agents, that you are not aware that any such gift has been offered, accepted, or promised by any employees of your organization.

SIGNATURE OF PREQUALIFIED BIDDER

Instructions: **2 Joint Venturers** Fill in lines (1), (2) and (3) and execute. **3 Joint Venturers** Fill in lines (1), (2), (3) and (4) and execute. On Line (1), fill in the name of the Joint Venture Company. On Line (2), fill in the name of one of the joint venturers and execute below in the appropriate manner. On Line (3), print or type the name of the other joint venturer and execute below in the appropriate manner. On Line (4), fill in the name of the third joint venturer, if applicable and execute below in the appropriate manner.

(1) _____
Name of Joint Venture

(2) _____
Name of Contractor

Address as Prequalified

Signature of Witness or Attest _____ BY _____ Signature of Contractor
Print or Type Signer's Name _____ Print or Type Signer's Name

If Corporation, affix Corporate Seal AND

(3) _____
Name of Contractor

Address as Prequalified

Signature of Witness or Attest _____ BY _____ Signature of Contractor
Print or Type Signer's Name _____ Print or Type Signer's Name

If Corporation, affix Corporate Seal AND

(4) _____
Name of Contractor

Address as Prequalified

Signature of Witness or Attest _____ BY _____ Signature of Contractor
Print or Type Signer's Name _____ Print or Type Signer's Name

If Corporation, affix Corporate Seal

**NON-COLLUSION, DEBARMENT AND GIFT BAN CERTIFICATION
INDIVIDUAL DOING BUSINESS UNDER A FIRM NAME**

The prequalified bidder, declares (or certifies, verifies, or states) under penalty of perjury under the laws of the United States that neither he, nor any official, agent or employee has entered into any agreement, participated in any collusion, or otherwise taken any action which is in restraint of free competitive bidding in connection with any bid or contract, that the prequalified bidder has not been convicted of violating *N.C.G.S. § 133-24* within the last three years, and that the prequalified bidder intends to do the work with its own bona fide employees or subcontractors and will not bid for the benefit of another contractor.

By submitting this non-collusion, debarment and gift ban certification, the Contractor is attesting his status under penalty of perjury under the laws of the United States in accordance with the Debarment Certification attached, provided that the Debarment Certification also includes any required statements concerning exceptions that are applicable.

N.C.G.S. § 133-32 and Executive Order 24 prohibit the offer to, or acceptance by, any State Employee of any gift from anyone with a contract with the State, or from any person seeking to do business with the State. By execution of any response in this procurement, you attest, for your entire organization and its employees or agents, that you are not aware that any such gift has been offered, accepted, or promised by any employees of your organization.

SIGNATURE OF PREQUALIFIED BIDDER

Name of Prequalified Bidder

Individual Name

Trading and Doing Business As

Full name of Firm

Address as Prequalified

Signature of Witness

Signature of Prequalified Bidder, Individual

Print or Type Signer's Name

Print or Type Signer's Name

NON-COLLUSION, DEBARMENT AND GIFT BAN CERTIFICATION

INDIVIDUAL DOING BUSINESS IN HIS OWN NAME

The prequalified bidder, declares (or certifies, verifies, or states) under penalty of perjury under the laws of the United States that neither he, nor any official, agent or employee has entered into any agreement, participated in any collusion, or otherwise taken any action which is in restraint of free competitive bidding in connection with any bid or contract, that the prequalified bidder has not been convicted of violating *N.C.G.S. § 133-24* within the last three years, and that the prequalified bidder intends to do the work with its own bona fide employees or subcontractors and will not bid for the benefit of another contractor.

By submitting this non-collusion, debarment and gift ban certification, the Contractor is attesting his status under penalty of perjury under the laws of the United States in accordance with the Debarment Certification attached, provided that the Debarment Certification also includes any required statements concerning exceptions that are applicable.

N.C.G.S. § 133-32 and Executive Order 24 prohibit the offer to, or acceptance by, any State Employee of any gift from anyone with a contract with the State, or from any person seeking to do business with the State. By execution of any response in this procurement, you attest, for your entire organization and its employees or agents, that you are not aware that any such gift has been offered, accepted, or promised by any employees of your organization.

SIGNATURE OF PREQUALIFIED BIDDER

Name of Prequalified Bidder _____

Print or Type Name

Address as Prequalified

Signature of Prequalified Bidder, Individually

Print or type Signer's Name

Signature of Witness

Print or type Signer's name

DEBARMENT CERTIFICATION

Conditions for certification:

1. The prequalified bidder shall provide immediate written notice to the Department if at any time the bidder learns that his certification was erroneous when he submitted his debarment certification or explanation filed with the Department, or has become erroneous because of changed circumstances.
2. The terms *covered transaction*, *debarred*, *suspended*, *ineligible*, *lower tier covered transaction*, *participant*, *person*, *primary covered transaction*, *principal*, *proposal*, and *voluntarily excluded*, as used in this provision, have the meanings set out in the Definitions and Coverage sections of the rules implementing Executive Order 12549. A copy of the Federal Rules requiring this certification and detailing the definitions and coverages may be obtained from the Contract Officer of the Department.
3. The prequalified bidder agrees by submitting this form, that he will not knowingly enter into any lower tier covered transaction with a person who is debarred, suspended, declared ineligible, or voluntarily excluded from participation in NCDOT contracts, unless authorized by the Department.
4. For Federal Aid projects, the prequalified bidder further agrees that by submitting this form he will include the Federal-Aid Provision titled *Required Contract Provisions Federal-Aid Construction Contract (Form FHWA PR 1273)* provided by the Department, without subsequent modification, in all lower tier covered transactions.
5. The prequalified bidder may rely upon a certification of a participant in a lower tier covered transaction that he is not debarred, suspended, ineligible, or voluntarily excluded from the covered transaction, unless he knows that the certification is erroneous. The bidder may decide the method and frequency by which he will determine the eligibility of his subcontractors.
6. Nothing contained in the foregoing shall be construed to require establishment of a system of records in order to render in good faith the certification required by this provision. The knowledge and information of a participant is not required to exceed that which is normally possessed by a prudent person in the ordinary course of business dealings.
7. Except as authorized in paragraph 6 herein, the Department may terminate any contract if the bidder knowingly enters into a lower tier covered transaction with a person who is suspended, debarred, ineligible, or voluntarily excluded from participation in this transaction, in addition to other remedies available by the Federal Government.

DEBARMENT CERTIFICATION

The prequalified bidder certifies to the best of his knowledge and belief, that he and his principals:

- a. Are not presently debarred, suspended, proposed for debarment, declared ineligible, or voluntarily excluded from covered transactions by any Federal department or agency;
- b. Have not within a three-year period preceding this proposal been convicted of or had a civil judgment rendered against them for commission of fraud or a criminal offense in connection with obtaining, attempting to obtain, or performing a public (Federal, State or local) transaction or contract under a public transaction; violation of Federal or State antitrust statutes or commission of embezzlement, theft, forgery, bribery, falsification or destruction of records; making false statements; or receiving stolen property;
- c. Are not presently indicted for or otherwise criminally or civilly charged by a governmental entity (Federal, State or local) with commission of any of the offenses enumerated in paragraph b. of this certification; and
- d. Have not within a three-year period preceding this proposal had one or more public transactions (Federal, State or local) terminated for cause or default.
- e. Will submit a revised Debarment Certification immediately if his status changes and will show in his bid proposal an explanation for the change in status.

If the prequalified bidder cannot certify that he is not debarred, he shall provide an explanation with this submittal. An explanation will not necessarily result in denial of participation in a contract.

Failure to submit a non-collusion and debarment certification will result in the prequalified bidder's bid being considered non-responsive.

Check here if an explanation is attached to this certification.

STATE OF NORTH CAROLINA DEPARTMENT OF TRANSPORTATION




DIVISION THREE

County: BRUNSWICK
 WBS Element: 15RE.13.3
 State ID#: 21-24079-01A
 Description: BRUNSWICK COUNTY REST AREA
 & VISITOR CENTER RENOVATION
 US-17, SHALOTTE, NC

Architect

W. S. Architects, PA
 Ginger Summer, Architect
 3305-109 Durham Dr.
 Raleigh, NC 27603
 (919) 779-9797
 Corp. Cert. 549



DocuSigned by:

Ginger Summer

3/31/2022

E9D28345662C422...

Plumbing, Mechanical & Electrical Engineer


Burke Design Group, PA
 Ben Burke, PE
 3305-109 Durham Dr.
 Raleigh, NC 27603
 (919) 771-1916
 Corp. License C-2652

Benjamin Burke, P.E.

Digitally signed by Benjamin
 Burke, P.E.
 DN: c=US, o=Burke Design Group,
 PA, cn=Benjamin Burke, P.E.
 Date: 2022.03.31 15:04:14 -04'00'

Structural Engineer

Lysaght & Assoc.
 Jim Struffolino, PE
 120 Saint Mary's Street
 Raleigh, NC 27605
 (919) 833-0495
 Corp. License C-0621



J-E Struffolino

James E. Struffolino

Digitally signed by James E. Struffolino
 DN: E=jes@lysaghtassociates.com,
 CN=James E. Struffolino, O=Lysaght &
 Associates, PA, L=Raleigh, S=North
 Carolina, C=US
 Location: Raleigh NC
 Reason: I am approving this document
 Contact Info: jes@lysaghtassociates.com
 Date: 2022.04.01 08:00:51-04'00'

TABLE OF CONTENTS

<u>SECTION</u>	<u>TITLE</u>	<u>PAGES</u>
	<u><i>DIVISION 1 - GENERAL REQUIREMENTS</i></u>	
01026	Payment and Completion Procedures	-4
01100	Compensation for General Construction	-4
01151	Construction and Demolition Materials Recycling Requirements	-4
01200	Progress Documentation and Procedures	-2
01300	Submittals	-4
01600	Substitutions	-2
	<u><i>DIVISION 2 - SITE WORK</i></u>	
02072	Demolition for Remodeling	-3
	<u><i>DIVISION 3 - CONCRETE</i></u>	
03310	Cast in place Concrete	-5
	<u><i>DIVISION 4 - MASONRY</i></u>	
04210	Clay Masonry Units	-6
04220	CMU	-3
	<u><i>DIVISION 5 - METALS</i></u>	
05120	Structural steel	-3
	<u><i>DIVISION 6 - WOOD AND PLASTICS</i></u>	
06100	Rough Carpentry	-2
06200	Finish Carpentry	-3
06651	Solid Surface Fabrication	-5
061516	Wood Roof Decking	-1
061800	Glue-laminated Construction	-2
	<u><i>DIVISION 7 - THERMAL & MOISTURE PROTECTION</i></u>	
07130	Waterproofing Membrane	-3
07210	Building Insulation	-2
07250	Weather Barrier	-4
07260	Vapor Barrier	-2
07310	Asphalt Shingles	-6
07463	Vinyl Siding	-4
07625	Sheet Metal Gutters and Downspouts	-2
07900	Joint Sealers	-3
	<u><i>DIVISION 8 - DOORS AND WINDOWS</i></u>	
08110	Steel Frames	-2
08211	Flush Wood Doors	-4
08310	Access Doors	-2
08410	Metal framed storefronts	-4
08460	Automatic entrance doors	-6
08710	Door hardware	-4
08800	Glazing	-3

	<u>DIVISION 9 - FINISHES</u>	
09252	Cement backer board	-3
09260	Gypsum Board System	-2
09300	Tile	-14
09900	Painting	-5
	<u>DIVISION 10 - SPECIALTIES</u>	
10170	Plastic Toilet Compartments	-2
10425	Signs	-2
10700	Aluminum Sunshade	-2
10810	Toilet Accessories	-3
	<u>DIVISION 11 -14 Not Used</u>	
	<u>DIVISION 15 - PLUMBING AND MECHANICAL</u>	
15010	Basic Plumbing Requirements	
15140	Hangers and Supports	
15250	Plumbing Piping Insulation	
15410	Plumbing Piping	
15430	Plumbing Specialties	
15440	Plumbing Fixtures	
15500	Basic Mechanical Requirements	
15501	Hangers and supports	
15513	Refrigerant piping	
15870A	Power ventilators	
15891A	Metal Ductwork	
15910	Duct Accessories	
15932	Air Outlets and Vents	
	<u>DIVISION 16 - ELECTRICAL</u>	
16010	Basic Electrical Requirements	-7
16050	Basic Electrical Materials and Methods	-4
16100	Raceways, Boxes and Cabinets	-5
16120	Wires and Cables	-3
16140	Wiring Devices	-3
16190	Supporting Devices	-3
16195	Electrical Identification	-3

SECTION 01026 - PAYMENT AND COMPLETION PROCEDURES

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Schedule of values.
 - 2. Payment procedures.
 - 3. Completion procedures.
- B. Related Requirements Specified Elsewhere in the Project Manual: Overhead and profit distribution.

1.02 CONTRACT CONDITIONS

- A. See the conditions of the contract for additional requirements.
- B. Progress payments will be made on or about the 25th of each month.
- C. The Architect/Engineer will act upon the Contractor's application for payment within 5 days after receipt.
- D. The Owner will act upon the application for payment within 15 days after receipt.
- E. No payment will be made for materials or equipment stored off site unless specifically approved in advance, in writing by the owner. Submit copy of the owner's agreement to pay for such materials and equipment with the application for payment covering such materials and equipment.
- F. Payments may be withheld if the contractor fails to make dated submittals within the time periods specified.

1.03 DEFINITIONS

- A. Final Completion: The stage at which all incomplete and incorrect work has been completed or corrected in accordance with the contract documents.
- B. List of Incomplete Work: A comprehensive list of items to be completed or corrected, prepared by the Designer/Owner/Contractor for the purpose of obtaining certification of substantial completion. This list is also referred to as a "Pre-Final and Final Punch List."
- C. Schedule of Values: A detailed breakdown of the contract sum into individual cost items, which will serve as the basis for evaluation of applications for progress payments during construction.
- D. Substantial Completion: The time at which the work, or a portion of the work which the owner agrees to accept separately, is sufficiently complete in accordance with the contract documents so that the owner can occupy or use the work for its intended purpose.
- E. Time and Material Work: Work which will be paid for on the basis of the actual cost of the work, including materials, labor, equipment, and other costs as defined elsewhere, as documented by detailed records. This basis is also referred to using the terms "cost-plus," "cost of the work," "force account," and similar terms.

1.04 SUBMITTALS

- A. Schedule of Values: First application for payment will not be reviewed without schedule of values. (use AIA G702 or equal)
 - 1. Submit in size not larger than 8-1/2 by 11 inches.
 - 2. Submit at Pre-Construction Conference and digitally.
 - 3. Identify with:
 - a. Project name, Project number, Architect's name, Owner's name, Contractor's name and address, and Submittal date.

- B. Applications for Progress Payments: Submit sufficiently in advance of date established for the progress payment to allow for the processing indicated. This will be based on schedule of values.

PART 2 - PRODUCTS (NOT USED)

PART 3 – EXECUTION

3.01 SCHEDULE OF VALUES

- A. Prepare a schedule of values prior to the first application for payment.
- B. Schedule of Values: Break costs down into line items which will be comparable with line items in applications for payment.
 - 1. Coordinate line items in the schedule of values with portions of the contract documents which identify units or subdivisions of work; provide cross-referencing if necessary to clarify.
 - a. Specifically, correlate with the project manual table of contents.
 - 2. Divide major subcontracts into individual cost items.
 - 3. Where applications for payment are likely to include products purchased or fabricated but not yet installed, provide individual line items for material cost, installation cost, and other applicable phases of completion.
 - 4. Include the following information for each line item, using AIA G703, Continuation Sheet.
 - a. Item name.
 - b. Applicable specification section.
 - c. Dollar value, rounded off to the nearest whole dollar (with the total equal to the contract sum).
 - d. Proportion of the contract sum represented by this item, to the nearest one-hundredth percent (with the total adjusted to 100 percent).
 - 5. Provide the following supporting data for each line item:
 - a. Subcontractor's name.
 - b. Manufacturer or fabricator's name.
 - c. Supplier's name.
- C. Submit schedule of values not later than 10 days prior to submittal of first application for payment.
- D. The Architect/Engineer will notify the contractor if schedule is not satisfactory; revise and resubmit acceptable schedule.
- E. Submit a revised schedule of values when modifications change the contract sum or change individual line items.
 - 1. Make each modification a new line item.
 - 2. Show the following information for each line item:
 - a. All information required for original submittal.
 - b. Identification of modifications which have affected its value.
 - 3. Submit prior to next application for payment.

3.02 APPLICATIONS FOR PAYMENT

- A. Application for Payment will be through Architect.
- B. Provide the following information with every application for payment which involves work completed on a time and material basis:
 - 1. Detailed records of work done, including:
 - a. Dates and times work was performed, and by whom.
 - b. Time records and wage rates paid.
 - c. Invoices and receipts for products.
 - 2. Provide similar detailed records for subcontracts.

- C. Transmit application for payment with a transmittal form itemizing supporting documents attached.

3.03 FIRST PAYMENT PROCEDURE

- A. The first application for payment will not be reviewed until the following submittals have been received:
 - 1. Schedule of values.
 - 2. List of subcontractors, principal suppliers, and fabricators.
 - 3. Contractor's construction schedule. Monthly Progress Schedules are required, see Section 01200.
 - 4. Names of the contractor's principal staff assigned to the project.
 - 5. All submittals specified to occur prior to first application for payment or prior to first payment.

3.04 SUBSTANTIAL COMPLETION PROCEDURES

- A. The architect will perform a Pre-Final Inspection with the contractor two weeks before substantial completion inspection, upon request of the contractor. Plumbing, Mechanical, & Electrical subcontractors shall be present for all Final Inspections.
- B. The architect will perform a Final Inspection with the contractor for substantial completion and verification that the Pre-Final Inspection Punchlist is complete, upon request of the contractor.
 - 1. Only one certificate of substantial completion will be issued, for the entire project.
- C. Submit the following with application for payment following substantial completion:
 - 1. Certificate of Substantial Completion; use AIA original current editions of G704.
 - 4. Final Inspection list of incomplete work.
 - 5. Other data required by the contract documents.

3.05 FINAL COMPLETION PROCEDURES

- A. Request for Final Inspection and final application for payment may coincide.
- B. The architect/engineer will perform inspection for final completion, upon request of the contractor.
 - 1. Submit the following with request for inspection:
 - a. Previous inspection lists indicating completion of all items.
 - b. If any items cannot be completed, obtain prior approval of such delay.
- C. Do not submit request for Final Inspection until the following activities have been completed:
 - 1. Completion of all work, Pre-Final Inspection Punch List, except those items agreed upon by the owner.
 - 2. Final cleaning.
 - 3. All activities specified to occur between substantial completion and final completion.
- D. Do not submit request for final inspection until the following submittals have been completed:
 - 1. Startup reports; HVAC balance and test reports.
 - 2. Operation and maintenance data. Demonstration reports. Instruction reports.
 - 3. Water bacterial test report of new domestic water supply.
 - 4. Final Electrical Inspection and certification by the State Construction Office electrical inspector.
 - 5. Project record documents, record drawings or as-built drawings.
 - 6. All other outstanding specified submittals.
- E. Submit the following with the final application for payment:
 - 1. Certified copy of the previous list of items to be completed or corrected, stating that each has been completed or otherwise resolved for acceptance.
 - 2. Contractor's Affidavit of Payment of Debts and Claims; use AIA original current editions of G706
 - 3. Contractor's Affidavit of Release of Liens; use AIA original current editions of G706A.
 - 4. Consent of surety to final payment; use AIA original current editions of G707.

Brunswick County (US17) Rest Area Renovations

5. Final liquidated damages statement.
6. Certification that financial obligations to governing authorities and public utilities have been fulfilled.
7. Description of unsettled claims.
8. Other data required by the contract documents.

END OF SECTION 01026

SECTION 01100- COMPENSATION FOR GENERAL CONSTRUCTION

US-17
REST AREA AND VISITOR CENTER
MARCH 2022
BRUNSWICK COUNTY, NORTH CAROLINA

1.1 COMPENSATION

- A. The work of furnishing all materials and constructing/renovating the existing Rest Area Building, the Visitors Center, porched, patio and fenced area in accordance with the plans and specifications, completed and accepted, will be paid for at the contract lump sum price for the "General Construction of Rest Area Building". Such price and payment will be full compensation for all work included in construction documents for renovating the Rest Area Building, & Welcome Center, including but not limited to furnishing all transportation, materials, labor, tools, equipment, fees and incidentals necessary to complete the work. Payment will be made under:

"General Construction of Rest Area Building".....Lump Sum

Brunswick County (US17) Rest Area Renovations

US-17
REST AREA AND VISITOR CENTER
MARCH 2022
BRUNSWICK COUNTY, NORTH CAROLINA

DIVISION 15A- COMPENSATION FOR PLUMBING --

COMPENSATION

- A. The work of furnishing materials and constructing the Plumbing installation and demolition for the Rest Area Building and Visitor Center in accordance with the plans and specifications, completed and accepted, will be paid for at the contract lump sum price for the "Plumbing Installation of Rest Area Building". Such price and payment will be full compensation for all work of constructing the Plumbing installation for the Rest Area Building and Welcome Center as indicated within construction documents, including but not limited to furnishing all transportation, materials, labor, tools, equipment, fees and incidentals necessary to complete the work. Payment will be made under:

"Plumbing Installation of Rest Area Building".....Lump Sum

Brunswick County (US17) Rest Area Renovations

US-17

REST AREA AND VISITOR CENTER

MARCH 2022

BRUNSWICK COUNTY, NORTH CAROLINA

DIVISION 15B- COMPENSATION FOR MECHANICAL

COMPENSATION

- A. The work of furnishing materials and constructing the Mechanical System for the Rest Area Building in accordance with the plans and specifications, completed and accepted, will be paid for at the contract lump sum price for the "Mechanical Installation for Rest Area Building". Such price and payment will be full compensation for all work of the Mechanical Installation for Rest Area Building, including but not limited to furnishing all transportation, materials, labor, tools, equipment, fees and incidentals necessary to complete the work. Payment will be made under:

"Mechanical Installation for Rest Area Building".....Lump Sum

Brunswick County (US17) Rest Area Renovations

US-17
REST AREA AND VISITOR CENTER
MARCH 2022
BRUNSWICK COUNTY, NORTH CAROLINA

DIVISION 16- COMPENSATION FOR ELECTRICAL

COMPENSATION

- A. The work of furnishing materials and constructing the Electrical installation for the Rest Area Building and Welcome Center in accordance with the plans and specifications, completed and accepted, will be paid for at the contract lump sum price for the "Electrical Installation for Rest Area Building". Such price and payment will be full compensation for all work of constructing the Electrical installation for the Rest Area Building and Welcome Center, including but not limited to furnishing all transportation, materials, labor, tools, equipment, fees and incidentals necessary to complete the work. Payment will be made under:

"Electrical Installation for Rest Area Building".....Lump Sum

SECTION 01151 - CONSTRUCTION AND DEMOLITION MATERIALS RECYCLING REQUIREMENTS

PART 1 GENERAL

1.01 SUMMARY

- A. Section includes: Requirements and procedures for ensuring optimal diversion of demolition and construction waste materials generated by the Work from landfill disposal within the limits of the Construction Schedule and Contract Sum.
 - 1. State of North Carolina Executive Order 156, Section 1.b, states that "...all state agencies are to maximize their efforts to...reduce and recycle material recoverable from solid waste originating...from the construction and renovation of new facilities..."
 - 2. The Waste Reduction Goal of this Contract is that a minimum of 50% by weight of the construction and demolition materials generated in the Work be diverted from landfill disposal through a combination of re-use and recycling activities.
 - 3.. Requirements for submittal of Contractor's Construction Waste and Recycling Plan prior to the commencement of the Work.
 - 4. Contractor's quantitative reports for construction waste materials as a condition of approval of progress payments submitted to the Architect

1.02 DEFINITIONS

- A. Class III Landfill: A landfill that accepts non-hazardous resources such as household, commercial, and industrial waste, resulting from construction, remodeling, repair, and demolition operations.
- B. Construction and Demolition Debris: Building materials and solid waste resulting from construction, remodeling, repair, cleanup, or demolition operations that are not hazardous. This term includes, but is not limited to, asphalt concrete, Portland cement concrete, brick, lumber, gypsum wallboard, cardboard and other associated packaging, roofing material, ceramic tile, carpeting, carpet pad, ceiling tile, plastic pipe, other plastic material, vinyl flooring, copper pipe, and steel. This will also include other jobsite materials such as cardboard packaging, sheet vinyl, plastic bottles, white paper, and aluminum cans.
- C. C&D Recycling Center. A facility that receives C&D material that has been separated for reuse. Recycling facilities are often part of the overall County waste management facilities.
- D. Disposal. Final deposition of construction and demolition material
- E. Mixed Debris Recycling Facility: A processing facility that accepts loads of commingled construction and demolition debris for the purpose of recovering re-usable and recyclable materials and disposing the non-recyclable residual materials.
- F. Recycling: The process of sorting, cleansing, treating and reconstituting materials for the purpose of using the altered form in the manufacture of a new product. Recycling does not include burning, incinerating or thermally destroying solid waste.
- G. Reuse. The use, in the same or similar form as it was produced, of a material which might otherwise be discarded.
- H. Source-Separated: Materials, including commingled recyclables, that have been separated or kept separate from the solid waste stream at the point of generation, for the purpose of additional sorting or processing of those materials for reuse or recycling in order to return them to the economic mainstream in the form of raw materials for new, reused, or reconstituted products which meet the quality standards necessary to be used in the marketplace.
- I. Waste Hauler: A company that possesses a valid permit from the [local waste management authority to collect and transport solid wastes from individuals or businesses for the purpose of recycling or disposal in [the locality].

1.03 SUBMITTALS

- A. Contractor's Construction Waste and Recycling Plan
 1. Review Contract Documents and estimate the types and quantities of materials under the Work that are anticipated to be feasible for on-site processing, source separation for re-use or recycling. Indicate the procedures that will be implemented in this program to effect jobsite source separation, such as, identifying a convenient location where dumpsters would be located, putting signage to identify materials to be placed in dumpsters, etc.
 2. Prior to commencing the Work, submit Contractor's Construction Waste and Recycling Plan. Submit in format provided (**Section 01151A**). The Plan must include, but is not limited to the following:
 - a. Contractor's name and project identification information;
 - b. Procedures to be used;
 - c. Materials to be re-used and recycled;
 - d. Estimated quantities of materials;
 - e. Names and locations of re-use and recycling facilities/sites;
 - f. Tonnage calculations that demonstrate that Contractor will re-use and recycle a minimum 50% by weight of the construction waste materials generated in the Work.
 - g. Cost of local tip fees for non-recycled material/ton
 - h. Cost or revenue generated from recycled material, per category, per ton (note: cost and revenue are to be managed by the General Contractor as part of the Work; tonnage, cost, and savings information are to be provided to the Architect for tracking purposes only)
 2. Contractor's Construction Waste and Recycling Plan must be approved by the Architect prior to the start of Work.
 3. Contractor's Construction Waste and Recycling Plan will not otherwise relieve the Contractor of responsibility for adequate and continuing control of pollutants and other environmental protection measures.
- B. Contractor's Reuse, Recycling, and Disposal Report
 1. Submit Contractor's Reuse, Recycling, and Disposal Report on the form provided (**Section 01151B**) with each application for progress payment. Failure to submit the form and its supporting documentation will render the application for progress payment incomplete and delay progress payments. If applicable, include manifests, weight tickets, receipts, and invoices specifically identifying the Project for re-used and recycled materials:
 - a. Reuse of building materials or salvage items on site
 - b. Salvaging building materials for reuse
 - c. Recycling source separated materials on site, with approval
 - d. Recycling source separated material at an off site recycling center
 - e. Delivery of soils or mixed inerts to an inerts landfill for disposal (inert fill).
 - f. Disposal at a landfill or transfer station (where no recycling takes place).
 - g. Other (describe).

Contractor's Reuse, Recycling, and Disposal Report must quantify all materials generated in the Work, disposed in landfills, or diverted from disposal through recycling. Indicate zero (0) if there is no quantity to report for a type of material. As indicated on the form:

1. Report disposal or recycling either in tons or in cubic yards: if scales are available at disposal or recycling facility, report in tons; otherwise, report in cubic yards. Report in units for salvage items when no tonnage or cubic yard measurement is feasible.
2. Indicate locations to which materials are delivered for reuse, salvage, recycling, accepted as daily cover, inert backfill, or disposal in landfills or transfer stations.

3. Provide legible copies of weigh tickets, receipts, or invoices that specifically identify the project generating the material. Said documents must be from recyclers and/or disposal site operators that can legally accept the materials for the purpose of re-use, recycling, or disposal.
 - a. Indicate project title, project number, progress payment number, name of the company completing the Contractor's Report and compiling backup documentation, the printed name, signature, and daytime phone number of the person completing the form, the beginning and ending dates of the period covered on the Contractor's Report, and the date that the Contractor's Report is completed.
4. NCDOT General Services Division will provide a list of waste recycling sites, sorted by County and by Highway Division. It is the responsibility of the General Contractor to confirm the locations and manage the waste material.

PART 2 PRODUCTS (not used)

PART 3 EXECUTION

3.01 SALVAGE, RE-USE, RECYCLING AND PROCEDURES

- A. Identify re-use, salvage, and recycling facilities.
- B. Develop and implement procedures to re-use, salvage, and recycle new construction and excavation materials, based on the Contract Documents, the Contractor's Construction Waste and Recycling Plan, estimated quantities of available materials, and availability of recycling facilities. Procedures may include on-site recycling, source separated recycling, and/or mixed debris recycling efforts.
 1. Identify materials that are feasible for salvage, determine requirements for site storage, and transportation of materials to a salvage facility.
 2. Source separate new construction, excavation and demolition materials including, but not limited to the following types:
 - a. Asphalt.
 - b. Concrete, concrete block, slump stone (decorative concrete block), and rocks.
 - c. Gypsum wallboard
 - d. Green materials (i.e. tree trimmings and land clearing debris).
 - e. Metal (ferrous and non-ferrous).
 - f. Miscellaneous Construction Debris.
 - g. Paper or cardboard.
 - h. Red Clay Brick.
Reuse or Salvage Materials
 - i. Soils.
Wire and Cable.
 - j. Wood studs
 - k. Plastic pipe
 - l. Ceiling tile
 - m. Ceramic tile
 - n. Carpet
 - o. Vinyl flooring
 - p. Other
 3. Miscellaneous Construction Debris: Develop and implement a program to transport loads of mixed (commingled) new construction materials that cannot be feasibly source separated to a mixed materials recycling facility.

3.02 DISPOSAL OPERATIONS AND WASTE HAULING

- A. Legally transport and dispose of materials that cannot be delivered to a source separated or mixed recycling facility to a transfer station or disposal facility that can legally accept the materials for the purpose of disposal.
- B. Use a permitted waste hauler or Contractor's trucking services and personnel. To confirm valid permitted status of waste haulers, contact the local solid waste authority.
- C. Become familiar with the conditions for acceptance of new construction, excavation and demolition materials at recycling facilities, prior to delivering materials. NCDOT General Services Division will work with the General Contractor on identifying sites that will accept recycled materials.
- D. Deliver to facilities that can legally accept new construction, excavation and demolition materials for purpose of re-use, recycling, composting, or disposal.
- E. Do not burn, bury or otherwise dispose of solid waste on the project job-site.

3.03 REVENUE

- A. Revenues or other savings obtained from recycled, re-used, or salvaged materials shall accrue to the General Contractor. Accounting of revenues or savings is for the Owner's tracking purposes only.

END OF SECTION

SECTION 01200 - PROGRESS DOCUMENTATION AND PROCEDURES

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Progress documentation requirements:
 - a. Contractor's construction schedule.
 - 2. Progress procedures:
 - a. Progress meetings.
- B. Contract time is indicated elsewhere.

1.02 SUBMITTALS

- A. Contractor's Construction Schedule.
 - 1. Submit within 14 days after execution of contract.
 - 2. Submit revised schedule with application for payment to the Architect/ Engineer

1.03 FORM OF SUBMITTALS

- A. Schedules - General:
 - 1. Provide legend of symbols and abbreviations for each schedule.
 - 2. Use the same terminology as that used in the contract documents.
 - 3. When transparencies are submitted, use only media which will not fade or lose contrast over time.
- B. Bar Charts:
 - 1. Provide individual horizontal bars representing the duration of each major activity.
 - 2. Coordinate each element on the schedule with other construction activities.
 - 3. Show activities in proper sequence.
 - 4. Show percentage of completion of each activity.
 - 5. Include cost bar at top of chart, showing estimated and actual costs of work performed at the date of each application for payment.
 - 6. Use vertical lines to mark the time scale at not more than one week intervals.
 - 7. Prepare on reproducible transparency.
 - 8. Use sheets of sufficient number and width to show the full schedule clearly.

1.04 COORDINATION

- A. In preparation of schedules, take into account the time allowed or required for the Engineer's administrative procedures.

PART 2 - PRODUCTS (NOT USED)

PART 3 - EXECUTION

3.01 CONTRACTOR'S CONSTRUCTION SCHEDULE

- A. Prepare and submit a construction schedule.
- B. Provide construction schedule in the form of bar charts:
 - 1. Where related activities must be performed in sequence, show relationship graphically.
 - 2. Indicate activities separately for:
 - a. Each separate building.
 - 3. Incorporate the submittal schedule specified elsewhere.
 - 4. Show dates of:
 - a. Each activity that influences the construction time.
 - b. Ordering dates for products requiring long lead time.
 - c. All submittals required.

- d. Completion of structure.
 - e. Completion of permanent enclosure.
 - f. Instruction of the owner's personnel in operation and maintenance of equipment and systems.
 - g. Substantial and final completion, with time frames for the Engineer's completion procedures.
5. In developing the schedule take into account:
- a. Work by owner.
 - b. Need for temporary heating, ventilating, or air-conditioning.
- C. The Engineer will notify the contractor if schedule is not satisfactory; revise and resubmit.
1. Resubmit within 7 days.
- D. Make and distribute copies of schedule to the Engineer, to subcontractors, and to other entities whose work will be influenced by schedule dates.
1. Hang a copy of the schedule up in each field office or meeting room.
- E. Update the schedule whenever changes occur or are made, or when new information is received, but not less often than at the same intervals at which applications for payment are made.
1. Indicate changes made since last issue; show actual dates for activities completed.
 2. Submit updated schedule with application for payment.
 3. Issue updated schedule with report of meeting at which revisions are made.
 4. Issue updated schedule in same manner as original schedule.

3.02 PROGRESS MEETINGS

- A. Schedule and conduct periodic progress meetings during construction period.
1. Have meetings once a month.
 2. Notify the Engineer at least one week in advance of date of meeting.
- B. The following are required to attend:
1. Project superintendent.
 2. Major subcontractors and suppliers.
 3. Others who have an interest in the agenda.
 4. State inspectors.
- C. Prepare and distribute agenda prior to meetings; cover the following topics when applicable:
1. Review minutes of previous meeting.
 2. Status of submittals and impending submittals.
 3. Actual progress of activities in relation to the schedule.
 4. Actual and anticipated delays, their impact on the schedule, and corrective actions taken or proposed.
 5. Actual and potential problems.
 6. Status of change order work.
 7. Status of corrective work ordered by the Engineer.
 8. Progress expected to be made during the next period.

END OF SECTION 01200

SECTION 01300 - SUBMITTALS

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Preparing and processing of submittals for review and action.
 - 2. Preparing and processing of informational submittals.
- B. Submit the following for the Architect/Engineer's review and action:
 - 1. Shop drawings.
 - 2. Product data.
 - 3. Samples.
- C. Submit the following as informational submittals:
 - 1. Reports.
- D. Specific submittals are described in individual sections.
- E. Do not commence work which requires review of any submittals until receipt of returned submittals with an acceptable action.
- F. Submit all submittals to the Engineer.
- G. Related Sections: The following are specified elsewhere in Division 1:
 - 1. Progress of work submittals:
 - a. Contractor's construction schedules.
 - 2. Quality control submittals:
 - a. Test reports.

1.02 DEFINITIONS

- A. "Shop drawings" are drawings and other data prepared, by the entity who is to do the work, specifically to show a portion of the work.
 - 1. Shop drawings also include:
 - a. Product data specifically prepared for this project.
 - b. Shop or plant inspection and test reports, when made on specific materials, products, or systems to be used in the work.
- B. "Product data submittals" are standard printed data which show or otherwise describe a product or system, or some other portion of the work.
- C. "Samples" are actual examples of the products or work to be installed.
- D. Informational Submittals: Submittals identified in the contract documents as to be submitted for information only.

1.03 FORM OF SUBMITTALS

- A. Sheets Larger Than 8-1/2 by 14 Inches:
 - 1. Maximum sheet size: 36 by 48 inches.
 - a. Exception: Full size pattern or template drawings.
 - 2. Number of copies:
 - a. Submittals for review:
 - 1. One correctable reproducible print, not folded and 6 copies] of blue- or black-line print(s).
 - 2. Reproducible will be returned.
- B. Small Sheets or Pages:
 - 1. Minimum sheet size: 8-1/2 by 11 inches.
 - 2. Maximum sheet size for opaque copies: 8-1/2 by 17 inches.
 - 3. Number of copies:
 - a. One (1) Electronic Submittal Copy: General Contractor to Email one (1) stamped and signed copy to the Architect, and Engineer.

- b. Electronic Submittal shall be in PDF. format.
- c. Architect and Engineer shall review, stamp and sign submittal; scan and return 1 set to the General Contractor and Roadside Engineer for distribution to his subcontractors, suppliers, and retain 1 copy for his field office.
- C. If additional sets are needed by other entities involved in work represented by the samples, submit with original submittal.
- D. Copies in excess of the number requested will not be returned.

1.04 COORDINATION OF SUBMITTALS

- A. Coordinate submittals and activities that must be performed in sequence, so that the Engineer has enough information to properly review the submittals.
- B. Coordinate submittals of different types for the same product or system so that the Engineer has enough information to properly review each submittal.

PART 2 - PRODUCTS (NOT USED)

PART 3 - EXECUTION

3.01 TIMING OF SUBMITTALS

- A. Transmit each submittal at or before the time indicated on the approved schedule of submittals.
 - 1. Prepare and submit for approval a schedule showing the required dates of submittal of all submittals.
 - 2. Organize the schedule by the applicable specification section number.
 - 3. Incorporate the contractor's construction schedule specified elsewhere.
 - 4. Submit within 14 days after commencement of the work.
 - 5. Revise and resubmit the schedule for approval when requested.
- B. Deliver each submittal requiring approval in time to allow for adequate review and processing time, including resubmittals if necessary; failure of the contractor in this respect will not be considered as grounds for an extension of the contract time.
- C. Deliver each informational submittal prior to start of the work involved, unless the submittal is of a type which cannot be prepared until after completion of the work; submit promptly.
- D. If a submittal must be processed within a certain time in order to maintain the progress of the work, state so clearly on the submittal.

3.02 SUBMITTAL PROCEDURES - GENERAL

- A. Contractor Review: Sign each copy of each submittal certifying compliance with the requirements of the contract documents.
- B. Notify the Engineer, in writing and at time of submittal, of all points upon which the submittal does not conform to the requirements of the contract documents, if any.
- C. Preparation of Submittals:
 - 1. Label each copy of each submittal, with the following information:
 - a. Project name.
 - b. Date of submittal.
 - c. Contractor's name and address.
 - d. Engineer's name and address.
 - e. Subcontractor's name and address.
 - f. Other necessary identifying information.
 - 2. Pack submittals suitably for shipment.
 - 3. Submittals to receive Engineer's action marking:
Provide blank space on the label or on the submittal itself for action marking; minimum 4 inches wide by 5 inches high.

- D. Transmittal of Submittals:
 - 1. Submittals will be accepted from the contractor only. Submittals received from other entities will be returned without review or action.
 - 2. Submittals received without a transmittal form will be returned without review or action.
 - 3. Transmittal form: Similar to AIA G810.
 - 4. Fill out a separate transmittal form for each submittal; also include the following:
 - a. Other relevant information.
 - b. Requests for additional information.

3.03 SHOP DRAWINGS

- A. Content: Include the following information:
 - 1. Dimensions, at accurate scale.
 - 2. All field measurements that have been taken, at accurate scale.
 - 3. Names of specific products and materials used.
 - 4. Coordination requirements; show relationship to adjacent or critical work.
 - 5. Name of preparing firm.
- B. Preparation:
 - 1. Identify as indicated for all submittals.
 - 2. Space for Engineer's action marking shall be adjacent to the title block.

3.04 PRODUCT DATA

- A. When product data submittals are prepared specifically for this project (in the absence of standard printed information) submit such information as shop drawings and not as product data submittals.
- B. Content:
 - 1. Submit manufacturer's standard printed data sheets.
 - 2. Show compliance with properties specified.
 - 3. Show compliance with the specific standards referenced.
 - 4. Show compliance with specified testing agency listings; show the limitations of their labels or seals, if any.
 - 5. Identify dimensions which have been verified by field measurement.
 - 6. Show special coordination requirements for the product.

3.05 SAMPLES

- A. Samples:
 - 1. Provide samples that are the same as proposed product.
 - 2. Where unavoidable variations must be expected, submit "range" samples, minimum of 3 units, and describe or identify variations among units of each set.
- B. Preparation:
 - 1. Attach a description to each sample.
 - 2. Attach name of manufacturer or source to each sample.
- C. Keep final sample set(s) at the project site, available for use during progress of the work.

3.06 REVIEW OF SUBMITTALS

- A. Submittals for approval will be reviewed, marked with appropriate action, and returned.
- B. Informational submittals: Submittals will be reviewed.
 - 1. "X" action: No action taken.
 - 2. "Not Approved" action: Revise the submittal or prepare a new submittal complying with the comments made.
 - 3. A copy will be returned if submittal is unsatisfactory.

3.07 RETURN, RESUBMITTAL, AND DISTRIBUTION

- A. Submittals will be returned to the contractor by mail.
- B. Perform resubmittals in the same manner as original submittals; indicate all changes other than those requested by the Engineer.
- C. Distribution:
 - 1. Make extra copies for operation and maintenance data submittals, as required.

END OF SECTION 01300

SECTION 01600 -SUBSTITUTION PROCEDURES

PART 1 - GENERAL

1.1 DESCRIPTION

- A. Section includes Substitution Bid and Submittal Process.

1.2 SUBSTITUTION REQUIREMENTS

- A. When material, article, or method is specified using name of proprietary product manufacturer, vendor, or method followed by phrase "or equal," specific item mentioned establishes basis upon which bids are to be prepared.
 - 1. Other manufacturers' materials, articles, and methods not named will be considered as substitutions provided required information is submitted on "FORM FOR SUBSTITUTIONS FOR SPECIFIED ITEMS" and will not require substantial revisions of Contract Documents.
 - 2. This applies to specific construction methods when required by Contract Documents.
- B. Whenever material, article, or method is specified or described without phrase "or equal," no substitutions will be allowed.
- C. Cost for redesigns due to substituted items are responsibility of Contractor.
- D. Bidder represents the following in making their request for substitution(s).
 - 1. Has personally investigated proposed product or method and determined it is equal in all respects to that specified.
 - 2. Will furnish same guarantee for substitution as for product or method specified.
 - 3. Will coordinate installation of accepted substitution into Work, making design and construction changes to complete Work in all respects following Contract requirements without additional cost to the Commission.
- E. Request for substitutions received after bids are open will not be considered except as stated herein.

1.3 SUBMITTAL OF DATA FOR PROPOSED SUBSTITUTIONS

- A. In order for substitutions that do not change design intent to be considered, submit no later than 30 days after date of Notice to Proceed, 3 copies of complete data set forth herein to permit complete analysis of proposed substitutions
 - 1. For Products.
 - a. Identification including manufacturer's name and address.
 - b. Manufacturer's literature, including but not necessarily limited to:
 - 1) Product description, performance, and test data.
 - 2) Reference standards.
 - c. Samples where appropriate.
 - d. Name and address of similar projects on which product was used and dates of installation with contact name and telephone number.
 - 2. For Construction Methods.
 - a. Detailed description of proposed method.
 - b. Drawings illustrating methods.
 - c. Name and address of similar projects on which method was used and dates of use with contact name and telephone number.
 - 3. Comparison of proposed substitution with product or method specified.
 - 4. Data relating to impact on construction schedule by proposed substitution.
 - 5. Impact on other contracts.

Brunswick County (US17) Rest Area Renovations

1.4 SUBSTITUTIONS RECEIVED AFTER 30 DAYS AFTER NOTICE

- A. No request for substitutions submitted after 30 days after Notice to Proceed will be considered unless following evidence is submitted to the Architect.
 - 1. Specified material or method is unavailable, due to cause(s) stated in General Conditions, Article 15.5.1.
 - a. Submit data to permit complete analysis of the proposed substitution.

1.5 APPROVAL OF SUBSTITUTION

- A. Architect/Engineer's decision regarding evaluation of substitutions will be final and binding.
- B. Request for time extensions and additional costs based on submission, acceptance, or rejection of substitutions will be evaluated following Contract Documents.
- C. All approved substitutions will be incorporated into Contract by Change Order.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

PART 4 - MEASUREMENT AND PAYMENT

- 1.1 Providing for and complying with requirements in this Section will not be measured for payment, but cost will be considered incidental to Contract.

SECTION 02072 - DEMOLITION FOR REMODELING

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Demolition and removal of portions of the existing Rest Area building or structure; including exterior storefront, interior sheathing/drywall/tile walls, wall & roof fiberglass insulation, roofing, roof framing, exterior fencing, plumbing and electrical systems.
 - a. Site Clearing including sidewalks
 - b. See Section 01151 for the Construction and Demolition Materials Recycling Requirements.
 - 2. Owner shall have the right to salvage the Contractor removed gutters and toilet partitions.
 - a. Removal of existing small shrubbery (may be by NCDOT, Division office).

1.02 SUBMITTALS

- A. Project Record Documents:
 - 1. Identify location of capped utilities.
 - 2. Submit form Sections 01151A and 01151B per Section 01151 for the Construction and Demolition Materials Recycling Requirements.

1.03 PROJECT CONDITIONS

- A. Existing Conditions:
 - 1. After the project is begun, the contractor is responsible for the condition of structures. The owner does not warrant that the condition of structures will not have changed since the time of inspection for bidding purposes.

PART 2 - PRODUCTS (NOT USED)

PART 3 - EXECUTION

3.01 EXAMINATION

- A. Verify that utilities have been disconnected and sealed.
- B. Survey existing conditions and correlate with drawings and specifications to determine extent of demolition required; see Architectural and Electrical drawings. Salvage costs shall be reflected in the Contractor's bid.
- C. In so far as is practicable, arrange operations to reveal unknown or concealed structural conditions for examination and verification before removal or demolition.

3.02 PREPARATION

- A. Protection:
 - 1. Provide for the protection of persons passing around or through the area of demolition.
 - 2. Perform demolition so as to prevent damage to adjacent improvements and facilities to remain.
- B. Construct and maintain shoring, bracing, and supports as necessary to ensure the stability of structures.

3.03 UTILITY SERVICES

- A. Arrange with utility companies and shut off indicated utilities serving structures.
- B. Disconnect and cap indicated utilities before starting demolition operations.
- C. Identify location of capped utilities on project record documents.

3.04 POLLUTION CONTROLS

- A. Observe environmental protection regulations.
- B. Do not allow water usage that results in freezing or flooding.

3.05 DEMOLITION - GENERAL

- A. Remove: Unless items are otherwise indicated to be reinstalled or salvaged, remove and scrap.
- B. Remove and Reinstall: Remove items indicated; clean, service, and otherwise prepare for service; reinstall in the same location (or in the location indicated).
- C. Remove and Install New: Remove and dispose of items indicated and install new items in the same location (or in the location indicated).
- D. Remove and Salvage: Items indicated to be salvaged will remain the Owner's property. Carefully remove and clean items indicated to be salvaged; protect against damage; Owner may salvage some of the toilet fixtures, and toilet partitions.
- E. Remove and Scrap: Remove and dispose of items indicated in Section 01151 for the Construction and Demolition Materials Recycling Requirements.
 - 1. Items of value to the contractor: Do not store removed items on site.
- F. Existing to Remain: Construction or items indicated to remain shall be protected against damage during demolition operations. Where practicable, and with the architect's permission, the contractor may elect to remove items to a suitable storage location during demolition and then properly clean and reinstall the items.
- G. Perform work in a systematic manner.
- H. Perform selective demolition using methods which are least likely to damage work to remain and which will provide proper surfaces for patching.

3.06 DEMOLITION ON OR BELOW GRADE

- A. Where portions of concrete slabs-on-grade are to be removed, first outline the portion with a concrete saw to a depth of at least 1 inch.

3.07 FILLING BELOW-GRADE AREAS AND VOIDS

- A. Below-grade areas and voids resulting from demolition of structures shall be filled or excavated further, as appropriate, according to requirements specified elsewhere.

3.08 DISPOSAL OF DEMOLISHED MATERIALS

- A. Promptly dispose of materials resulting from demolition operations. Do not allow materials to accumulate on site. See Section 01151 for the Construction and Demolition Materials Recycling Requirements.
- B. Transport concrete or masonry debris resulting from demolition operations and dispose off the Owner's property.
- C. Transport all other materials resulting from demolition operations and legally dispose of off-site.

Brunswick County (US17) Rest Area Renovations

- D. Do not burn removed materials on project site.
- F. Remove decayed, vermin-infested, or otherwise dangerous or unsuitable materials and promptly dispose of off-site.

3.09 CLEANING

- A. Clean soil, smudges, and dust from surfaces to remain.

END OF SECTION 02072

THIS PAGE LEFT BLANK INTENTIONALLY.

SECTION 03300 – CAST IN PLACE CONCRETE

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes: Cast-in-place concrete and concrete curing.
 - 1. Sidewalks, see Roadside Environmental concrete section.
 - 2. New concrete slab
 - 3. Repair of concrete slabs

1.2 SUBMITTALS

- A. Product Data: Submit manufacturer's product data / Mix Design to the Engineer:
 - 1. Concrete mix, reinforcing, admixtures and curing compound.

1.3 QUALITY ASSURANCE

- A. Codes and Standards: Comply with the following documents, except where requirements of the contract documents or of governing codes and governing authorities are more stringent:
 - 1. Sidewalks, curb ramps, steps, curb & gutters, and parking lot paving shall comply with **NCDOT Standard Specifications** dated January 2012, Divisions 7 and 8; Sections 710, 846 and 848; Class "A" concrete for Portland Cement Production and Delivery.
 - 2. ACI 301 & ACI 318.
- B. Testing Agency Services:
 - 1. NCDOT's testing agency will conduct tests and perform other services specified for quality control during construction.

PART 2 - PRODUCTS

2.1 CONCRETE MATERIALS

- A. Portland Cement: ASTM C 150, and as follows:
 - 1. Type I, except where other type is specifically permitted or required.
 - a. Type I may be replaced by Type III (high early strength) for concrete placed during cold weather.
- B. Water: Potable.
- C. Aggregates: Normal weight concrete: ASTM C 33.
- D. Admixtures - General: Admixtures which result in more than 0.1 percent of soluble chloride ions by weight of cement are prohibited.
- E. Air-Entraining Admixture: ASTM C 260 and certified by manufacturer for compatibility with other mix components.
- F. Water-Reducing Admixture: ASTM C 494, Type A.

2.2 CONCRETE REPAIR MATERIALS

- A. Fast-drying, cement-based underlayment skim coat
 - 1. Manufacturer: Basis of Design: Laticrete NXT Skim (or approved equal. All concrete repair products to be of the same manufacturer. Also the tile installation materials shall be the same manufacturer to ensure compatibility.)
 - 2. Prep slab according to manufacturer's instructions
 - 3. Use to level/repair any cracks per manufacturer's instructions.

- B. Fast set two-component hybrid urethane for permanent concrete repair
 - 1. Manufacturer: Basis of Design: Laticrete, Spartacote Fast Fix (or approved equal. All concrete repair products to be of the same manufacturer. Also the tile installation materials shall be the same manufacturer to ensure compatibility.)
 - 2. Prep slab according to manufacturer's instructions
 - 3. Use to level/repair any cracks per manufacturer's instructions
- C. Fast-Drying Cement Based underlayment for patching
 - 1. Manufacturer: Basis of Design: Laticrete, NXT Patch (or approved equal. All concrete repair products to be of the same manufacturer. Also the tile installation materials shall be the same manufacturer to ensure compatibility.)
 - 2. Prep slab according to manufacturer's instructions
 - 3. Use to level/repair any cracks per manufacturer's instructions

2.3 MISCELLANEOUS MATERIALS AND ACCESSORIES

- A. Formwork:
 - 1. Facing Materials: Unexposed finish concrete: Any standard form materials that produce structurally sound concrete.
 - 2. Formwork Accessories:
 - a. Form coating: Form release agent that will not adversely affect concrete surfaces or prevent subsequent application of concrete coatings.
 - b. Metal ties: Commercially manufactured types; cone snap ties, taper removable bolt, or other type which will leave no metal closer than 1-1/2 inches from surface of concrete when forms are removed, leaving not more than a 1-inch-diameter hole in concrete surface.
- B. Reinforcing Materials:
 - 1. Reinforcing Bars: Provide deformed bars complying with the following, except where otherwise indicated: ASTM A 615, Grade 60.
 - 2. Welded Wire Fabric: ASTM A 185, cold-drawn steel, plain.
 - 3. Tie wire: Black annealed type, 16-1/2 gage or heavier.
 - 4. Supports: Bar supports conforming to specifications of CRSI "Manual of Standard Practice."
- C. Vapor Retarder: Membrane for installation beneath slabs on grade, resistant to decay when tested in accordance with ASTM E 1745, and as follows:
 - 1. 15 mils thick, multi-layer, fabric-, cord-, grid-, or aluminum-reinforced polyethylene or equivalent, Class A; stated by manufacturer as suitable for installation in contact with soil or granular fill under concrete slabs Single ply polyethylene sheet is prohibited.
 - 2. See also spec section 07260.
- D. Moisture-Retaining Cover: ASTM C 171, and as follows:
 - 1. Polyethylene film.
- E. Liquid Curing Compounds: Comply with ASTM C 309, Type 1 and compatible with flooring.

2.4 CONCRETE MIX DESIGN

- A. Proportioning of Normal Weight Concrete: Comply with recommendations of ACI 211.1.
- B. Specified Compressive Strength f_c at 28 Days for Locations as Indicated on Drawings:
 - 1. Footings: 3000 psi., maximum w/c ratio = 0.58
 - 2. Interior Slabs: 4000 psi, maximum w/c ratio = 0.50.
 - 3. Exterior slabs: 5000 psi, maximum w/c ratio = 0.40.
- C. Admixtures:
 - 1. Air-entraining admixture: Use in mixes for exterior exposed concrete unless otherwise specifically indicated. Add at rate to achieve total air content in accordance with Table

- 1.4.3 of ACI 201.2. For concrete not exposed to exterior, add at rate to achieve total air content between 1 percent and 3 percent.
 - a. Do not use in slabs-on-grade scheduled to receive topping, unless manufacturer of topping recommends use over air-entrained concrete.
2. Do not use admixtures not specified or approved.

PART 3 - EXECUTION

3.01 EXISTING SLAB PREP

- A. General: Remove mud bed tile and thin-set tile as indicated on drawings. Clean surface as needed. Grind surface for proper bonding. Apply bonding agent as recommended by concrete repair and tile setting materials. See also spec section 09300.

3.02 VAPOR RETARDER INSTALLATION

- A. General: Place vapor retarder sheet over prepared base material, aligning longer dimension parallel to direction of pour and lapped 6 inches. Seal joints with appropriate tape. Cover with sand to depth shown on drawings.

3.03 JOINT CONSTRUCTION

- A. Construction Joints: Locate and install construction joints as indicated on drawings. If construction joints are not indicated, locate in manner which will not impair strength and will have least impact on appearance, as acceptable to the Engineer.
 1. Keyways: Provide keyways not less than 1-1/2 inches deep.
 2. Reinforcement: Continue reinforcement across and perpendicular to construction joints, unless details specifically indicate otherwise.
- B. Control Joints: Construct contraction joints in slabs poured on grade to form panels of sizes indicated on drawings, but not more than 12 feet apart in either direction.
 1. Saw cuts: Form control joints by means of saw cuts one-fourth slab depth.

3.04 CONCRETE PLACEMENT

- A. Inspection: Before beginning concrete placement, inspect formwork, reinforcing steel, and items to be embedded, verifying that all such work has been completed.
 1. Wood forms: Moisten immediately before placing concrete in locations where form coatings are not used.
- B. Placement - General: Comply with requirements of ACI 304 and as follows:
 1. Schedule continuous placement of concrete to prevent the formation of cold joints.
 2. Provide construction joints if concrete for a particular element or component cannot be placed in a continuous operation.
 3. Deposit concrete as close as possible to its final location, to avoid segregation.
- C. Placement in Forms: Limit horizontal layers to depths which can be properly consolidated, but in no event greater than 24 inches.
 1. Vibrate concrete sufficiently to achieve consistent consolidation without segregation of coarse aggregates.
 2. Do not use vibrators to move concrete laterally.
- D. Slab Placement: Schedule continuous placement and consolidation of concrete within planned construction joints.
 1. Thoroughly consolidate concrete without displacing reinforcement or embedded items, using internal vibrators, vibrating screeds, roller pipe screeds, or other means acceptable to Engineer.

2. Strike off and level concrete slab surfaces, using highway straightedges, darbies, or bull floats before bleed water can collect on surface. Do not work concrete further until finishing operations are commenced.

3.05 FINISHING FORMED SURFACES

- A. Repairs, General: Repair surface defects, including tie holes, immediately after removing formwork.
 1. Smooth rubbed finish: Apply to surfaces indicated no later than 24 hours after form removal.
 - a. Wet concrete surfaces to be finished and rub with Carborundum brick or other abrasive until uniform color and texture are achieved.
 - b. Do not apply separate grout mixture.

3.06 FINISHING SLABS

- A. Finishing Operations - General:
 1. Do not directly apply water to slab surface or dust with cement.
 2. Use hand or powered equipment only as recommended in ACI 302.1R.
 3. Screeding: Strikeoff to required grade and within surface tolerances indicated. Verify conformance to surface tolerances. Correct deficiencies while concrete is still plastic.
 4. Bull Floating: Immediately following screeding, bull float or darby before bleed water appears to eliminate ridges, fill in voids, and embed coarse aggregate. Recheck and correct surface tolerances.
 5. Final floating: Float to embed coarse aggregate, to eliminate ridges, to compact concrete, to consolidate mortar at surface, and to achieve uniform, sandy texture. Recheck and correct surface tolerances.
 6. Troweling: Trowel immediately following final floating. Apply first troweling with power trowel except in confined areas, and apply subsequent trowelings with hand trowels. Wait between trowelings to allow concrete to harden. Do not over trowel. Begin final troweling when surface produces a ringing sound as trowel is moved over it. Consolidate concrete surface by final troweling operation. Completed surface shall be free of trowel marks, uniform in texture and appearance, and within surface tolerance specified.
 - a. Grind smooth surface defects which would telegraph through final floor covering system.
- B. Coordinate appearance and texture of required final finishes with the Engineer before application.
- C. Broomed Float Finish: After floating and when water sheen has practically disappeared, apply uniform transverse corrugations approximately 1/16 inch deep, without tearing surface.
- D. Trowel Finish: As specified above.
- E. Trowel and Fine Broom Finish: Follow trowel finishing operation immediately with fine brooming to achieve slightly scarified surface.
- F. Slab Surface Tolerances:
 1. Achieve flat, level planes except where grades are indicated. Slope uniformly to drains.
 2. Floated finishes: Depressions between high spots shall not exceed 5/16 inch under a 10-foot straightedge.
 3. Troweled finishes: Achieve level surface plane so that depressions between high spots do not exceed the following dimension, using a 10-foot straightedge:
 - a. 1/8 inch.
- G. Slab Finish Schedule: Apply finishes in the following typical locations and as otherwise shown on the drawings:
 1. Trowel finish:
 - a. Exposed interior floors not otherwise scheduled.
 - b. Surfaces to receive resilient tile.
 2. Trowel and fine broom: Surfaces to receive terrazzo.

3. Broom float finish: Exterior slabs and stairs.

3.07 CONCRETE CURING AND PROTECTION

- A. General:
 1. Prevent premature drying of freshly placed concrete, and protect from excessively cold or hot temperatures until concrete has cured.
 2. Provide curing of concrete by one of the methods listed and as appropriate to service conditions and type of applied finish in each case.
- B. Curing Period:
 1. Not less than 7 days for standard cements and mixes.
 2. Not less than 4 days for high early strength concrete using Type III cement.
- C. Formed Surfaces: Cure formed concrete surfaces by moist curing with forms in place for full curing period or until forms are removed.
- D. Surfaces Not in Contact with Forms:
 1. Start initial curing as soon as free water has disappeared, but before surface is dry.
 2. Keep continuously moist for not less than 3 days by uninterrupted use of any of the following:
 - a. Water ponding.
 - b. Water-saturated sand.
 - c. Water-fog spray.
 - d. Saturated burlap: Provide 4-inch minimum overlap at joints.
 3. Begin final curing procedures immediately following initial curing and before concrete has dried.
 4. Continue final curing to end of curing period.
- E. Avoid rapid drying at end of curing period.
- F. Protect slabs during construction process, especially from spillage.

3.08 QUALITY CONTROL TESTING DURING CONSTRUCTION

- A. Composite Sampling, and Making and Curing of Specimens: ASTM C 172 and ASTM C 31.
- B. Slump: ASTM C 143. One test per batch.
 1. Modify sampling to comply with ASTM C 94.
- C. Air Content of Normal Weight Concrete: ASTM C 173 or ASTM C 231. One test per strength test performed on air-entrained concrete.
- D. Compressive Strength Tests: ASTM C 39.
 1. Testing for acceptance of potential strength of as-delivered concrete:
 - a. Obtain samples on a statistically sound, random basis.
 - b. Minimum frequency:
 1. One set per 100 cubic yards or fraction thereof for each day's pour of each concrete class.
 2. One set per 3500 square feet of slab or wall area or fraction thereof for each day's pour of each concrete class.

END OF SECTION 03310

Brunswick County (US17) Rest Area Renovations

This page left blank intentionally.

SECTION 04210 - CLAY UNIT MASONRY

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Clay masonry units and accessories including:
 - 1. Brick units.
 - 2. Anchors and ties.
 - 3. Expansion joints.
 - 4. Flashing.
 - 5. Reinforcement.
 - 6. Mortar.
 - 7. Cleaning.

1.2 RELATED SECTIONS

- A. Section 03300 - Cast-In-Place Concrete.
- B. Section 04220 - Concrete Unit Masonry.
- C. Section 05120 - Structural Steel.
- D. Section 07160 - Bituminous Waterproofing.
- E. Section 07210 - Thermal Insulation.

1.3 REFERENCES

- A. ASTM A 36 - Standard Specification for Carbon Structural Steel.
- B. ASTM A 82 - Standard Specification for Steel Wire, Plain, for Concrete Reinforcement.
- C. ASTM A 153 - Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware.
- D. ASTM A 615 - Standard Specification for Deformed and Plain Carbon-Steel Bars for Concrete Reinforcement.
- E. ASTM A 616 - Standard Specification for Rail-Steel Deformed and Plain Bars for Concrete Reinforcement.
- F. ASTM A 617 - Standard Specification for Axle-Steel Deformed and Plain Bars for Concrete Reinforcement.
- G. ASTM A 666 - Standard Specification for Stainless and Heat-Resisting Chromium-Nickel Steel Plate, Sheet, and Strip.
- H. ASTM A 775 - Standard Specification for Epoxy-Coated Steel Reinforcing Bars.
- I. ASTM A996 - Standard Specification for Rail-Steel and Axle-Steel Deformed Bars for Concrete Reinforcement.
- J. ASTM B 370 - Standard Specification for Copper Sheet and Strip for Building Construction.
- K. ASTM C 67 - Standard Test Methods for Sampling and Testing Brick and Structural Clay Tile.
- L. ASTM C 216 - Standard Specification for Facing Brick (Solid Masonry Units Made from Clay or Shale).
- M. ASTM C 270 - Standard Specification for Mortar for Unit Masonry.
- N. ASTM C 652 - Standard Specification for Hollow Brick (Hollow Masonry Units Made From Clay or Shale).
- O. ASTM C 1088 - Standard Specification for Thin Veneer Brick Units Made from Clay or Shale.
- P. ASTM D 1056 - Standard Specification for Flexible Cellular Materials Sponge or Expanded Rubber.

1.4 SUBMITTALS

- A. Submit under provisions of Section 013300.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Installation methods.
- C. Sample Panel: Mock-up or sample panels shall be used to review brick and mortar color and serve as the standard of workmanship for the Project.
 - 1. Approximately 4 feet (1.2 m) long by 3 feet (1 m) high, showing the proposed color range, texture, bond, mortar and workmanship. All brick shipped for the sample shall be included in the panel.
 - 2. When required, provide a separate panel for each type of brick or mortar.
 - 3. Do not start work until Architect/Engineer has accepted sample panel.
 - 4. Use panel as standard of comparison for all masonry work built of same material.
 - 5. Do not destroy or move panel until work is completed and accepted by Architect.

1.5 QUALITY ASSURANCE

- A. Installer Qualifications: Company specializing in performing the work of this section with minimum five years experience.
- B. Brick Tests: Sample and test shall be in accordance with ASTM C 67.
- C. Test Reports:
 - 1. Testing and reports shall be completed by an independent laboratory.
 - 2. Test reports for each type of building and facing brick shall be submitted to the Architect/Engineer for review.
 - 3. Test reports shall indicate:
 - 4. Compressive strength.
 - 5. 24 hour cold water absorption.
 - 6. 5-hour boil absorption.
 - 7. Saturation coefficient.
 - 8. Initial rate of absorption.
 - 9. Efflorescence.
- D. Certificates: Prior to delivery, submit to Architect/Engineer certificates attesting compliance with the applicable specifications for grades, types or classes included in these specifications.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Store brick off the ground to prevent contamination by mud, dust or other materials likely to cause staining or other defects.
- C. Cover all materials with a nonstaining waterproof membrane material when necessary to protect from elements.
- D. Store different types of materials separately.

1.7 PROJECT CONDITIONS

- A. Protection of Work:
 - 1. Wall Covering:
 - a. During erection, cover top of wall with strong nonstaining waterproof membrane at end of each day or shutdown.
 - b. Cover partially completed walls when work is not in progress.
 - c. Extend cover minimum of 24 inches (610 mm) down both sides.
 - d. Hold cover securely in place.
 - 2. Load Applications:

Brunswick County (US17) Rest Area Renovations

- a. Do not apply uniform floor or roof loading for at least 12 hours after building masonry columns or wall.
 - b. Do not apply concentrated loads for at least 3 days after building masonry columns or walls.
 3. Stain Prevention:
 - a. Prevent grout or mortar from staining the face of masonry.
 - b. Remove immediately grout or mortar in contact with face of such masonry.
 - c. Protect all sills, ledges and projections from droppings of mortar.
 - d. Protect base of wall from rain-splashed mud and mortar splatter.
 - e. Scaffold boards shall be turned on edge when work is not in progress.
- B. Cold Weather Protection:
1. Preparation:
 - a. When ice or snow has formed on masonry bed, remove by carefully applying heat not to exceed 120 degrees F (49 degrees C) until surface is dry to the touch.
 - b. Remove all masonry deemed frozen or damaged.
 2. Products:
 - a. When brick suction exceeds BIA reference standard, sprinkle with heated water:
 - 1) When units are above 32 degrees F (0 degrees C), heat water above 70 degrees F (21 degrees C).
 - 2) When units are below 32 degrees F (0 degrees C), heat water above 130 degrees F (54 degrees C).
 - b. Use dry masonry units.
 - c. Do not use wet or frozen units.
 3. Construction Requirements While Work is Progressing:
 - a. Air temperature 40 degrees F (4 degrees C) to 32 degrees F (0 degrees C):
 - 1) Heat sand or mixing water to produce mortar temperatures between 40 degrees F (4 degrees C) to 32 degrees F (0 degrees C).
 - b. Air temperature 32 degrees F (0 degrees C) to 25 degrees F (-4 degrees C):
 - 1) Heat sand and mixing water to produce temperatures between 40 degrees F (4 degrees C) and 120 degrees F (49 degrees C).
 - 2) Maintain temperature of mortar on boards above freezing.
 - c. Air temperatures 25 degrees F (-4 degrees C) to 20 degrees F (-7 degrees C):
 - 1) Heat sand and mixing water to produce mortar temperatures between 40 degrees F (4 degrees C) and 120 degrees F. (49 degrees C).
 - 2) Maintain mortar temperatures on boards above freezing.
 - 3) Use salamanders or other heat sources on both sides of walls under construction.
 - 4) Use windbreaks when wind is in excess of 15 mph (24 kms/h).
 - d. Air temperature 20 degrees F (-7 degrees C) and below:
 - 1) Heat sand and mixing water to produce mortar temperatures between 40 degrees F (4 degrees C) and 120 degrees F (49 degrees C.).
 - 2) Provide enclosures and auxiliary heat to maintain air temperature above 32 degrees F (0 degrees C).
 - 3) Minimum temperature of units when laid: 20 degrees F (-7 degrees C).
 4. Protection requirements for completed masonry and masonry not being worked on:
 - a. Mean daily air temperature 40 degrees F (4 degrees C) to 32 degrees F (0 degrees C):
 - 1) Protect masonry from rain or snow for 24 hours by covering with

- weather-resistive membrane.
 - b. Mean daily air temperature 32 degrees F (0 degrees C) to 25 degrees F (-4 degrees C):
 - 1) Completely cover masonry with weather-resistive membrane for 24 hrs.
 - c. Mean daily temperature 25 degrees F (-4 degrees C) to 20 degrees F (-7 degrees C):
 - 1) Completely cover masonry with insulating blankets or equal protection for 24 hours.
 - d. Mean daily air temperature 20 degrees F (-7 degrees C) and below:
 - 1) Maintain masonry temperature above 32 degrees F (0 degrees C) for 24 hours by:
 - a) Method: Enclosure and supplementary heat.
 - b) Method: Other approved methods.
- C. Hot Weather Protection:
 - 1. When temperature exceeds 100 degrees F or 90 degrees F with 8 mph wind (above 38 degrees C or 32 degrees C with 13 kms/h wind).
 - a. Maintain temperature of mortar and grout between 70 degrees F and 120 degrees F (21 degrees C and 49 degrees C).
 - 1) Limit spread of mortar bed to 4 feet (1.2 m). Place units within 1 minute of spreading mortar.
 - b. Partially or recently completed walls may be fog sprayed and/or covered with opaque plastic or canvas or both to control moisture evaporation.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturers: Triangle Brick, Lee Brick, Statesville Brick, Pine Hall or Taylor Clay
- B. Substitutions: submit to Architect.

2.2 CLAY MASONRY UNITS

- A. All brick specified and shown on drawing shall be as listed below:
 - 1. Facing Brick: ASTM C 216, Grade SW,
 - a. Type FBS.
 - b. Size: Modular.
- B. Minimum Compressive Strength: 5,000 PSI.
- C. Maximum Initial Rate of Absorption (IRA): 0.78.
- D. Provide brick similar in texture, color and physical properties to those available for inspection at the Architect/Engineer's office and/or as supplied on the approved sample panel.
- E. Shapes: Special shapes are required to be used per architectural detail(s).
- F. All brick supplied shall be pre-blended by the manufacturer.

2.3 ANCHORS AND TIES

- A. Ladder Joint Reinforcement: ASTM A 82 (ASTM A 666), Size per structural drawings, Galvanized: ASTM A 153, Class B-2.
- B. Anchors:
 - 1. at CMU and Concrete: 2-Seal Thermal Concrete Wing Nut Anchor by Hohmann & Barnard, Inc., or approved equal
 - 2. at Metal Studs: Adjustable, 2-piece assemblies, for attachment over sheathing to

metal studs with leg length to allow for rigid insulation, allowing vertical and horizontal movement and capable of withstanding a 100-lbf load in tension or compression without deforming.

2.4 FLASHING

- A. Combinations
 - 1. Asphalt-Coated Copper: 7 oz.

2.5 EXPANSION JOINTS

- A. Premolded Foam: ASTM D 1056, Type 2, Class A, Grade 1.
- B. Neoprene: ASTM D 1056, Type 2, Class A, Grade 1.
- C. Backer Rod: Extruded, Closed Cell Polyethylene.

2.6 ACCESSORIES

- A. Weepholes:
 - 1. Plastic Weep/Vents if preferred in lieu of open head joints.
- B. Mortar Deflector:
 - 1. Trapezoidal shape, open weave mesh with insect barrier

2.7 MORTAR

- A. Mortar shall conform to ASTM C 270 under the guidelines provided in BIA Technical Notes #8 Series.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Do not begin installation until substrates have been properly prepared.
- B. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Cleaning Reinforcement:
 - 1. Remove mud, loose rust, ice and other coatings from reinforcement which would interfere with bond.
- C. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

3.3 INSTALLATION

- A. Install in accordance with manufacturer's instructions.

3.4 BONDING

- A. Lay masonry in bond pattern as indicated on drawings or general notes.
 - 1. Reference BIA Technical Note #30 for additional requirements.

3.5 LAYING MASONRY

- A. Lay masonry with full head and bed joints.
- B. Lay all brick plumb and true to lines.
- C. Where fresh mortar joins partially set mortar, remove loose brick and mortar, and lightly wet exposed surface of set masonry.
- D. Toothing shall be subject to approval by the Architect/Engineer.
- E. When adjustment is necessary to be made after mortar begins to harden, remove hardened mortar and replace with fresh mortar.

3.6 TOOLING AND POINTING

- A. Joint Profile: Tool mortar joints to a concave appearance.
- B. Tool exposed joints when "thumb-print" hard.
- C. Flush cut all joints not tooled.
- D. When pointing, rake mortar joints to a depth of not less than 1/2 inch (12 mm). Fill solidly with pointing mortar. Tool joints.

3.7 FLASHING

- A. Clean surface of masonry from projections which might puncture flashing.
- B. Place through-wall flashing on bed of mortar.
- C. Cover flashing with mortar.
- D. Lap flashing a minimum of 6 inches (152 mm).
- E. Leave flashing project from face of wall approximately 1/4 inch (6 mm) to form a drip. Flashing shall be cut back to the face of the wall after inspection, if the drip is deemed objectionable by Architect.

3.8 WEEPHOLES

- A. Provide weep holes in head joints of the first brick course immediately above flashing by placing weeps no more than 24 inches (610 mm) on center horizontally.
- B. Keep cavity free from mortar.

3.9 EXPANSION JOINTS

- A. Keep clean from all mortar and debris.
- B. Locate as shown on drawing.
- C. Install neoprene pre-molded foam pad.
- D. Install backer rod.
- E. Install sealant. Prime surfaces if necessary.

3.10 CLEANING

- A. Cut out all defective mortar joints and holes in exposed masonry and provide new mortar.
- B. Clean pre-selected sample wall area. Do not proceed with cleaning until approved by Architect.
- C. Clean brick as outlined in BIA Technical Notes 20 Revised II.
- D. All cleaning practices and product used shall be in accordance with cleaning products manufacturer's printed instructions.

END OF SECTION

SECTION 04220 – CONCRETE UNIT MASONRY

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Concrete masonry units.
 - 2. Mortar and grout, reinforcement, anchorage, and accessories.

PART 2 - PRODUCTS

2.01 CONCRETE MASONRY UNITS

- A. Concrete Block: Comply with referenced standards for types required to match existing, and as follows:
 - 1. Size: Standard units with nominal dimensions of 16" long, 8" high, and 4", 6" & 8" thick.
 - 2. Special shapes: Provide special block types where required for corners, control joints, headers, lintels, and other special conditions, whether or not specifically indicated on the drawings as special.
 - a. Outside corners: Square-edged units except where otherwise indicated.
 - 3. Hollow load-bearing units: ASTM C 90, and as follows:
 - a. Standard weight.
 - b. 2000 psi net compressive strength.
 - c. Exposed faces: Manufacturer's standard color and texture.

2.02 MORTAR AND GROUT MATERIALS

- A. Portland Cement: ASTM C 150, Type I.
- B. Hydrated Lime: ASTM C 207, Type S.
- C. Aggregate for Mortar: ASTM C 144.
- D. Water: Potable.

2.03 REINFORCEMENT AND ANCHORAGE

- A. Joint Reinforcement and Anchorage Materials: Comply with the following general requirements for materials required in joint reinforcement and anchorage devices:
 - 1. Steel wire: ASTM A 82.
 - a. Hot-dip galvanizing (after fabrication): ASTM A 153, Class B-2.
 - 1. Use: Exterior locations or in contact with earth.
 - 2. Hot-dip galvanized steel sheet: ASTM A 635 or ASTM A 366; galvanizing in compliance with ASTM A 153, Class B.
 - a. Use: Anchors and miscellaneous sheet metal in masonry accessories at exterior exposures.
- B. Joint Reinforcement: Welded-wire units prefabricated into straight lengths of not less than 10 feet, with deformed continuous side rods and plain cross rods.
 - 1. Width: Approximately two inches less than nominal wall width, providing not less than 5/8 inch mortar coverage on exterior exposures and 1/2 inch elsewhere.
 - 2. Wire sizes:
 - a. Side rod diameter: 0.1483 inch.
 - b. Cross rod diameter: 0.1483 inch.
 - 3. Configuration:

- a. Applications of single unit width: Ladder design, cross rods at not more than 16 inches on center.
- b. Corners: Prefabricated L- and T-shaped units.

2.04 MISCELLANEOUS MASONRY ACCESSORIES

- A. Bond Breaker Strips: ASTM D 226, Type I; No. 15 asphalt felt.
- B. Sealant and Backer Rod: As specified in Division 7.
- C. Masonry Veneer Anchors at Wood Studs: Adjustable, 2-piece assemblies, for attachment over sheathing to wood studs, allowing vertical and horizontal movement and capable of withstanding a 100-lbf load in tension or compression without deforming.
- D. Flexible Sheet Flashing: Perm-A-Barrier Wall Flashing by W. R. Grace & Company or Keystone Flashing Co. or Polyguard Products Inc. or approved equal, 40 mil thick x 18" wide rolls.

2.05 MORTAR AND GROUT MIXES

- A. Mortar for Unit Masonry: ASTM C 270, Proportion Specification.
 1. Limit cementitious materials to lime and portland cement.
 2. Masonry below grade and in contact with earth: Type M or S.
 3. Locations indicated on the drawings: Type S.
 4. Applications as follows: Type N.
 - a. Exterior, above-grade veneer.
 - b. Locations for which another mortar type has not been specifically indicated.
- B. Grout fill for masonry: ASTM C476, 28-day compressive strength = 3000 psi

PART 3 - EXECUTION

3.01 INSTALLATION PROCEDURES

- A. Comply with manufacturer's installation instructions for the stone veneer selected with a stacked appearance.
- B. Concrete Masonry Units: Do not wet concrete masonry units prior to laying.
- C. Cutting: Where cutting is required, use power saws to provide clean, sharp, unchipped edges.
 1. Do not use wet cutting techniques with concrete unit masonry.

3.02 LAYING MASONRY UNITS

- A. Hollow Masonry Units: Install so that face shells are solidly mortared, horizontally and vertically. Bed webs solidly in mortar at starting course.
- B. Joints: Make mortar joints visually and dimensionally consistent.
 1. Except as otherwise indicated, maintain mortar joint widths of 3/8 inch.
- C. Exposed Joints: Using concave jointer slightly larger than joint width, tool exposed joints before mortar has assumed final set.

3.03 JOINT REINFORCEMENT, SINGLE-WYTHE WALLS

- A. General: Provide continuous horizontal joint reinforcement for specific single-wythe masonry walls indicated. Lap reinforcing a minimum of 6 inches.
- B. Vertical Spacing: Not more than 16 inches on center.

3.04 CLEANING AND PROTECTION

- A. Clean masonry after mortar is thoroughly set and cured.
 - 1. Scrape off adhered mortar particles by hand, using non-metallic tools.
 - 2. Comply with directions of concrete unit masonry manufacturer and NCMA Tek Bulletin No. 45 for cleaning CMU.
- B. Protection: Institute protective measures as required to ensure that unit masonry work will be clean and undamaged at substantial completion.

END OF SECTION 04220

Brunswick County (US17) Rest Area Renovations

This page left blank intentionally.

SECTION 05120 - STRUCTURAL STEEL

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Fabrication and erection of structural steel framing members, as defined in AISC Code and as indicated on the drawings.
 - 2. Shop painting.

1.02 SUBMITTALS

- A. Product Data: Producer's or manufacturer's information for products as follows, including sufficient data to show compliance with specified requirements:
 - 1. Mill test reports for each type of structural steel furnished.
 - 2. Specifications for primer paint, including manufacturer's data on chemical composition, adhesion of spray fireproofing, and dry film thickness per applied coat.
 - 3. Specifications for nonshrink grout.
- B. Shop Drawings: Complete drawings for structural steel, including information on location, type, and size of all connections, distinguishing between those made in the shop and those made in the field.

1.03 QUALITY ASSURANCE

- A. Welding Procedures: Establish that joint welding procedures are prequalified or test in accordance with American Welding Society (AWS) qualification procedures.
- B. Regulatory Requirements: Unless other requirements of governing authorities or particular requirements of this specification are more stringent, comply with provisions of the following:
 - 1. AISC "Code of Standard Practice for Steel Buildings and Bridges."
 - 2. AISC "Specification for Structural Steel Buildings—ANSI/AISC 360-10, with Commentary and Supplements."
 - 3. AWS D1.1, "Structural Welding Code - Steel."
- C. Testing and Inspection Agency: The owner will engage an independent testing and inspection agency to perform testing, inspect and evaluate connections, and prepare test reports.
 - 1. Correct deficiencies in the structural steel work identified by the testing and inspection agency at no additional expense to the owner. Subsequent tests to confirm the adequacy of corrected work will be at the contractor's expense.

PART 2 - PRODUCTS

2.01 STEEL MATERIALS

- A. Structural Steel Members: ASTM A 36.
- B. Steel Pipe: ASTM A 53, Type and grade: Type E, Grade B.
- C. Cold-Formed Structural Tubing: ASTM A 500, Grade B or C.
- D. Anchor Bolts: ASTM F1554, Grade 36, or ASTM A36 rod; ASTM A 36 steel plate washers.
- E. Carbon Steel Bolts and Nuts: ASTM A 307, Grade A.
- F. High-Strength Bolts, Nuts, and Washers: ASTM A 325.
 - 1. Type 1, plain (medium carbon steel).

2.02 MISCELLANEOUS MATERIALS

- A. Welding Electrodes and Fluxes: AWS D1.1; types as required by materials being welded.

- B. Nonshrink Grout: Prepackaged material requiring only the addition of water and complying with ASTM C 1107, and as follows:
 - 1. Natural aggregate (nonmetallic) type.
- C. Shop Primer: Rust-inhibitive, lead and chromate free, low VOC primer, complying with FS TT-P-664, or equivalent.

2.03 FABRICATION

- A. Shop Assembly - General: Comply with requirements of AISC Specifications. Shop fabricate and assemble to maximum degree possible.
- B. Connections:
 - 1. Shop connections: Welded or bolted, as required.
 - 2. Field connections: Welded or bolted, as required.
 - 3. Bolts: High-strength steel bolts, except as otherwise indicated.
 - a. Bolting: Comply with requirements of AISC "Specification for Structural Joints Using ASTM A325 or A490 Bolts."
 - 4. Welds: Comply with requirements of AWS Code for welding procedures and quality of welds, including appearance.
- C. Finishing: Accurately mill ends of columns and other members which must transmit loads in bearing.

2.04 SHOP COATING - PAINT

- A. Shop prime steel members as noted on drawings.
- B. Preparation: Thoroughly clean steel surfaces to be shop primed, removing loose rust, loose mill scale, dirt, oil, and grease. Clean steel in accordance with SSPC procedures as follows:
 - 1. Power tool or blast cleaning: SSPC SP-3, -5, -6, or 10.
- C. Painting: As soon as possible after cleaning, apply rust-inhibiting gray primer paint in accordance with instructions of paint manufacturer, at a rate sufficient to provide a finished thickness of not less than 1.5 mils and an average thickness of 2.0 mils.

2.05 SHOP COATING – HOT-DIPPED GALVANIZED

- A. Hot dip galvanize steel members as noted on drawings complying with ASTM A123/123M
- B. Preparation: all material shall be clean and finished by filing and grinding so that it may be installed without additional finish work. Follow also ASTM A143/A143M, ASTM 384/A394M and ASTM A385.
- C. Finish to be continuous, smooth and uniform and in compliance with ASTM A 123/A123M.
- D. Protect finish.

2.06 SHOP QUALITY CONTROL

- A. Testing and Inspection:
 - 1. General: Provide access to testing and inspection agency so that specified testing and inspection can be safely accomplished.
 - 2. Shop bolted connections: Comply with testing and verification procedures in AISC "Specification for Structural Joints Using ASTM A325 or A490 Bolts."
 - 3. Shop welded connections: Inspect and test shop-fabricated welds as follows:
 - a. Visually inspect all welds.

PART 3 - EXECUTION

3.01 ERECTION

- A. General: Erect structural steel in compliance with AISC Code and Specifications.
- B. Assembly:
 - 1. Set structural members accurately to locations and elevations indicated, within tolerances established in AISC Code, before making final connections.

2. Do not use thermal cutting to correct fabrication errors on any major structural member.
- C. Columns and Bearing Surfaces:
 1. Clean bearing and contact surfaces before assembly. Slightly roughen concrete and masonry surfaces to improve bond.
 2. Set base and bearing plates accurately, using metal wedges, shims, or setting nuts as required.
 3. After tightening anchor bolts and ensuring that structure is plumb, grout solidly between plates and bearing surfaces.
- D. Bolting:
 1. Carbon steel bolts: Use only for temporary bracing during erection, unless otherwise specifically permitted by contract documents.
 2. High-strength bolts: Comply with requirements of AISC "Specification for Structural Joints Using ASTM A325 or A490 Bolts."
- E. Welding:
 1. Perform field welding in accordance with AWS "Structural Welding Code - Steel."
 2. Tighten and leave in place erection bolts used in field-welded construction.

3.02 FIELD QUALITY CONTROL

- A. Testing and Inspection:
 1. General: Provide access to testing and inspection agency so that specified testing and inspection can be safely accomplished.
 2. Field-bolted connections: Comply with testing and verification procedures in AISC "Specification for Structural Joints Using ASTM A325 or A490 Bolts."
 3. Field-welded connections: Inspect and test field-fabricated welds as follows:
 - a. Visually inspect all field welds.

END OF SECTION 05120

Brunswick County (US17) Rest Area Renovations

This page left blank intentionally.

SECTION 06100 - ROUGH CARPENTRY

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Rough carpentry for:
 - a. Wood framing and sheathing for the renovation of the existing rest area.
 - b. Miscellaneous lumber for attachment and support of other work.
 - 2. Preservative treatment.

1.02 SUBMITTALS

- A. Product Data:
- B. Framing Connectors and Supports: Submit manufacturer's standard data demonstrating compliance with building code requirements.
- C. Treated Wood: Treating plant's instructions for use, including storage, cutting, and finishing.
 - 1. Pressure preservative treatment: Treating plant's certification of compliance with specified standards and stating process employed and preservative retention values.
 - a. Treatment for above-ground use: Certification of kiln drying after treatment.

1.03 QUALITY ASSURANCE

- A. Inspection Agencies:
 - 1. SPIB: Southern Pine Inspection Bureau; for all structural framing of roof joists and headers.

PART 2 – PRODUCTS

2.01 DIMENSION LUMBER

- A. Size: Provide nominal sizes indicated, complying with NIST PS 20 except where actual sizes are specifically required. Provide continuous members; splicing is not acceptable.
 - 1. Surfacing: Dressed lumber (S4S).
 - 2. Moisture content: Kiln-dry or MC15 (15 percent maximum moisture content).
- C. Joist and Small Beam Framing -- 2 x 6 through 2 x 12:
 - 1. Species: Spruce-Pine-Fir (SPF), Grade: No. 2.
- D. Miscellaneous Lumber: Provide dimension lumber and boards necessary for the support of work specified in other sections, whether or not specifically indicated, and including but not limited to blocking, nailers, etc.
 - 1. Lumber: S4S, No. 2 or better, 15 percent maximum (kiln-dry).

2.02 CONSTRUCTION PANELS

- 2. A. Roof Sheathing: Oriented Strand Board sheathing: APA Rated, OSB Structural Panels, Exposure 1 (exterior glue), PS-2 or APA PRP-108 performance standards, 40/20 APA rated, and 5/8" thick.
- B. Wall Sheathing: Oriented Strand Board (OSB), square edged, APA Rated (exterior glue) sheathing panels with nailing pattern recommended by the manufacturer for shear walls, and nominal 1/2" thick.

2.03 MISCELLANEOUS MATERIALS

- A. Fasteners: Provide as required by applicable codes and as otherwise indicated.
 - 1. Provide fasteners with a hot-dip zinc coating (ASTM A 153) for treated lumber and where wood is in ground contact, subjected to high relative humidity, or exposed to weather.
- B. Framing Connectors and Supports: Prefabricated, formed steel units; hot-dip galvanized finish unless otherwise indicated; type and size as required; approved by applicable codes.
 - 1. The following manufacturer's products, or approved equal, provided they comply the the requirements of the contract documents, will be among those considered acceptable:

- a. Cleveland Steel Specialty Company.
- b. Simpson Strong-Tie Company.
- c. United Steel Products (USP) Company.
- C. Saturated Building Felt (30#)
- D. Sill Sealer Gaskets: Glass fiber insulation strips; uncompressed thickness, 1 inch (1/32 inch compressed); width to match sill members.

2.04 WOOD TREATMENT BY PRESSURE PROCESS

- A. Aboveground Lumber: AWPB LP-2 (waterborne preservatives).
 - 1. Kiln dried after treatment to 19 percent maximum moisture content.
 - 2. Treat the following:
 - a. Wood in contact with masonry or concrete.
 - b. Sill plate.
 - c. Other members indicated.
- B. Fasteners for Preservative Treated Wood: Hot-dip galvanized steel (ASTM A153).

PART 3 - EXECUTION

3.01 INSTALLATION - GENERAL

- A. Arrange work to use full length pieces except where lengths would exceed commercially available lengths. Discard pieces with defects that would lower the required strength or appearance of the work.
- B. Cut and fit members accurately. Install plumb and true to line and level.
- C. Fasten carpentry in accordance with applicable codes and recognized standards.
- D. Where exposed, countersink nails and fill flush with suitable wood filler.

3.02 MISCELLANEOUS CARPENTRY

- A. Provide miscellaneous blocking, nailers, grounds, and framing as shown and as required for support of facing materials, fixtures, specialty items, and trim. Cut and shape to the required size. Provide in locations required by other work.
- B. Use countersunk fasteners appropriate to applied loading.

3.03 WOOD FRAMING - GENERAL

- A. Comply with sizes, spacing, and configurations indicated. Where not specifically indicated, comply with applicable codes and NFPA "Manual for Wood Frame Construction." Splice members only where specifically indicated or approved.
- B. Space fasteners as indicated. Where not specifically indicated, comply with applicable codes and the "Recommended Nailing Schedule" of NFPA "Manual for Wood Frame Construction" and "National Design Specification for Wood Construction."

3.04 INSTALLATION OF CONSTRUCTION PANELS

- A. Employ the following fastening methods:
 - 1. Nail roof and wall sheathing to framing.
 - a. Provide solid blocking under panel edges other than intact tongue and groove edges.

3.05 AIR INFILTRATION BARRIER

- A. Install air infiltration barrier in accordance with manufacturer's instructions.

END OF SECTION 06100

SECTION 061516 - WOOD ROOF DECKING

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes **solid-sawn** wood roof decking

1.2 INFORMATIONAL SUBMITTALS

- A. Research/Evaluation Reports: For glued-laminated wood roof decking indicated to be of diaphragm design and construction, from ICC-ES.

PART 2 - PRODUCTS

2.1 WOOD ROOF DECKING, GENERAL

- A. General: Comply with DOC PS 20 and with applicable grading rules of inspection agencies certified by ALSC's Board of Review.

2.2 SOLID-SAWN WOOD ROOF DECKING

- A. Roof Decking Species: **Southern pine**.
- B. Roof Decking Nominal Size: **2 by 6**.
- C. Roof Decking Grade: **Select Decking**.
- D. Grade Stamps: Factory mark each item with grade stamp of grading agency. Apply grade stamp to surfaces that are not exposed to view.
- E. Moisture Content: Provide wood roof decking with **15** percent maximum moisture content at time of dressing.
- F. Face Surface: **Smooth**.
- G. Edge Pattern: Tongue & groove.

2.3 ACCESSORY MATERIALS

- A. Fastener Material: Hot-dip galvanized steel.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install solid-sawn wood roof decking to comply with AITC 112. Tongu
 - 1. Locate end joints for **two-span continuous lay-up**.

3.2 PROTECTION

- A. Provide water-resistive barrier over roof decking as the Work progresses to protect roof decking until roofing is applied.

END OF SECTION 061516

Brunswick County (US17) Rest Area Renovations

This page left blank intentionally.

SECTION 061800 - GLUED-LAMINATED CONSTRUCTION

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Framing using structural glued-laminated timber.

1.2 INFORMATIONAL SUBMITTALS

- A. Certificates of Conformance: Issued by a qualified testing and inspecting agency indicating that structural glued-laminated timber complies with requirements in AITC A190.1.

1.3 QUALITY ASSURANCE

- A. Manufacturer Qualifications: An AITC- or APA-EWS-licensed firm [certified for chain of custody by an FSC-accredited certification body].

1.4 DELIVERY, STORAGE, AND HANDLING

- A. General: Comply with provisions in AITC 111.
- B. Individually wrap members using plastic-coated paper covering with water-resistant seams.

PART 2 - PRODUCTS

2.1 STRUCTURAL GLUED-LAMINATED TIMBER

- A. General: Provide structural glued-laminated timber that complies with AITC A190.1 and AITC 117 or research/evaluation reports acceptable to authorities having jurisdiction.
 - 1. Factory mark each piece of structural glued-laminated timber with AITC Quality Mark or APA-EWS trademark. Place mark on surfaces that are not exposed in the completed Work.
 - 2. Provide structural glued-laminated timber made with wet-use adhesive complying with AITC A190.1.
- B. Species and Grades for Structural Glued-Laminated Timber: Southern pine that complies with structural properties & combination symbols indicated.
- C. Species and Grades for Beams & Purlins:
 - 1. Species and Beam Stress Classification: As indicated on structural drawings.
- D. Appearance Grade: Architectural, complying with AITC 110.

2.2 TIMBER CONNECTORS

- A. Materials: Unless otherwise indicated, fabricate from the following materials:
 - 1. Hot-dip galvanize steel assemblies and fasteners after fabrication to comply with ASTM A123/A123M or ASTM A153/A153M.

2.3 PRESERVATIVE TREATMENT

- A. Preservative Treatment: Where preservative-treated structural glued-laminated timber is indicated, comply with AWPA U1, Use Category UC3B.
 - 1. Use preservative solution without water repellents or substances that might interfere with application of indicated finishes.

Brunswick County (US17) Rest Area Renovations

- a. Do not incise structural glued-laminated timber or wood used to produce structural glued-laminated timber.

2.4 MISCELLANEOUS MATERIALS

- A. End Sealer: Manufacturer's standard, transparent, colorless wood sealer that is effective in retarding the transmission of moisture at cross-grain cuts and is compatible with indicated finish.
- B. Penetrating Sealer: Manufacturer's standard, transparent, penetrating wood sealer that is compatible with indicated finish.

2.3 FABRICATION

- A. End-Cut Sealing: Immediately after end cutting each member to final length, apply a saturation coat of end sealer to ends and other cross-cut surfaces, keeping surfaces flood coated for not less than 10 minutes.
- B. Seal Coat: After fabricating, sanding, and end-coat sealing, apply a heavy saturation coat of penetrating sealer on surfaces of each unit.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. General: Erect structural glued-laminated timber true and plumb and with uniform, close-fitting joints. Provide temporary bracing to maintain lines and levels until permanent supporting members are in place.
 1. Handle and temporarily support glued-laminated timber to prevent surface damage, compression, and other effects that might interfere with indicated finish.

3.2 ADJUSTING

- A. Repair damaged surfaces after completing erection. Replace damaged structural glued-laminated timber if repairs are not approved by Architect.

3.3 PROTECTION

- A. Do not remove wrappings on individually wrapped members until they no longer serve a useful purpose, including protection from weather, sunlight, soiling, and damage from work of other trades.
 1. Slit underside of wrapping to prevent accumulation of moisture inside the wrapping.

END OF SECTION 061800

SECTION 06200 - FINISH CARPENTRY

PART 1 - GENERAL

1.01 SUMMARY

- A. Misc. trim
- B. Fiber-cement lap siding, siding panels, and trim see Section 07462.

1.02 SUBMITTALS

- A. Plastic Laminate:
 - 1. Product data.
 - 2. Samples for verification: 8- by 10-inch piece of each type, pattern, and color.
- B. Coordinate installation of woodwork with other work to avoid damage.

PART 2 - PRODUCTS

2.01 WOODWORK

- A. All Woodwork Finishes: As indicated on drawings.

2.02 WOOD MATERIALS

- A. Lumber: Species and grade as indicated; lumber ready for installation shall comply with WM 4, "General Requirements For Wood Molding," Wood Molding and Millwork Producers (WMMP).
 - 1. Specie(s):
 - a. "Pine": Plain sawn Spruce or Idaho white pine at window extensions and window trim
 - 2. Softwood: Comply with NIST PS 20 and grade in accordance with the grading rules of the grading and inspection agency applicable to the species.
 - 3. For transparent finish, use only solid pieces of lumber; WM 4 N-grade.
 - 4. For opaque finish, pieces which are glued up may be used; WM 4 N- or P-grade.
 - 5. Moisture content: Not greater than that required by applicable grading rules; provide kiln-dried lumber.
 - 6. Provide lumber dressed on all exposed faces, unless otherwise indicated.
 - 7. Do not use twisted, warped, bowed, or otherwise defective lumber.
 - 8. Sizes indicated are nominal, unless otherwise indicated.
 - 9. Do not mark or color lumber, except where such marking will be concealed in finish work.
- B. Plywood: Types, grades, and cores as indicated.
 - 1. Medium density overlaid plywood: NBS PS 1, Special Exterior MDO.
 - 1. Plywood in concealed locations: Comply with NBS PS 1, Grade C minimum.
- C. Finish hardwood:
 - 1. Specie(s):
 - a. Maple: FAS grade, for lobby trim
 - 2. For transparent finish, use only solid pieces of lumber.
 - 3. Moisture content: Not greater than that required by applicable grading rules; provide kiln-dried lumber.
 - 4. Provide lumber dressed on all exposed faces, unless otherwise indicated.
 - 5. Do not use twisted, warped, bowed, or otherwise defective lumber.
 - 6. Sizes indicated are nominal, unless otherwise indicated.
 - 7. Do not mark or color lumber, except where such marking will be concealed in finish work.

2.03 MELAMINE SHELVING:

- A. Shelving: 3/4" thick premium MDF, Medium Density Fiber boards

2.04 FABRICATION

- A. Fabricate in sizes and shapes indicated and using details indicated.
- B. Complete fabrication and assembly in shop.
 - 1. Ease edges of solid lumber members where indicated, using:
 - a. 1/16-inch radius for members 1 inch or less nominal thickness.
 - b. 1/8-inch radius for members more than 1 inch nominal thickness.
- C. Where woodwork is indicated to be field finished, sand smooth, fill nail holes, clean thoroughly, and otherwise prepare for finishing.
- D. Standing and Running Trim: Miter exposed ends of members to match profile.
 - 1. Rout out backs of flat members over 2 inches wide, unless ends are exposed.
 - 2. Kerf backs of flat members over 4 inches wide, except where ends are exposed.

PART 3 - EXECUTION

3.01 PREPARATION

- A. Verify that blocking and backings have been installed at appropriate locations for anchorage.

3.02 INSTALLATION – GENERAL

- A. Do not begin installation of interior woodwork until potentially damaging construction operations are complete in the installation area.
- B. Make joints neatly, with uniform appearance.
- C. Install woodwork in correct location, plumb and level, without rack or warp.
 - 1. Where adjoining surfaces are flush, install with maximum 1/16-inch offset.
 - 2. Where adjoining surfaces are separated by a reveal, install with maximum 1/8-inch offset.
- D. Cut woodwork precisely to fit.
- E. Secure woodwork to blocking or use anchors indicated.
 - 1. Where anchorage method is not indicated, conceal all fasteners where possible.
 - 2. Where exposed nailing is required or indicated, use finishing nails, countersink, and fill.
- F. Repair damaged and defective woodwork to eliminate visual and functional defects; where repair is not possible, replace woodwork.
- G. Standing and Running Trim: Use longest pieces available and as few joints as possible.
 - 1. Stagger joints in built-up trim members. Miter all vertical joints tight at 45 degrees at interior T&G Cedar wall siding and fascia corners. Miter external and miter internal corners.
 - 2. Use diagonal (scarfed) joints in lengths of trim.
 - 3. Cope or miter at inside corners and miter at outside corners; fit tightly.
 - 4. Allowed variation in plumb and level: Not more than 1/8 inch in 8 feet.
 - 5. Install by blind-nailing where possible. Use face-nailing with fine finishing nails countersunk and filled at starter course only.
- H. Panel Type Paneling:
 - 1. Arrange panels for best appearance.
 - 2. Install with tight joints, unless otherwise indicated.
 - 1. Install by face-nailing with fine finishing nails countersunk and filled.

3.03 PROTECTION

Brunswick County (US17) Rest Area Renovations

- A. Protect woodwork from damage and maintain design environmental conditions.

END OF SECTION 06200

This page left blank intentionally.

SECTION 07130 - SHEET WATERPROOFING

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Self-adhering sheet waterproofing membranes.

1.2 RELATED SECTIONS

- A. Section 03300 - Concrete.
- B. Section 04220 - CMU.
- C. Section 06100 - Rough carpentry.
- D. Section 07210 - Thermal Insulation.

1.3 REFERENCES

- A. ASTM International:
 - 1. ASTM D 412 - Standard Test Methods for Vulcanized Rubber and Thermoplastic Rubbers and Thermoplastic Elastomers-Tension.
 - 2. ASTM D 779 - Standard Test Method for Water Resistance of Paper, Paperboard, and Other Sheet Materials by the Dry Indicator Method.
 - 3. ASTM D 882 - Standard Test Method for Tensile Properties of Thin Plastic Sheeting.
 - 4. ASTM D 1970 - Standard Specification for Self-Adhering Polymer Modified Bituminous Sheet Materials Used as Steep Roofing Underlayment for Ice Dam Protection.
 - 5. ASTM E 96 - Standard Test Methods for Water Vapor Transmission of Materials.
- B. International Code Council - Evaluation Service (ICC-ES):
 - 1. ICC-ES AC 38 - Acceptance Criteria for Water-Resistive Barriers.
 - 2. ICC-ES ESR 2783 - Evaluation Report.

1.4 SUBMITTALS

- A. Submit under provisions of Section 013300.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Installation methods.
- C. Shop Drawings: Submit shop drawings including details of construction and relationship with adjacent construction.
- D. Manufacturer's Certification: Submit manufacturer's certification that materials comply with specified requirements and are suitable for intended application.
- E. Warranty: Submit manufacturer's standard warranty.

1.5 QUALITY ASSURANCE

- A. Installer Qualifications: Experienced in installation of specified material type with working knowledge of specified products and Project specific application requirements.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Delivery: Deliver materials to site in manufacturer's original, unopened containers and packaging, with labels clearly identifying product name and manufacturer.
- B. Storage:
 - 1. Store materials in clean, dry, heated area indoors in accordance with manufacturer's instructions.
 - 2. Store cartons on end and protect from moisture and damage.
 - 3. Protect from temperatures above 100 degrees F (38 degrees C).
 - 4. Do not remove rolls from cartons until application.

1.7 PROJECT CONDITIONS

- A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's recommended limits.

1.8 WARRANTY

- A. Limited Warranty:
 - 1. Manufacturer warrants materials to be free from leaks caused by defects in material or manufacturing for a period of 5 years from the date of purchase when applied according to published directions.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturers:
 - 1. MFM Building Products Corp., Web: www.mfmbp.com
 - 2. W.R. Meadows, Inc., Web: www.wrmeadows.com
 - 3. Tamko Building Products, Inc., Web: www.tamko.com
- B. Requests for substitutions will be considered by Architect upon written request.

2.2 WATERPROOFING MEMBRANES

- A. Product: Underlayment
 - 1. Description: Prefabricated self-adhering sheet-type waterproofing membrane.
 - 2. Composition: High-tensile polyester film coated with a layer of specially formulated rubberized asphalt adhesive.
 - 3. Release Liners: Protect asphalt, removed as membrane is installed.
 - 4. Technical Properties:
 - a. Installation Temperature Range: Greater than 50 degrees F (10 degrees C).
 - b. Material Color: Black.
 - c. Material Thickness (ASTM D 1970): 40 Mils (1.0 mm) Nominal.
 - d. Flexibility at -20 degrees F (-29 degrees C) (ASTM D 1970): Pass.
 - e. Vapor Permeance (ASTM E 96): 0.08 g/m2 Maximum.
 - f. Nail Sealability (ASTM D 1970): Pass.
 - g. Tensile (ASTM D 412): 37 lbf/in2 (0.04 ksi).
 - h. Elongation (ASTM D 412): 135 percent Minimum.
- B. Product: Waterproofing membrane for basement walls.
 - 1. Description: Prefabricated, 40 mil (1 mm) self adhering sheet-type waterproofing membrane.
 - 2. Composition: Multi-layer high-strength polymer film that is coated with a layer of specially formulated rubberized asphalt adhesive.
 - 3. Release Liners: Protect asphalt, removed as membrane is installed.
 - 4. Technical Properties:
 - a. Tested to ICC-ES AC 38, ICC-ES ESR 2783.
 - b. Material Thickness (ASTM D 1970): 40 Mils (1.0 mm) Nominal.
 - c. Pliability (ICC-ES AC 38): Pass.
 - d. Vapor Permeance (ASTM E 96): 0.02 g/m2 Maximum.
 - e. Water Resistance (ASTM D 779): Greater than 30 hours
 - f. Nail Sealability (ASTM D 1970): Pass.
 - g. Tensile MD (ASTM D 882): 21 lbf/in2 (0.02 ksi).
 - h. Tensile CMD (ASTM D 882): 28 lbf/in2 (0.03 ksi).
 - i. Installation Temperature Range: Greater than 50 degrees F (10 degrees C).
 - j. Material Color: Black.

2.3 ACCESSORIES

- A. Adhesive: MFM Spray Adhesive as manufactured by MFM Building Products Corp.
- B. Primer: Asphalt-based commercial primer.
- C. Termination Bar.

PART 3 EXECUTION

3.1 EXAMINATION AND PREPARATION

- A. Inspect and prepare substrates using the methods recommended by the manufacturer for achieving best result for the substrates under project conditions.
- B. Clean surfaces thoroughly prior to installation. Do not proceed with installation until substrates have been prepared using the methods recommended by the manufacturer and deviations from manufacturer's recommended tolerances are corrected. Commencement of installation constitutes acceptance of conditions.
- C. If preparation is the responsibility of another installer, notify Architect in writing of deviations from manufacturer's recommended installation tolerances and conditions.

3.2 INSTALLATION

- A. Install in accordance with manufacturer's instructions including the following:
 - 1. Apply in clear, dry weather.
 - 2. Surface must be clean, dry and free from oil.
 - 3. Masonry must be clean, fully cured and primed with an asphalt primer.
 - 4. Prime weathered surfaces as necessary - clean, dry, wood and metal surfaces do not require priming.
 - 5. Use 3 inches (76 mm) side laps and 6 inches (152 mm) head laps.
 - 6. Apply uniform pressure with a 2 to 3 inches (51 to 76 mm) hand roller to entire surface.
 - 7. Do not install over solvent-based sealants unless fully cured - active solvents may liquefy bottom adhesive surface.
 - 8. Test for compatibility with caulks and sealants.
 - 9. Do not install over flexible vinyl gaskets.
 - 10. Do not expose installed product to direct sunlight for more than 90 days.

3.3 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Substantial Completion.

END OF SECTION 07130

THIS PAGE LEFT BLANK INTENTIONALLY.

SECTION 07210 - BUILDING INSULATION

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Extruded polystyrene board.
 - 2. Foamed in place insulation
 - 3. Fiberglass batt insulation

1.02 DEFINITIONS

- A. Thermal Resistance (R-value): The temperature difference in degrees F between the two surfaces of a material of given thickness, required to make 1 Btu of energy flow through 1 square foot of the material in 1 hour.

1.03 SUBMITTALS

- A. Product Data: Submit for each product specified in this section.

1.04 DELIVERY, STORAGE, AND HANDLING

- A. Foamed Plastic Insulation: Minimize period between product delivery and actual installation. Protect against exposure to flame, sparks, or excessive heat. Minimize exposure to sunlight.

1.05 REGULATORY REQUIREMENTS

- A. Conform to applicable code for concealment limitations.

1.06 FIELD CONDITIONS

- A. Do not apply foam when temperature is below that specified by the manufacturer for ambient air and substrate.
- B. Do not apply foam when temperature is within 5 F of dew point.

PART 2 - PRODUCTS

2.01 MATERIALS

- A. Provide manufacturer's standard preformed insulation units, sized for proper fit in indicated applications.
- B. Blanket/Batt Insulation: Where installation of blanket/batt insulation is indicated, glass fiber blanket/batt complying with requirements below.
- C. Extruded Polystyrene Board Insulation: Manufactured by extrusion process with integral high density skin:
 - 1. Type VII (ASTM C 578): 60.0 psi compressive strength.
 - 2. Total R-value: 5.
 - 3. Manufacturers: Products of the following manufacturers or approved equal, provided they comply with requirements of the contract documents, will be among those considered acceptable:
 - a. Amoco Foam Products Company.
 - b. Dow U.S.A.
 - c. DiversiFoam Products Company.
 - d. UC Industries, Inc.
- D. Foamed-In-Place Insulation: Medium-density, rigid or semi-rigid, closed cell polyurethane foam; foamed on-site, using blowing agent of water or non-ozone-depleting gas.

1. Aged Thermal Resistance (R-value): 6.5 (deg F hr sq ft)/Btu, minimum, when tested at 1 inch thickness in accordance with ASTM C518 after aging for 180 days at 41 degrees F.
2. Water Vapor Permeance: Vapor retarder; 1 perm, maximum, when tested at intended thickness in accordance with ASTM E96/E96M, desiccant method.
3. Water Absorption: Less than 2 percent by volume, maximum, when tested in accordance with ASTM D2842.
4. Air Permeance: 0.004 cfm/sq ft, maximum, when tested at intended thickness in accordance with ASTM E2178 at 1.5 psf.
5. Closed Cell Content: At least 90 percent.
6. Surface Burning Characteristics: Flame spread/Smoke developed index of 25/450, maximum, when tested in accordance with ASTM E84.

2.02 ACCESSORIES

- A. Provide accessories as necessary to properly install specified products.
Adhesive: Insulation manufacturer's recommended adhesive, complying with fire performance requirements.

PART 3 - EXECUTION

3.01 INSTALLATION

- A. Comply with insulation manufacturer's recommendations and installation sequence. Provide permanent placement and support of insulation.
- B. Install materials in a manner which will maximize continuity of thermal envelope. Use a single layer of insulation wherever possible to achieve indicated requirements, unless otherwise indicated.
- C. Insulation Boards:
 1. Extruded polystyrene insulation:
 - a. Foundation installation: Provide installation capable of sustaining subsequent construction work without damage or displacement.
 1. Adhesive: Use insulation manufacturer's recommended adhesive to attach insulation boards to foundation. Maximize contact between board surface and substrate.
 - b. Under-slab installation: Do not install insulation before compaction of subgrade is verified. Provide installation capable of sustaining subsequent construction work without damage or displacement.
- D. Insulation Blankets/Batts:
 1. Application: Wood-framed construction:
 - a. Unfaced insulation: Friction-fit insulation between framing members.
 - b. Support ceiling insulation with plastic mesh.
- E. Foamed-in-place insulations
 1. Apply insulation in accordance with manufacturer's instructions.
 2. Apply insulation by spray method, to a uniform monolithic density without voids.
 3. Apply to a minimum cured thickness of 3 at walls and 6 inch at ceilings/roofs.
 4. Patch damaged areas.
 5. Where applied to voids and gaps assure space for expansion to avoid pressure on adjacent materials that may bind operable parts.
 6. Trim excess away for applied trim or remove as required for continuous sealant bead.

3.02 PROTECTION

- A. Do not permit subsequent construction work to disturb applied insulation.

END OF SECTION 07210

SECTION 07250 - WEATHER BARRIER

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Sheet applied weather barrier and related accessories for wall air/moisture barrier system.

1.2 REFERENCES

- A. The American Association of Textile Chemists and Colorists (AATCC) 127 - Water Resistance: Hydrostatic Pressure Test.
- B. American Society for Testing and Materials (ASTM) E-96 - Standard Test Methods for Water Vapor Transmission of Materials.
- C. American Society for Testing and Materials (ASTM) D1117 - Standard Guide for Evaluating Nonwoven Fabrics.
- D. American Society for Testing and Materials (ASTM) D3330 - Standard Test Method for Peel Adhesion of Pressure-Sensitive Tape1.
- E. American Society for Testing and Materials (ASTM) D3759 - Standard Test Method for Tensile Strength and Elongation of Pressure-Sensitive Tapes.
- F. PSTC-1 - Peel Adhesion of Single Coated Pressure-Sensitive Tapes at 180 Degree Angle.
- G. TAPPI T-460 - Porosity - Gurley.

1.3 SYSTEM DESCRIPTION

- A. The airtight components and secondary moisture protection of the building enclosure and the joints, junctures and transitions between materials, products, and assemblies forming the air-tightness and moisture barrier of the building enclosure are called "the air/moisture barrier system". Services include coordination between the trades, the proper scheduling and sequencing of the work, preconstruction meetings, inspections, tests, and related actions, including reports performed by Contractor, by independent agencies, and by governing authorities. They do not include contract enforcement activities performed by the Architect.
- B. Air Barrier Penetrations: All penetrations of the air/moisture barrier and paths of air infiltration / exfiltration through the air/moisture barrier system shall be made air-tight.
- C. Moisture Barrier Penetrations: All penetrations of the air/moisture barrier and paths of water migration through the air/moisture barrier system shall be made water shedding.

1.4 SUBMITTALS

- A. Submit under provisions of Section 013300.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Installation methods.

1.5 QUALITY ASSURANCE

- A. Installer Qualifications: Minimum of 2 years experience with installation of similar products.

- B. Mock-Up: Provide a mock-up for evaluation of surface preparation and sealing techniques and application workmanship.
 - 1. Finish areas designated by Architect.
 - 2. Do not proceed with remaining work until workmanship is approved by Architect.
 - 3. Repair mock-up area as required to produce acceptable work.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Do not store in direct sunlight. Weather barrier shall be stored in a covered area. Do not expose to building site chemicals.
- C. Store and dispose of solvent-based materials, and materials used with solvent-based materials, in accordance with requirements of local authorities having jurisdiction.

1.7 PROJECT CONDITIONS

- A. Anticipate environmental conditions and schedule installation when conditions are within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.

1.8 WARRANTY

- A. Product Warranty: Limited product warranty against manufacturing defects.
 - 1. Weather Barrier and related products for 10 years.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturers:
 - 1. DuPont.
 - 2. James Hardie
 - 3. Henry
 - 4. Dow Corning
- B. Requests for approval of equal substitutions will be considered in accordance with provisions of Section 016000.

2.2 WEATHER BARRIER SYSTEM

- A. Moisture Air Barrier Sheet:
 - 1. Composition: Non-woven, non-perforated polyolefin.
 - 2. Film: MicroTech Coating with micropores to balance water holdout and breathability.
 - 3. Thickness: 11 mil (0.28 mm).
 - 4. UV Stability: Up to 180 days.
 - 5. Water Holdout (AATCC127): 128 inches (3250 mm).
 - 6. Breathability/Water Vapor Permeance (ASTM E-96A): 15 perms.
 - 7. Air Resistance (TAPPI T-460): >1800 sec/100 cc.
 - 8. Tear Strength (ASTM D1117): 15 to 18 lb (6.8 to 8.2 kg).
 - 9. Basis Weight: 19.4 lbs/1000 sf (9.5 kgs/100 sm).
- B. Self-adhering Flashing: Designed for peel and stick application.
 - 1. Composition: Butyl rubber adhesive non-woven polyolefin backing; coated Kraft paper release.
 - 2. Total Thickness: 25 mil (0.64 mm).

3. UV Stability: Up to 180 days.
 4. Application Temperature: 30 degree F to 180 degree F (-1 degree C to 82 degree C).
 5. Operating Temperature: -30 degree F to 200 degree F (-34 degree C to 93 degree C).
 6. Packaging: Individually shrink-wrapped.
 7. Roll Weight: 4 inch (102 mm) = 4.6 lb (2 kg)/roll, 6 inches (152 mm) = 6.9 lb (3 kg) /roll, 9 inches (229 mm) = 9.9 lb (4.5 kg)/roll.
 8. Provide Width for Application Required: 4 inches by 100 feet (102 mm by 30.5 m) (2x4 construction), 6 inches by 100 feet (152 mm by 30.5 m) (2x4 construction), 9 inches by 100 feet (229 mm by 30.5) (2x6 construction).
- C. Flexible Flashing:
1. Composition: Butyl rubber adhesive; creped cross-laminated polyolefin backing; polyethylene film release.
 2. Total Thickness: 60 mil (1.5 mm).
 3. Tensile Strength (ASTM D3759): 18 lb/inch (3.2kg/cm).
 4. UV Stability: Up to 180 days.
 5. Water Vapor Transfer Rate (≈STM E96-94): <.2g/100 square inches/24hrs.
 6. Application Temperature: 30 degree F to 180 degree F (-1 degree C to 82 degree C).
 7. Operating Temperature: -30 degree F to 200 degree F (-34 degree C to 93 degree C).
 8. Packaging: Each roll is packed in a convenient dispenser box
 9. Roll Weight: 6 inches (152 mm) = 22.2 lb (10kg)/roll, 9 inches (229 mm) = 33.3 lb (15 kg)/roll.
 10. Provide Width for Application Required: 6 inches by 75 feet (152 mm by 23.9 m) (2x4 construction), 9 inches by 75 feet (229 mm by 23.9) (2x6 construction).
- D. Seam Tape:
1. Composition: Polypropylene film coated with acrylic adhesive Total Thickness: 3.0 mil (.08 mm).
 2. Adhesion Peel to HardieWrap (PSTC-1): 22 oz/inch (25 N/100 mm).
 3. Tensile Strength (ASTM D3759): 32 lb/in (.58 kg/mm).
 4. Elongation: 136 percent.
 5. UV Stability: Up to 90 days.
 6. Application Temperature: 30 degree F to 180 degree F (-1 degree C to 82 degree C).
 7. Operating Temperature: -30 degree F to 200 degree F (-34 degree C to 93 degree C).
 8. Packaging: Individually shrink-wrapped.
 9. Roll Weight: 1 lb(0.5 kg)/roll.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Do not begin installation until substrates have been properly prepared.
- B. If framing preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.
- C. Weather barrier shall be installed before window and door installation. Do not install on

saturated sheathing. Weather barrier can become slippery and should not be used in any application where it may be walked on.

- D. Weather barrier shall be installed on vertical wall applications only.
- E. Manufacturer warrants weather barrier sheet only when covered within 180 days of its installation.

3.3 INSTALLATION

- A. Moisture Air Barrier Sheet:
 - 1. Weather barrier shall be installed before window and door installation. Do not install on saturated sheathing. Weather barrier can become slippery and should not be used in any application where it may be walked on.
 - 2. Begin by affixing weather barrier extending at least 6 inches (152 mm) around a building corner. Unroll horizontally (with print side facing out) around the building covering rough window and door openings.
 - 3. Fasten to studs or nailable sheathing material with galvanized construction grade staples a maximum of 18 inches (457 mm) in the vertical and horizontal direction.
 - 4. Attach weather barrier so that it is taut and flat. The vertical overlap shall have a minimum of 6 inches (152 mm) and the vertical seam shall be taped.
 - 5. Assure that the bottom edge of the weather barrier extends over the sill plate and foundation interface by at least 1 inch (25 mm).
 - 6. Overlap upper layers of weather barrier (in shingle lap fashion) by a minimum of 6 inches below the horizontal edge, and tape the horizontal seam line.
 - 7. At roof to wall intersection (or wall to deck), affix wrap to the wall such that it overlaps any step flashing already in place on the wall by at least 2 inches (51 mm).
- B. Flexible Flashing:
 - 1. Windows and Doors: Weather barrier is not designed nor guaranteed as a flashing material to prevent moisture or air from intruding behind weather barrier. Verify that flashing has previously been installed around all windows and door openings. Install flexible flashing per manufacturer's instructions.
 - a. Use the inverted "Y" cut method at rough window and door openings. Do not place fasteners within 9 inches (229 mm) of the rough opening, door or window heads. This area shall not be fastened to allow for proper head flashing installation. At the top corners of the rough opening, cut the weather barrier at 45 degree to extend 9 inches (229 mm) past the joint.
 - b. Fold the top flap up and out of the way and fasten temporarily.
 - c. Fold the remaining three flaps in through the opening fastening them inside the opening with staples.
 - 2. Rough Electrical and Plumbing Penetrations: Seal with a double layer of flashing. Install the top flashing piece over the bottom flashing piece overlapping flashing layers to cover flashing cut-out necessary for placement around penetration.
- C. Repairs: For minor punctures or tears, less than 3 inches (76 mm), cover and completely seal with seam tape. For larger holes, greater than 3 inches (76 mm), use slit flashing technique.
 - a. Slit flashing requires making a horizontal slit above the damaged area and placing a cut piece of weather barrier into the slit, covering the damaged area. Tape the perimeter of the patched area.

3.4 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Substantial Completion.

END OF SECTION 07250

SECTION 072600 - UNDER-SLAB VAPOR BARRIER

PART 1 – GENERAL

1.1 SUMMARY

- A. Products supplied under this section:
 - 1. Vapor barrier and installation accessories for installation under concrete slabs.
- B. Related sections:
 - 1. Section 03 30 00 Cast-in-Place Concrete

1.2 REFERENCES

- A. American Society for Testing and Materials (ASTM):
 - 1. ASTM E 1745- 11 Standard Specification for Plastic Water Vapor Retarders Used in Contact with Soil or Granular Fill Under Concrete Slabs.
 - 2. ASTM E 154- 08 Standard Test Methods for Water Vapor Retarders Used in Contact with Earth Under Concrete Slabs, on Walls, or as Ground Cover.
 - 3. ASTM F 1249-06 (2011) Standard Test Method for Water Vapor Transmission Rate Through Plastic Film and Sheeting Using a Modulated Infrared Sensor.
 - 4. ASTM D 882-10 Standard Test Method for Tensile Properties of Thin Plastic Sheeting.
 - 5. ASTM D 1709-09 Standard Test Methods for Impact Resistance of Plastic Film by the Free-Falling Dart Method.
 - 6. ASTM E 1643- 11 Selection, Design, Installation, and Inspection of Water Vapor Retarders Used in Contact with Earth or Granular Fill Under Concrete Slabs.
- B. American Concrete Institute (ACI):
 - 1. ACI 302.2R-06 Guide for Concrete Slabs that Receive Moisture-Sensitive Flooring Materials.

1.3 SUBMITTALS

- A. Quality control/assurance:
 - 1. Summary of test results per paragraph 9.3 of ASTM E 1745.
 - 2. Manufacturer's samples and literature.
 - 3. Manufacturer's installation instructions for placement, seaming and penetration repair instructions.

PART 2 – PRODUCTS

2.1 MATERIALS

- A. Vapor barrier shall have all of the following qualities:
 - 1. Maintain permeance of less than 0.01 Perms [grains/(ft² · hr · inHg)] as tested after conditioning tests per ASTM E 1745 Section 7.1.
 - 2. Other performance criteria:
 - a. Strength: ASTM E 1745 Class A.
 - b. Thickness: 15 mils minimum
- B. Acceptable Manf.:
 - 1. Stego Industries LLC.
 - 2. CertainTeed
 - 3. WR Meadows.
 - 4. Or approved equal

2.2 ACCESSORIES

- A. Seams : to be taped per manf. recommended product
- B. Penetrations of Vapor barrier: use tape or mastic per manf. recommended product
- C. Perimeter/edge seal: per manf. recommended product
- D. Term Bar per manf. recommended product.

PART 3 – EXECUTION

3.1 PREPARATION

- A. Ensure that subsoil is approved by Architect or Geotechnical Engineer.
 - 1. Level and compact base material.

3.2 INSTALLATION

- A. Install vapor barrier in accordance ASTM E 1643.
 - 1. Unroll vapor barrier with the longest dimension parallel with the direction of the concrete placement and face laps away from the expected direction of the placement whenever possible.
 - 2. Extend vapor barrier over footings and grade beams to a distance acceptable to the structural engineer or stop at impediments such as dowels and waterstops.
 - 3. Seal vapor barrier to foundation wall or footing/grade beam with tape, termination bar, or a combination of both.
 - 4. Overlap joints 6 inches and seal with manufacturer's tape.
 - 5. Apply tape/sealant to a clean and dry vapor barrier.
 - 6. Seal all penetrations (including pipes) per manufacturer's instructions.
 - 7. No penetration of the vapor barrier is allowed except for reinforcing steel and permanent utilities.
 - 8. Repair damaged areas by cutting patches of vapor barrier, overlapping damaged area 6 inches and taping all sides with tape.

END OF SECTION

SECTION 07310 - ASPHALT SHINGLES

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Asphalt roofing shingles.
- B. Leak barrier and moisture shedding roof deck protection.
- C. Underlayment.
- D. Metal flashing associated with shingle roofing.

1.2 RELATED SECTIONS

- A. Section 06 10 00 - Rough Carpentry.

1.3 REFERENCES

- A. American Society of Civil Engineers (ASCE): ASCE 7 - Minimum Design Loads for Buildings and Other Structures.
- B. Asphalt Roofing Manufacturers Association (ARMA).
- C. ASTM International (ASTM):
 - 1. ASTM D 3018 - Standard Specification for Class A Asphalt Shingles Surfaced with Mineral Granules.
 - 2. ASTM D 7158 - Standard Test Method for Wind-Resistance of Asphalt Shingles (uplift Force/Uplift Resistance method)
 - 3. ASTM D 3462 - Standard Specification for Asphalt Shingles Made from Glass Felt and Surfaced with Mineral Granules.
 - 4. ASTM A 653/A 653M - Standard Specification for Steel Sheet, Zinc Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
 - 5. ASTM B 209 - Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate.
 - 6. ASTM B 370 - Standard Specification for Copper Sheet and Strip for Building Construction.
 - 7. ASTM D 4586 - Standard Specification for Asphalt Roof Cement, Asbestos-Free.
- D. National Roofing Contractors Association (NRCA).
- E. Sheet Metal and Air Conditioning Contractors National Association, 1nc. (SMACNA) - Architectural Sheet Metal Manual.
- F. Underwriters Laboratory (UL)
 - 1. UL 790 - Tests for Fire Resistance of Roof Covering Materials.
 - 2. UL 997 - Wind Resistance of Prepared Roof Covering Materials.

1.4 DEFINITIONS

- A. Roofing Terminology: Refer to ASTM D1079 and the glossary of the National Roofing Contractors Association (NRCA) Roofing and Waterproofing Manual for definitions of roofing terms related to this section.

1.5 SUBMITTALS

- A. Submit under provisions of Section 01 30 00 - Administrative Requirements.
- B. Product Data: Manufacturer's data sheets on each product to be used, showing compliance

with requirements.

- C. Installation Instructions: Manufacturer's installation instructions, showing required preparation and installation procedures.

1.6 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Provide all primary roofing products, including shingles, underlayment, leak barrier, and ventilation, by a single manufacturer.
- B. Installer Qualifications: Installer must be approved by manufacturer for installation of all roofing products to be installed under this section.

1.7 REGULATORY REQUIREMENTS

- A. Provide a roofing system achieving an Underwriters Laboratories (UL) Class A fire classification.
- B. Install all roofing products in accordance with all federal, state and local building codes.
- C. All work shall be performed in a manner consistent with current OSHA guidelines.

1.8 PRE-INSTALLATION MEETINGS

- A. Convene a pre-installation meeting a minimum two weeks prior to starting work of this section.
 - 1. Contractor shall schedule and arrange meeting and meeting place and notify attendees.
 - 2. Mandatory Attendees: Roofing installer and manufacturer's steep slope technical representative (not sales agent).
 - 3. Optional Attendees: Owner's representative, Architect's representative, prime Contractor's representative.
 - 4. Review all pertinent requirements for achieving the warranty specified below and set schedule for final warranty inspection.

1.9 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened labeled packaging until ready for installation.
- B. Store products in a covered, ventilated area, at temperature not more than 110 degrees F; do not store near steam pipes, radiators, or in sunlight.
- C. Store bundles on flat surface to maximum height recommended by manufacturer; store rolls on end.
- D. Store and dispose of solvent-based materials, in accordance with requirements of local authorities having jurisdiction.

1.10 WEATHER CONDITIONS

- A. Proceed with work only when existing and forecasted weather conditions will permit work to be performed in accordance with roofing shingle manufacturer's recommendations.

1.11 WARRANTY

- A. Provide manufacturer's standard limited warranty:
 - 1. Provide to the Owner the manufacturer's warranty.
 - a. Warranty Duration: 25 years.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturers: CertainTeed, John Mansville, GAF or approved equal

2.2 SHINGLES

- A. Architectural Shingles:
 1. Granule surfaced, self-sealing asphalt shingle with a strong fiberglass reinforced Micro Weave core and StainGuard protection, which prevents pronounced discoloration from blue-green algae through formulation/unique blends of granules.
 2. Extra thick tabs and bold profile provide a bold unique appearance with a 7.5in. exposure.
 3. Reinforced strip to help prevent nail pull thru.
 4. UL 790 Class A rated with UL 997 Wind Resistance Label; ASTM D 7158, Class H; ASTM D 3161, Type 1; ASTM D 3018, Type 1; ASTM D 3462; AC438 compliant; CSA 123.5-98; Dade County Approved, Florida Building Code Approved, Texas Dept of Insurance Approved, ICC Report Approval.

2.3 HIP AND RIDGE SHINGLES

- A. Distinctive self-sealing hip and ridge cap shingle complementing the color of selected roof shingle.

2.4 STARTER STRIPS

- A. Self sealing starter shingle designed for premium roof shingles.

2.5 LEAK BARRIER

- A. Self-adhering, self-sealing, bituminous leak barrier surfaced with fine, skid-resistant granules. Approved by UL and ICC.

2.6 UNDERLAYMENT

- A. Premium, water repellent, breather type non-asphaltic underlayment. UV stabilized polypropylene construction. Meets or exceeds ASTM D226 and D4869. Approved by ICC.

2.7 ROOFING CEMENT

- A. Asphalt Plastic Roofing Cement meeting the requirements of ASTM D 4586, Type I or II.

2.8 ROOF ACCESSORIES

- A. Paint: Exterior acrylic rust resistant aerosol roof accessory paint. Each 6 oz can is available in boxes of 6 and in color to compliment the roof. Shingle-Match Roof Accessory Paint by GAF.
- B. Compression Collars: UV stable solid molded PVC compression collar, Kynar PVDF coated

24 gauge galvanized flange, Ultimate Pipe Flashing by Lifetime Tool.

2.9 VENTILATION

- A. Ridge Vents:
 - 1. Flexible rigid plastic ridge ventilator designed to allow the passage of hot air from vented insulation panels, while resisting snow infiltration.

2.10 NAILS

- A. Nails: Standard round wire, zinc-coated steel or aluminum; 10 to 12 gauge, smooth, barbed or deformed shank, with heads 3/8 inch (9mm) to 7/16 inch (11mm) in diameter. Length must be sufficient to penetrate into solid wood at least 3/4 inch (19mm) or through plywood or oriented strand board by at least 1/8 inch (3.18mm). Nails shall not penetrate thru to interior of finished wood decking.

2.11 METAL FLASHING

- A. Aluminum: 0.032-inch (0.8mm) aluminum sheet, complying with ASTM B 209.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Do not begin installation until roof deck has been properly prepared.
- B. If roof deck preparation is the responsibility of another installer, notify Architect or building owner of unsatisfactory preparation before proceeding.

3.2 PREPARATION OF SUBSTRATE

- A. Clean deck surfaces thoroughly prior to installation of leak barrier and roof deck protection.
- B. At areas to receive leak barrier, fill knot holes and cracks with latex filler.

3.3 INSTALLATION OF UNDERLAYMENT

- A. Install using methods recommended by manufacturer in accordance with local building code. When local codes and application instructions are in conflict, the more stringent requirements shall take precedence.
- B. Eaves:
 - 1. Place eave edge metal flashing tight with fascia boards; lap joints 2 inches and seal with plastic cement; nail at top of flange.
 - 2. On roofs with slope between 2:12 and 4:12, install leak barrier up the slope from eave edge to 36 inches from the edge or at least 24 inches beyond the interior face of the warm exterior wall, whichever is greater; lap ends 6 inches and bond.
- C. Valleys:
 - 1. Install leak barrier at least 36 inches wide centered on valley; lap ends 6 inches and seal.
 - 2. Where valleys are indicated to be "open valleys", install metal flashing over leak barrier before roof deck protection is installed; DO NOT NAIL THROUGH metal flashing; secure by nailing at 18 inches on center just beyond edge of flashing so that nail heads hold down edge.

- D. Hips and Ridges:
 - 1. Install leak barrier along entire lengths. If ridge vents are to be installed, position the leak barrier so that the ridge slots will not be covered.
- E. Roof Deck:
 - 1. Install one layer of roof deck protection over entire area not protected by eave or valley membrane; run sheets horizontally lapped so water sheds; nail in place.
 - 2. On roofs sloped at more than 4 in 12, lap horizontal edges at least 2 inches and at least 2 inches over eave protection membrane.
 - 3. On roofs sloped between 2 in 12 and 4 in 12, lap horizontal edges at least 19 inches and at least 19 inches over eave protection membrane.
 - 4. Lap ends at least 4 inches; stagger end laps of each layer at least 36 inches.
 - 5. Lap roof deck protection over valley protection at least 6 inches
- F. Penetrations:
 - 1. At vent pipes, install a 24 inch square piece of leak barrier lapping over roof deck protection; seal tightly to pipe.
 - 2. At vertical walls, install leak barrier extending at least 6 inches up the wall and 12 inches on to the roof surface lapping over roof deck protection.
 - 3. At rake edges, install metal edge flashing over leak barrier and roof deck protection; set tight to rake boards; lap joints at least 2 inches and seal with plastic cement; secure with nails.
 - 4. At hips and ridges, install leak barrier along entire lengths. If ridge vents are to be installed, position the leak barrier so that the ridge slots are not covered.

3.4 INSTALLATION OF SHINGLES

- A. Install in accordance with manufacturer's instructions and requirements of local building code.
 - 1. Avoid breakage of shingles by avoiding dropping bundles on edge, by separating shingles carefully (not by "breaking" over ridge or bundles), and by taking extra precautions in temperatures below 40 degrees F.
 - 2. Handle carefully in hot weather to avoid damaging shingle edges.
 - 3. Secure with 4 to 6 nails per shingle; use number of nails required by manufacturer or by code, whichever is greater. Nails must be long enough to penetrate through plywood or OSB, or 3/4 inch into dimensional lumber.
- B. Install hip and ridge shingles as required by the manufacturer. At ridges, install hip and ridge shingles over ridge or ridge vent material.
- C. Make valleys using "woven valley" technique.
 - 1. Run shingles from both roof slopes at least 12 inches (305 mm) across center of valley, lapping alternate sides in a woven pattern.
 - 2. Nail not closer than 6 inches (150 mm) to center of valley.
- D. All penetrations are to be flashed according to manufacturer, ARMA and NRCA application instructions and construction details.

3.5 INSTALLATION OF VENTILATION

- A. Code Requirements: Ventilation shall meet or exceed current FHA, HUD and local code requirements.
- B. Ridge Vents:
 - 1. Cut continuous vent slot through sheathing, stopping 6 inches (150 mm) from each end of ridge.
 - 2. On roofs without ridge board, make slot 2 inches (50 mm) wide, centered on ridge.
 - 3. On roofs with ridge board, make two slots 1-3/4 inches (89 mm) wide, one on each side.

4. Install ridge vent material full length of ridge, including uncut areas.
5. Butt ends of lengths of ridge vent material and join using plastic cement.
6. Install eave vents in sufficient quantity to equal or exceed the ridge vent area, calculated as specified by manufacturer.
7. Install ridge shingles over ridge vent material; use nails of specified length; do not drive nails home, leaving 3/4 inch (19 mm) slot open between ridge and roof shingles.

3.6 PROTECTION

- A. Stage work progress so that traffic is minimized over completed roofing.
- B. Protect installed products until completion of project

END OF SECTION

SECTION 07463 - VINYL SIDING AND SOFFITS

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Polymer siding.
- B. Vinyl soffits.
- C. Trim and accessories.

1.2 RELATED SECTIONS

- A. Section 06 10 00 - Rough Carpentry: Framing and sheathing.
- B. Section 07 90 00 - Joint Protection.

1.3 REFERENCES

- A. ASTM D 5206 - Standard Windload Resistance Test.
- B. ASTM E 84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- C. ASTM E 119 - Standard Test Methods for Fire Tests of Building Construction and Materials.
- D. ASTM D7254 – Standard Specification for Polypropylene (PP) Siding

1.4 SUBMITTALS

- A. Submit under provisions of Section 01 30 00.
- B. Samples: Siding/soffit design, size, and color for approval.
- C. Manufacturer's installation instructions.
- D. Certificate: Manufacturer's certification that siding/soffit as supplied meets or exceeds the conditions specified herein.

1.5 QUALITY ASSURANCE

- A. Manufacturer: Maintain rigorous production quality control standards to ensure that vinyl siding and soffit will perform as expected for its intended use.
- B. Regulatory Requirements:
 - 1. National Building Code - BOCA Research No. 93-42.
 - 2. Standard Building Code - SBCCI Compliance Report No. 9632.
 - 3. Uniform Building Code - ICBO Evaluation Report No. 3663.
 - 4. Underwriters Laboratories Listing R14214.
 - 5. ICC - ESR-1258, ESR 1133.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Pack siding and soffits two squares per carton and clearly mark each carton with manufacturer's name, siding style, color, identifying lot number, and VSI Certification Stamp.
- C. Store vinyl siding, soffits, and accessories in clean, dry area, out of direct sunlight.
- D. Handle material to prevent damage. Do not allow cartons to crease.

1.7 WARRANTY

- A. Upon completion, provide a written transferable, lifetime limited warranty.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturers: Certainteed, Royal Building Products, Boral or approved equal.
- B. Requests for substitutions will be considered in accordance with provisions of Section 01600.

2.2 MATERIALS

- A. Siding and Soffits - General Requirements: Produced from polyvinyl chloride (PVC) compounds meeting ASTM D 3679 requirements for compound class number 2.
 - 1. Vinyl Siding Institute Certified.
 - 2. Average Impact Strength: 3.86 ft. lbs./in. of notch at 73.4 degrees F, per ASTM D 256.
 - 3. Tensile Strength: 6,700 psi (46,195 kPa), per ASTM D 638.
 - 4. Modulus of Elasticity: 410,000 psi (2,826,850 kPa), per ASTM D 638.
 - 5. Deflection Temperature: 170 degrees F (77 degrees C), per ASTM D 648.
 - 6. Fire Properties:
 - a. Average Time of Burning: Less than 5 seconds, when tested in accordance with ASTM D 635.
 - b. Average Extent of Burning: Less than 5 mm, when tested in accordance with ASTM D 635.
 - c. Flame Spread Index: 20 (Class A), when tested in accordance with ASTM E 84.
 - d. Smoke Developed Index: Less than 450, when tested in accordance with ASTM E 84.
 - e. Ignition Temperature: When tested in accordance with ASTM D 1929, no self ignition and no flaming; no smoldering at less than 680 degrees F (360 degrees C).
 - 7. Typical Siding Properties:
 - a. Camber: meet all requirements for camber per ASTM D 3679.
 - b. Heat Shrinkage: meet all requirements for heat shrinkage per ASTM D 3679.
 - c. Impact Resistance: 60 in-lbf, per ASTM D 4226, Procedure A, H.25.
 - d. Weatherability: No surface or structural defects such as peeling, cracking, or chipping when tested per ASTM D 3679.
 - e. Coefficient of Linear Expansion: 3.05 by 10-5 in/in F, per ASTM D 696.
 - f. Surface Distortion: No distortion at 120 degrees F (40.5 degrees C), per ASTM D 3679.
 - 8. Interlock: Post-form style lock with positive interlock; both ends of panels factory cut and notched for overlap.
 - 9. Nail Slots: Elongated 1-inch (25 mm) slots spaced approximately 1/4 inch (6 mm) apart in nailing hem to allow for expansion and contraction.
 - 10. Weep Holes: Small holes under the bottom butt of siding panels to prevent vapor build-up and allow accumulated moisture to escape.

2.3 SIDING

- A. Polymer Siding:
 - 1. Double 7" straight edge shingles.
 - a. Thickness: 0.090 inch.
 - b. Color: As selected by Architect from manufacturers standards.
 - 2. Single 7" Reinforced Vertical Siding
 - a. Thickness: 0.044 inch.
 - b. Color: As selected by Architect from manufacturers standards.

2.4 SOFFIT

- A. Vinyl Soffit: beaded soffit.
 - 1. Each 8 inch wide panel nominally configured as two 4 inch panels with an accent bead in both aerated and solid panels with 5/8 inch butt height.
 - 2. Aerated panels invisibly perforated with 3.2 sq. inch net free area per l/ft.
 - 3. Length: 12 feet 6 inches
 - 4. Width: 8 inches
 - 5. Thickness: 0.044 inch.
 - 6. Color: As selected by Architect from manufacturers standards.

2.5 ACCESSORIES

- A. Standard Accessories:
 - 1. Consistent with shape, size, and properties shown on the drawings and as required for complete installation.
 - 2. Produced from the same compound materials and with comparable properties as the siding.
 - 3. Color: Matching or color coordinated with siding.
- B. Accessories
 - 1. 4 inch (102 mm) traditional outside corner post with foam insert
 - 2. 3 inch (76 mm) beaded corner starter
 - 3. 7 inch (178 mm) lineal
 - 4. 1-1/2 inch (38 mm) j-channel
 - 5. Two piece j-channel

PART 3 EXECUTION

3.1 EXAMINATION

- A. Confirm that all critical dimensions are as specified on the drawings.
- B. Beginning installation indicates Installer's acceptance of substrate as suitable to accept siding and soffits.

3.2 PREPARATION

- A. Repair substrate flaws or defects before applying siding or soffits.
- B. Where necessary, fur surfaces to an even plane and free from obstructions before application.

3.3 INSTALLATION

- A. Install siding and soffits in accordance with the latest edition of "Vinyl Siding Installation Manual," published by the Vinyl Siding Institute (VSI) and special details from the drawings.
- B. Install vinyl siding, soffits, and accessories in accordance with best practice, with all joint members plumb and true.

3.4 FIELD QUALITY CONTROL

- A. After installation of siding and soffits, check entire surface for obvious flaws or defects.
- B. Replace and repair any problem areas, paying close attention to the substrate for causes of the problem.

3.5 CLEANING

- A. After application of siding and soffits, clean as necessary to remove all fingerprints and soiled areas.
- B. Upon completion of siding application, clean entire area, removing all scrap, packaging, and unused materials related to this work.

END OF SECTION

SECTION 07625 - SHEET METAL GUTTERS AND DOWNSPOUTS

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Gutters and downspouts for the renovated **Brunswick County Rest Area and Visitor Center**..

1.02 SUBMITTALS

- A. Product Data.
- B. Samples: Submit 3x6 -inch samples of each type of metal and finish required.

PART 2 - PRODUCTS

2.01 MATERIALS

- A. Seamless gutter to match existing consisting of Prefinished Aluminum Sheet: ASTM B 209, manufacturer's standard alloy and temper for indicated applications.
 - 1. Minimum thickness: 0.027 inch thick, unless indicated otherwise.
 - 2. Finish: 70 percent "Kynar 500" or "Hylar 5000" resin finish over epoxy primer; minimum system thickness 1.0 mil. Provide manufacturer's standard prime coat on underside.
 - a. Color: to be determined.
 - 3. Provide strippable plastic protective film on prefinished surface.
 - 4. Acceptable manufacturers: match existing

2.02 ACCESSORY MATERIALS

- A. Fasteners: Corrosion-resistant metal of same material as the material being fastened, or other material recommended by sheet metal manufacturer. Match finish and color of exposed fastener heads to finish and color of sheet material being fastened.
- B. Joint Adhesive: Two-component noncorrosive epoxy adhesive, recommended by metal manufacturer for sealing of nonmoving joints.
- C. Bituminous Coating: Heavy bodied, sulfur-free, asphalt-based paint; FS TT-C-494.

2.03 FABRICATION - GENERAL

- A. Form sheet metal to match profiles indicated, substantially free from oil-canning, fish-mouths, and other defects.
- B. Comply with SMACNA "Engineer rural Sheet Metal Manual" for applications indicated.
- C. Conceal fasteners and expansion provisions wherever possible.
 - 1. Exposed fasteners are not allowed on faces of sheet metal exposed to public view.
- D. Fabricate cleats and attachment devices from same material as sheet metal component being anchored or from compatible, noncorrosive metal recommended by sheet metal manufacturer.
 - 1. Gage: As recommended by SMACNA or metal manufacturer for application, but in no case less than gage of metal being secured.

2.04 GUTTERS AND DOWNSPOUTS

- A. Fabricate from prefinished aluminum sheet.
 - 1. Gutter: see roof plan for size.
 - 2. Downspouts: see roof plan for size.
- B. Provide expansion joints in gutters at spacing not to exceed 30 feet.
- C. Provide sheet metal baffles 6 inches high with legs 18 inches long at gutter corners below roof valleys.

- D. Gutter Supports: Brackets.
- E. Downspout Supports: Brackets.

PART 3 - EXECUTION

3.01 INSTALLATION

- A. General: Except as indicated otherwise, comply with sheet metal manufacturer's installation instructions and recommendations in the SMACNA "Architectural Sheet Metal Manual."

3.02 CLEANING AND PROTECTION

- A. Repair or replace work which is damaged or defaced, as directed by the Engineer.
- B. Protect sheet metal work as recommended by the installer so that completed work will be clean, secured, and without damage at substantial completion.

END OF SECTION 07625

SECTION 07900 - JOINT SEALERS

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. The sealing of joints indicated on schedule at the end of this section.
 - 2. The sealing of other joints indicated on drawings.
- B. Joints of a nature similar to that of joints indicated on the schedule shall be sealed with same sealer, whether indicated on drawings to be sealed or not.

1.02 DEFINITIONS

- A. Substrates:
 - 1. M-type substrates: Concrete, concrete masonry units, brick, mortar, natural stone. The term "masonry" means brick, stone, and concrete masonry work.
 - 2. G-type substrates: Glass and transparent plastic glazing sheets.
 - 3. A-type substrates: Metals, porcelain, glazed tile, and smooth plastics.
 - 4. O-type substrates: Wood, unglazed tile; substrates not included under other categories.

1.03 SUBMITTALS

- A. Product data.
- B. Samples for Color Selection. (Products exposed to view only.)

1.04 PROJECT CONDITIONS

- A. Environmental Limitations: Do not install sealers if any of the following conditions exist:
 - 1. Air or substrate temperature exceeds the range recommended by sealer manufacturers.
 - 2. Substrate is wet, damp, or covered with snow, ice, or frost.
- B. Dimensional Limitations: Do not install sealers if joint dimensions are less than or greater than that recommended by sealer manufacturer; notify the Engineer and get sealer manufacturer's recommendations for alternative procedures.

1.05 WARRANTY

- A. Submit Manufacturer's written warranty for failures in sealer work that occur within 5 years after substantial completion, without reducing or otherwise limiting any other rights to correction which the owner may have under the contract documents. Failure is defined as failure to remain weather-tight due to faulty materials. Correction is limited to replacement of sealers.

PART 2 - PRODUCTS

2.01 MATERIALS - GENERAL

- A. General: Provide only products which are recommended and approved by their manufacturer for the specific use to which they are put and which comply with all requirements of the contract documents.
 - 1. Provide only materials which are compatible with each other and with joint substrates.
 - 2. Colors of exposed sealers: As selected by the Engineer from manufacturer's standard colors.
- B. Manufacturers: Products of the manufacturers listed or approved equal, provided they comply with requirements of the contract documents will be among those considered acceptable.
 - 1. Silicone sealants:

- a. Dow Corning Corporation.
- b. Pecora Corporation.
- c. GE Silicones.

2.02 ELASTOMERIC SEALANTS

- A. Elastomeric Sealants - General: Chemically curing elastomeric sealants of types indicated, complying with ASTM C 920, including specific Type, Grade, Class, and Uses indicated, as well as all other requirements specified.
 1. Where movement capability exceeding that measured by ASTM C 920 is specified, sealant shall withstand the total movement indicated while remaining in compliance with the other requirements specified, when tested in accord with ASTM C 719, with base joint width measured at the time of application.
 2. For M-type substrates: Comply with requirements for Use M.
 3. For G-type substrates: Comply with requirements for Use G.
 4. For A-type substrates: Comply with requirements for Use A.
 5. For O-type substrates: Comply with requirements for Use M (minimum) and Use O for the particular substrate.
- B. Medium Movement Silicone Sealant: One- or two-part non-acid-curing, Grade NS, Class 25, Use NT, plus movement capability of more than 25 percent but less than 50 percent in both extension and compression.
- C. Mildew-Resistant Silicone Sealant: One-part, Type S, Grade NS, Class 25, Use NT, formulated with fungicide, for interior use on nonporous substrates, color to match glazed wall tile.

2.03 SILICONE-LATEX SEALANTS

- A. Silicone-Latex Emulsion Sealant: One-part, nonsag, mildew-resistant, paintable at H.M. frames and gray to match wall tile; complying with ASTM C 834 use at fiber-cement siding and panel joints.

2.04 SEALANT BACKERS

- A. Backers - General: Nonstaining; recommended or approved by sealant manufacturer for specific use.

PART 3 - EXECUTION

3.01 PREPARATION

- A. Do not begin joint sealer work until unsatisfactory conditions have been corrected.
- B. Masking Tape: Use masking tape to keep primers and sealers off of adjacent surfaces which would be damaged by contact or by cleanup. Remove tape as soon as practical.

3.02 INSTALLATION

- A. Comply with sealer manufacturers' installation instructions and recommendations, except where more restrictive requirements are specified.

3.03 SCHEDULE OF JOINT SEALERS

- A. Exterior Joints at fiber-cement siding and panel joints.
 1. Use Silicone-Latex sealants, paintable type.
 2. Joint shape: Concave joint configuration.
- B. Interior inside corners of all glazed tile walls; Mildew-Resistant Silicone Sealant color to match tile.
- C. Interior Joints for Which No Other Sealer Is Indicated:
 1. Use one of the following sealants:

Brunswick County (US17) Rest Area Renovations

- a. Use Silicone-Latex sealants, paintable type.
- b. Mildew-resistant silicone sealant at all ceramic tile corners (color to match gray wall tile) and at fixtures.
2. Use bond-breaker tape.
3. Joint shape: Concave joint configuration.

END OF SECTION 07900

Brunswick County (US17) Rest Area Renovations

This page left blank intentionally.

SECTION 08110 - STEEL DOORS AND FRAMES

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Standard steel doors and frames.

1.02 REFERENCES

- A. SDI 100-1991 -- Recommended Specifications: Standard Steel Doors and Frames; Steel Door Institute; 1991.

1.03 SUBMITTALS

- A. Product Data: Submit manufacturer's printed product information indicating compliance with specified requirements.
- B. Shop Drawings: Submit drawings for fabrication and installation of specified items, coordinated with opening schedule included in contract documents.

1.04 QUALITY ASSURANCE

- A. Quality Standard: Comply with SDI 100.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Deliver products in crates or cartons suitable for storage at the site.

PART 2 - PRODUCTS

2.01 MANUFACTURERS

- A. Manufacturers: Products of the following manufacturers or approved equal, provided they comply with requirements of the contract documents, will be among those considered acceptable:
 - 1. Benchmark Commercial Door Products.
 - 2. Curries Company/Essex Industries, Inc.
 - 3. Steelcraft Manufacturing Company/Masco Industries.

2.02 MATERIALS

- A. Steel Sheets, Hot-Rolled: ASTM A 569 and ASTM A 568, commercial quality, pickled and oiled.
- B. Steel Sheets, Cold-Rolled: ASTM A 366 and ASTM A 568, commercial quality, matte finish exposed, oiled.
- C. Steel Sheets, Galvanized: ASTM A 591, electrolytic zinc-coated, Class A, mill phosphatized.
- D. Anchorages: Galvanized steel, minimum 18 gage.
- E. Fasteners and Inserts: Units standard with manufacturer.
 - 1. Exterior walls: ASTM A 153, hot-dip galvanized, Class C or D.
- F. Primer Paint: Manufacturer's standard rust-inhibitive coating, suitable to receive finish coatings specified.

2.03 FABRICATION

- A. Exposed Door Faces: Fabricate from cold-rolled steel.
- B. Frames: Fabricate from cold-rolled or hot-rolled steel.

- C. Seal top and bottom edges integrally with door construction, or use minimum 16 gage steel channels to form flush closure.
- D. Exposed Screws and Bolts: Where required, provide only countersunk, flat Phillips-head fasteners.
- E. Hardware Preparation: Comply with DHI A115 series specifications.
 - 1. Locations: Comply with final shop drawings.
- F. Shop Painting:
 - 1. Primer: Apply primer evenly to achieve full protection of all exposed surfaces.

2.04 STEEL DOORS

- A. General: Fabricate steel doors in accordance with requirements of SDI 100.
- B. Interior Doors:
 - 1. Heavy-Duty, Model 1 - Full Flush.
 - 2. Minimum thickness: 16 gage exterior with insulated cores at exterior.
- C. Exterior doors: Provide exterior doors in accordance with ANSI/SDI A250.8 and in the configuration and size as indicated on the door schedule:
 - 1. Extra heavy-duty 1-3/4 inches, Model 1 - Full flush
 - 2. Minimum thickness: 16 gage exterior with insulated cores at exterior.

2.05 STEEL FRAMES

- A. General: Fabricate steel frames for scheduled openings, in styles and profiles as shown, using concealed fasteners.
 - 1. Minimum thickness: 14 gage exterior.
 - 2. Construction: Mitered and welded corners; foam frames for insulated installation.
- B. Guards: Weld protective covers to back of hardware openings at locations where grout, plaster, or other materials might interfere with hardware operation.

PART 3 - EXECUTION

3.01 INSTALLATION

- A. General: Install steel doors, frames, and accessories to comply with manufacturer's recommendations.
 - 1. Comply with detailed installation requirements of final shop drawings.
- B. Frame Installation: General: Adhere to provisions of SDI 105.
 - 1. Seal all exterior door frames with polyurethane foam sealant.
 - 2. Anchors: Provide 3 wall anchors per jamb at hinge and strike levels and minimum 18 gage base anchors.
 - 3. Fire-rated openings: Comply with requirements of NFPA 80.
- C. Door Installation:
 - 1. General: Comply with requirements and clearances specified in SDI 100.

3.02 ADJUST AND CLEAN

- A. Touch-Up: At locations where primer has been abraded or minor rusting has occurred, sand smooth and spray-apply compatible primer.
- B. Final Operating Adjustments: Check hardware at all openings for proper operation of doors, making final corrections as required to assure that work of this section is complete and undamaged.

END OF SECTION 08110

SECTION 08211 - FLUSH WOOD DOORS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Solid core veneer-faced doors.
- B. Related Requirements:
 - 1. Section 088000 "Glazing" for glass view panels in flush wood doors for factory installation.

1.3 SUBMITTALS

- A. Product Data: For each type of door. Include details of core, edge construction and factory-finishing specifications.
- B. Shop Drawings: Indicate location, size, and hand of each door; elevation of each kind of door; construction details not covered in Product Data; and the following:
 - 1. Requirements for veneer matching.
 - 2. Doors to be factory finished and finish requirements.
- C. Samples for Initial Selection
- D. Sample Warranty.
- E. Test Data
 - 1. Submit test data indicating compliance with the Sound Transmission Class (STC) requirements.

1.4 QUALITY ASSURANCE

- A. Manufacturer Qualifications:
 - 1. A qualified manufacturer that is a member in good standing of the Window and Door Manufacturers Association.
- B. Installer Qualifications: Minimum 2 years experience installing similar products.

1.3 DELIVERY, STORAGE, AND HANDLING

- A. Comply with requirements of referenced standard and manufacturer's written instructions.
- B. Package factory-finished doors individually in manufacturer's standard plastic bags, stretch wrap, or cardboard cartons.
- C. Mark each door on top rail with opening number used on Shop Drawings. Include manufacturer's order number and date of manufacture.

1.4 FIELD CONDITIONS

- A. Environmental Limitations: Do not deliver or install doors until spaces are enclosed and weather tight, wet work in spaces is complete and dry, and HVAC system is operating and maintaining temperature between **60 and 90 deg F** and relative humidity between 25 and 55 percent during remainder of construction period.

1.5 WARRANTY

- A. Special Warranty: Manufacturer agrees to repair or replace doors that fail in materials or workmanship within specified warranty period.
 - 1. Failures include, but are not limited to, the following:
 - a. Warping (bow, cup, or twist) more than 1/4 inch in a 42-by-84-inch section.
 - b. Telegraphing of core construction in face veneers exceeding 0.01 inch in a 3-inch span.
 - 2. Warranty shall also include installation and finishing that may be required due to repair or replacement of defective doors.
 - 3. Warranty Period for Solid-Core Interior Doors: Life of installation.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturers:
 - 1. Marshfield Door Systems
 - 2. Algoma Hardwoods, Inc.
 - 3. Eggers Industries.
 - 4. Assa Abloy
- B. Source Limitations: Obtain flush wood doors from single manufacturer.

2.2 FLUSH WOOD DOORS, GENERAL

- A. Quality Standard: In addition to requirements specified, comply with WDMA I.S.1-A-11, "Architectural Wood Flush Doors."
- B. WDMA I.S.1-A Performance Grade:
 - 1. Heavy Duty unless otherwise indicated.
- C. Wood-Based Particleboard-Core Doors:
 - 1. Provide wood-based particleboard core doors with a minimum density per ANSI A208.1, Grade LD-2 as required to meet WDMA Performance Duty level specified without added blocking.

2.3 VENEER-FACED DOORS FOR TRANSPARENT FINISH

- A. Interior Solid-Core Doors
 - 1. Veneer Grade: AA.
 - 2. Species: White birch
 - 3. Cut: Plain sliced.
 - 4. Match between Veneer Leaves: Book match.
 - 5. Assembly of Veneer Leaves on Door Faces: Running match.
 - 6. Pair and Set Match: Provide for doors hung in same opening
 - 7. Transom Match: Continuous match.
 - 8. Core: Wood-based Particleboard, fire-resistant composite, or specialty core as required per Article 2.2 and schedule.
 - 9. Construction: Five plies. Stiles and rails are bonded to core, and then entire unit is abrasive planed before veneering.
 - 10. WDMA I.S.1-A Performance Grade: As specified in Article 2.2.

2.4 LIGHT FRAMES AND LOUVERS

- A. Factory Glazing: Refer to Section 088000 "Glazing" for glass view panels in flush wood doors. Factory install glass. Fill glazing bead nail holes in factory finished doors.
- B. Wood Beads for Light Openings in Wood Doors: Provide manufacturer's standard flush wood beads unless otherwise indicated.
 - 1. Wood Species: Same species as door
 - 2. Profile: Lipped tapered beads.

2.5 FABRICATION

- A. Factory fit doors to suit frame-opening sizes indicated. Comply with clearance requirements of referenced quality standard for fitting unless otherwise indicated.
 - 1. Comply with NFPA 80 requirements for fire-rated doors.
- B. Transom and Side Panels: Fabricate matching panels with same construction, exposed surfaces, and finish as specified for associated doors. Finish bottom edges of transoms and top edges of rabbeted doors same as door stiles.
- C. Openings: Factory cut and trim openings through doors.
 - 1. Light Openings: Trim openings with moldings of material and profile indicated.

2.6 SHOP PRIMING

- A. Doors for Transparent Finish: Factory finish door faces and vertical stile edges with stain (if required).

2.7 FACTORY FINISHING

- A. General: Comply with referenced quality standard for factory finishing. Complete fabrication, including fitting doors for openings and machining for hardware that is not surface applied, before finishing.
 - 1. Finish faces and vertical edges, seal top and bottom edges as required for warranty purposes
- B. Factory finish doors.
- C. Transparent Finish:
 - 1. Grade: Custom.
 - 2. Finish: Manufacturer's standard UV cured polyurethane, equal to WDMA TR-6 catalyzed polyurethane.
 - 3. Staining: As selected by Architect from manufacturer's full range
 - 4. Sheen: Satin.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine doors and installed door frames, with Installer present, before hanging doors.
 - 1. Verify that installed frames comply with indicated requirements for type, size, location, and swing characteristics and have been installed with level heads and plumb jambs. Any deficiencies must be corrected prior to door installation.
 - 2. Reject doors with defects.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. Hardware: per schedule and manufacturers requirements.
- B. Installation Instructions: Install doors to comply with manufacturer's written instructions and referenced quality standard, and as indicated.
 - 1. Install fire-rated doors according to NFPA 80.
- C. Job-Fitted Doors: Align and fit doors in frames with uniform clearances and bevels as indicated below; do not trim stiles and rails in excess of limits set by manufacturer or permitted for fire-rated doors. Machine doors for hardware. Seal edges of doors, edges of cutouts, and mortises after fitting and machining.
 - 1. Clearances: Provide **1/8 inch** at heads, jambs, and between pairs of doors. Provide **1/8 inch** from bottom of door to top of decorative floor finish or covering unless otherwise indicated. Where threshold is shown or scheduled, provide **1/4 inch (6.4 mm)** from bottom of door to top of threshold unless otherwise indicated.
 - a. Comply with NFPA 80 for fire-rated doors.
 - 2. Bevel non-fire-rated doors **1/8 inch in 2 inches (3-1/2 degrees)** at lock and hinge edges.
 - 3. Trim bottom rail only to extent permitted by labeling agency.
- D. Factory-Fitted Doors: Align in frames for uniform clearance at each edge.
- E. Factory-Finished Doors: Do not trim factory finished doors for width.

3.3 ADJUSTING

- A. Operation: Correct any deficiency that prohibits the door from swinging or operating freely. Do not remove hinge screws after initial insertion. Shims used for alignment purposes must be inserted between hinge and frame. Do not insert shims between hinge and door.
- B. To prevent stile failure, insure that door closers are properly adjusted and do not limit the door opening swing. Limit door opening swing only with a properly located stop.
- C. Finished Doors: Replace doors that are damaged or that do not comply with requirements. Doors may be repaired or refinished if Work complies with requirements and shows no evidence of repair or refinishing.

END OF SECTION

SECTION 08310- ACCESS DOORS AND FRAMES

PART 1 GENERAL

1.1 RELATED SECTIONS

- A. Section 06100 - Rough Carpentry: opening support.

1.2 SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Manufacturer's data sheets, including:

1.3 DELIVERY, STORAGE, AND HANDLING

- A. Store access door in manufacturer's unopened packaging until ready for installation.
- B. Store access door until installation inside under cover in dry area out of direct sunlight.

1.4 WARRANTY

- A. Limited Warranty: One year against defective material and workmanship, covering parts only, no labor or freight. Defective parts, if deemed so by the manufacturer, will be replaced at no charge, freight excluded, upon inspection at manufacturer's plant which warrants same.

PART 2 PRODUCTS

2.1 ACCESS DOOR AND FRAME

- A. Stainless steel vertical access door
 1. Door: 16 ga. Rounded safety corners
 2. Frame: 14 ga. With continuous concealed hinge
 3. Lock: Mortise cylinder, 4 keys included

PART 3 EXECUTION

3.1 EXAMINATION

- A. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.
- B. Examine materials upon arrival at site. Notify the carrier and manufacturer of any damage.

3.2 INSTALLATION

- A. Install in accordance with manufacturer's instructions.

3.3 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Substantial Completion.

END OF SECTION

SECTION 08410-METAL-FRAMED STOREFRONTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Aluminum-framed storefront windows, doors, and door hardware.
- B. Perimeter sealant.

1.02 REFERENCES

- A. AAMA CW-10 - Care and Handling of Architectural Aluminum From Shop to Site; American Architectural Manufacturers Association; 1997.
- B. AAMA 2604 - Voluntary Specification, Performance Requirements and Test Procedures for High Performance Organic Coatings on Aluminum Extrusions and Panels; 1998.
- C. ASCE 7 - Minimum Design Loads for Buildings and Other Structures; American Society of Civil Engineers; 2002.
- D. ASTM B 221 - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes; 1996.
- E. ASTM B 221M - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes (Metric); 1996.
- F. ASTM E 283 - Standard Test Method for Determining the Rate of Air Leakage Through Exterior Windows, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen; 1991.
- G. ASTM E 330 - Standard Test Method for Structural Performance of Exterior Windows, Curtain Walls, and Doors by Uniform Static Air Pressure Difference; 1997.
- H. ASTM E 331 - Standard Test Method for Water Penetration of Exterior Windows, Curtain Walls, and Doors by Uniform Static Air Pressure Difference; 1996.

1.03 PERFORMANCE REQUIREMENTS

- A. Design and size components to withstand the following load requirements without damage or permanent set, when tested in accordance with ASTM E 330, using loads 1.5 times the design wind loads and 10 second duration of maximum load.
 - 1. Design Wind Loads: Comply with requirements of ASCE 7.
 - 2. Member Deflection: Limit member deflection to flexure limit of glass in any direction, with full recovery of glazing materials.
- B. Movement: Accommodate movement between storefront and perimeter framing and deflection of lintel, without damage to components or deterioration of seals.
- C. Air Infiltration: Limit air infiltration through assembly to 0.06 cu ft/min/sq ft of wall area, measured at a reference differential pressure across assembly of 1.57 psf as measured in accordance with ASTM E 283.
- D. Water Leakage: None, when measured in accordance with ASTM E 331 with a test pressure difference of 2.86 lbf/sq ft.
- E. System Internal Drainage: Drain to the exterior by means of a weep drainage network any water entering joints, condensation occurring in glazing channel, and migrating moisture occurring within system.
- F. Expansion/Contraction: Provide for expansion and contraction within system components caused by cycling temperature range of 170 degrees F over a 12 hour period without causing detrimental effect to system components, anchorages, and other building elements.
- G. Windborne Debris Resistance: Provide glazed windows capable of resisting impact from windborne debris, based on pass/fail criteria as determined from testing glazed windows identical to those specified, according to ASTM E 1886 and testing information in ASTM E 1996, and

requirements of authorities having jurisdiction.

1.04 SUBMITTALS

- A. See Section 01300 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide component dimensions, describe components within assembly, anchorage and fasteners, glass and infill, door hardware, internal drainage details.
- C. Shop Drawings: Indicate system dimensions, framed opening requirements and tolerances, affected related Work, expansion and contraction joint location and details, and field welding required.
- D. Manufacturer's Certificate: Certify that the products supplied meet or exceed the specified requirements.

1.05 DELIVERY, STORAGE, AND PROTECTION

- A. Handle products of this section in accordance with AAMA CW-10. Protect finished aluminum surfaces with wrapping. Do not use adhesive papers or sprayed coatings, which bond to aluminum when exposed to sunlight or weather.

1.06 ENVIRONMENTAL REQUIREMENTS

- A. Do not install sealants when ambient temperature is less than 40 degrees F. Maintain this minimum temperature during and 48 hours after installation.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Kawneer Company; Product Tri-Fab Versaglaze 601UT framing system with center plane.
- B. Other Acceptable Manufacturers:
 - 1. United States Aluminum Corp.
 - 2. Vistawall Architectural Products: www.vistawall.com.

2.02 COMPONENTS

- A. Aluminum-Framed Storefront: Factory fabricated, factory finished aluminum framing members with infill, and related flashings, anchorage and attachment devices.
 - 1. Finish: High performance organic coating.
 - 2. Color: Bronze to match existing, to be confirmed with architect.
- B. Aluminum Framing Members: Tubular aluminum sections, thermally broken with interior section insulated from exterior, drainage holes and internal weep drainage system.
 - 1. Alloy & temper recommended by aluminum storefront manufacturer for strength, corrosion resistance and application of required finish.
 - 2. Glazing stops: Flush.
 - 3. Cross-Section: 2x 6 inch nominal dimension.
- C. Doors: Glazed aluminum.
 - 1. Thickness: 1-3/4 inches.
 - 2. Top Rail: 4 inches wide.
 - 3. Vertical Stiles: 4-1/2 inches wide.
 - 4. Bottom Rail: 12 inches wide.
 - 5. Glazing Stops: Beveled.
 - 6. Finish: Same as storefront.

2.03 MATERIALS

- A. Extruded Aluminum: ASTM B221 (ASTM B221M).
- B. Fasteners: Stainless steel.
- C. Perimeter Sealant: Type 1 specified in Section 07900.
- D. Glass: As specified in Section 08800.
 - 1. Glass in Exterior Framing and Doors: Type 2, 1" insulated glass.
- E. Glazing Gaskets: Type to suit application to achieve weather, moisture, and air infiltration requirements.
- F. U-Factor: 0.77 max. and SHGC: 0.25 max.

2.04 FINISHES

- A. High Performance Organic Finish: AAMA 2604; multiple coats, thermally cured fluoropolymer system, 20-year finish.

2.05 HARDWARE

- A. Weatherstripping: Wool pile, continuous and replaceable; provide on all doors.
- B. Sill Sweep Strips: Resilient seal type, retracting, of neoprene; provide on all doors.
- C. Pivots: Center type; top and bottom; provide on all doors.
- D. Push/Pull Set: 1" bar, Hager No.160; provide on all doors.
- E. Threshold: Aluminum, ¼" high maximum; provide on all doors.
- F. Closers: Surface mounted on interior.
 - 1. Provide on all doors.
- G. Locks: Double cylinder mortise lock with key inside; keyed cylinder outside.
 - 1. Provide on all doors.

2.06 FABRICATION

- A. Fabricate components with minimum clearances and shim spacing around perimeter of assembly, yet enabling installation and dynamic movement of perimeter seal.
- B. Accurately fit and secure joints and corners. Make joints flush, hairline, and weatherproof.
- C. Prepare components to receive anchor devices. Fabricate anchors.
- D. Arrange fasteners and attachments to conceal from view.
- E. Reinforce components internally for door hardware.
- F. Reinforce framing members for imposed loads.
- G. Finishing: Apply factory finish to all surfaces that will be exposed in completed assemblies.
 - 1. Touch-up surfaces cut during fabrication so that no natural aluminum is visible in completed assemblies, including joint edges.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify dimensions, tolerances, and method of attachment with other work.
- B. Verify that wall openings and adjoining air and vapor seal materials are ready to receive work of this section.

3.02 INSTALLATION

- A. Install wall system in accordance with manufacturer's instructions.

- B. Attach to structure to permit sufficient adjustment to accommodate construction tolerances and other irregularities.
- C. Provide alignment attachments and shims to permanently fasten system to building structure.
- D. Align assembly plumb and level, free of warp or twist. Maintain assembly dimensional tolerances, aligning with adjacent work.
- E. Provide thermal isolation where components penetrate or disrupt building insulation.
- F. Install sill flashings. Turn up ends and edges; seal to adjacent work to form water tight dam.
- G. Coordinate attachment and seal of perimeter air and vapor barrier materials.
- H. Pack fibrous insulation in shim spaces at perimeter of assembly to maintain continuity of thermal barrier.
- I. Set thresholds in bed of mastic and secure.
- J. Install hardware using templates provided.
- K. Install glass in accordance with Section 08800, using glazing method required to achieve performance criteria.
- L. Install perimeter sealant in accordance with Section 07900.

3.03 ERECTION TOLERANCES

- A. Maximum Variation from Plumb: 0.06 inches every 3 ft non-cumulative or 1/16 inches per 10 ft, whichever is less.
- B. Maximum Misalignment of Two Adjoining Members Abutting in Plane: 1/32 inch.

3.04 ADJUSTING

- A. Adjust operating hardware for smooth operation.

3.05 CLEANING AND PROTECTION

- A. Remove protective material from pre-finished aluminum surfaces.
- B. Wash down surfaces with a solution of mild detergent in warm water, applied with soft, clean wiping cloths. Take care to remove dirt from corners. Wipe surfaces clean.
- C. Remove excess sealant by method acceptable to sealant manufacturer.
- D. Touch-up minor damage to factory applied finish; replace components that cannot be satisfactorily repaired.

END OF SECTION

SECTION 08710 - DOOR HARDWARE

PART 1 - GENERAL

1.01 SUBMITTALS

- A. Product Data.
- B. Final Hardware Schedule.
- C. Keying Schedule: Separate schedule showing how each lock is keyed.

PART 2 - PRODUCTS

- A. Latching and Locking Devices: Mortise locks, unless otherwise indicated, with appropriate locking function; provide on every door.

2.01 MATERIALS – GENERAL

- A. Manufacturers:
 - 1. Where a particular manufacturer's product is specified, products of other manufacturers will be considered for substitution.
- B. Fasteners: Provide hardware prepared by the manufacturer with fastener holes for machine screws, unless otherwise indicated.
 - 1. Provide all fasteners required for secure installation.
 - 2. Select fasteners appropriate to substrate and material being fastened.
 - 3. Use wood screws for installation in wood.
 - 4. Use fasteners impervious to corrosion outdoors and on exterior doors.
 - 5. Exposed screws: Match hardware finish.
- C. Finish on All Exposed Metal Items: Satin chrome plated (626).
 - 1. Exceptions:
 - a. Plates and bars: Satin stainless steel (630).
 - b. Hinges: Where steel hinges are acceptable, use matching plated finish.
 - c. As indicated for specific items.

2.02 LOCKS, LATCHES, AND BOLTS

- A. Mortise Locksets and Latchsets:
 - 1. Comply with requirements of BHMA A156.13, Operational Grade 2.
 - a. Security Grade 1.
 - 2. Trim: Cast lever with escutcheon plate.
- B. Strikes: Provide strike for each latch bolt and lock bolt.
 - 1. Finish to match other hardware on door.
 - 2. Use wrought box strikes with curved lips unless otherwise indicated.
 - 3. Open strike plates may be used on interior wood door frames.

2.03 LOCK CYLINDERS AND KEYING

- A. Keying: Obtain the owner's keying instructions.
 - 1. Match existing master key system.
 - 2. Provide standard cylinders for locks on all doors, unless otherwise indicated.
- B. Cylinders: Minimum 7-pin pin tumbler cylinders.
 - 1. Construction: All parts brass, bronze, nickel silver or stainless steel.

2. Cylinders made by manufacturers other than the lockset manufacturer will not be acceptable.
- C. Keys: Nickel silver.
 1. Stamp each key with manufacturer's change symbol.
 2. Provide individual change key for each lock which is not designated to be keyed alike with a group of related locks.
 3. Provide 3 of each change key. Master key system shall match existing: 5 master keys.

2.04 DOOR CONTROL DEVICES

- A. Closers - General:
 1. Use closers of sizes recommended by manufacturer, unless a larger size is specified.
 2. Size closer or adjust closer opening force to comply with applicable codes.
- B. Surface-Mounted Closers:
 1. Comply with requirements of BHMA A156.4, Grade 2.
 - a. Provide the following features:
 1. PT 4D: Adjustable hydraulic back check.
 2. PT 4F: Delayed action.
 2. Style: CO2021.
 3. Parallel arms: Provide for all closers; use larger size than normal.
 1. Finish: Metallic paint finish, color similar to metal hardware on same door.
- B. Recessed-Mounted Closers: Replace existing closers at the 2-Welcome Center entry doors.
- C. Wall/Floor-Mounted Stops/holders: Comply with requirements of ANSI A156.16.
 1. Floor-mounted stops: Style: L12121.
 2. Resilient bumpers: Gray.

2.05 SEALS AND THRESHOLDS

- A. Weatherstripping:
 1. At jambs and head: Replaceable bumper in surface-mounted extruded aluminum housing.
 - a. Bumper: Solid neoprene, hollow bulb or loop.
 2. At bottom: Replaceable sweep in surface-mounted extruded aluminum housing.
 - a. Sweep: Solid neoprene.
 3. Housing finish: Natural anodized.
- B. Thresholds: Ribbed aluminum.
 1. Select style to suit changes in elevation and to fit door hardware and frames.
 2. Interlocking hook type threshold: Hook strip on bottom of door, interlocking with top lip of threshold.
 - a. At doors that swing in, provide internal drain and drain pan.
- C. Sealant for Setting Thresholds: Butyl-rubber or butyl-polyisobutylene sealant.

2.06 ARCHITECTURAL DOOR TRIM

- A. Manufacturers:
 1. Architectural door trim: Products of the following manufacturers, or approved equal, provided they comply with requirements of the contract documents, will be among those considered acceptable:
 - a. Yale Security, Inc.
 - b. Hiawatha, Inc.
 - c. H. B. Ives, a Harrow Company.
 - d. Rockwood Manufacturing Company.
 - e. Triangle Brass Manufacturing Company, Inc.
- B. Push / pulls:

Brunswick County (US17) Rest Area Renovations

1. Decorative pulls: 1 inch round bars, radius ends, vertical(pull side) and horizontal(push side), 12 & 32 inches long respectively.
2. Pull handles which are not mounted on plates: Fasten with through-bolts concealed under plate on opposite side.
3. Where matching handles or bars are installed on each side of door, mount back-to-back with concealed fasteners.

PART 3 - EXECUTION

3.01 PREPARATION

- A. Factory- or shop-prepare all work for installation of hardware.

3.02 INSTALLATION

- A. Follow hardware manufacturer's recommendations and instructions.
- B. Mount at heights specified in the Door and Hardware Institute's "Recommended Locations for Architectural Hardware for Standard Steel Doors and Frames."
 1. Exception(s): As required by applicable regulations.
- C. Install hardware in correct location, plumb and level.
- D. Reinforce substrates as required for secure attachment and proper operation.
- E. Thresholds: Apply continuous bead of sealant to all contact surfaces before installing.

3.03 ADJUSTMENT

- A. Adjust each operable unit for correct function and smooth, free operation.
- B. Adjust door closers to overcome air pressure produced by HVAC systems.
- C. If hardware adjustment is completed more than one month before substantial completion, readjust hardware not more than one week before substantial completion.

3.04 CONTRACT CLOSEOUT

- A. Deliver all keys to the owner.

PART 4 - SCHEDULE

Manufacturers Code Name:

Ad	Adams Rite	Na	National Guard
Gl	Glynn Johnson	Ro	Rockwood
Ha	Hager	Sa	Sargent
Mc	McKinney		

Group # 1

2 Continuous Hinge	MCK-12HD 83	BZ	Mc	Pemko or Ives Equivalent
2 Flush Bolts	555	US10B	Ro	Ives or Hager Equivalent
1 Deadlock	MS1851SW	313	Ad	Schlage or Sargent Equivalent
1 Thumb Turn Cyl	4066 X 1 1/8"	313	Ad	Schlage or Sargent Equivalent
1 Mortise Cylinder	21 41 1 1/8 Gmk X 3 Keys	US10B	Sa	Schlage or Adams Rite Equivalent
2 Push/Pull Set	RM252 X 33"	US10B	Ro	Ives or Hager Equivalent
2 Closer	281 PS	US10B	Sa	LCN or Dorma Equivalent
1 Saddle Threshold	425 E X 72"	AL	Na	Pemko or Hager Equivalent

Group #2

Brunswick County (US17) Rest Area Renovations

3 Hinges	TA 2314 4 1/2 X 4 1/2	US32D	Mc	Pemko or Ives Equivalent
1 Passage set	8200-66 LNJ X	US32D	Sa	Schlage or Sargent Equivalent
1 Closer	281 PS	26D	Sa	LCN or Dorma Equivalent
1 Protection Plate	K1050 28" X 34"	US32D	Ro	Von Duprin or Hager Equivalent
3 Door Silencer	GJ64	Gray	Gl	Ives or Rockwood Equivalent
1 Wall Bumper	409	US32d	Ro	Ives or Rockwood Equivalent

END OF SECTION 08710

SECTION 08800 – GLAZING

PART 1 – GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Insulated, display, and obscure glass.
 - 2. Glazing accessories.
- B. Types of work in this section include work for:
 - 1. Exterior entry door and sidelights; see Section 08410-Metal-Framed Storefronts.
 - 2. Sliding glass entry door; see Section 08460.

1.02 PERFORMANCE REQUIREMENTS

- A. Exterior Glazing: Provide glazing assemblies which will withstand normal conditions without failure, loss of weathertightness, or deterioration.
 - a. Wind Loads-completed system shall withstand all wind and service pressure loads normal to wall plane.
 - b. Thermal Movement-provide for thermal movement caused by 180 degrees F surface temperature, without causing buckling stresses on glass, joint seal failure, undue stress on structural elements, damaging loads on fasteners, reduction of performance or detrimental effects.
- B. Deterioration includes:
 - 1. For insulating glass:
 - a. Moisture or dirt between panes.
 - b. Development of condensation between panes.
 - c. Damage to internal coating, if any.
 - d. Development of other visible indication of seal failure.
 - 2. For laminated glass: Development of visible delamination.

1.03 SUBMITTALS

- A. Product Data.
- B. Insulating Unit Warranty.

1.04 WARRANTY

- A. Warranty on Insulating Glass: Fabricator's standard warranty for 5 years.

PART 2 – PRODUCTS

2.01 MANUFACTURERS

- A. Manufacturers:
 - 1. Laminated glass: Products of the following manufacturers or approved equal, provided they comply with requirements of the contract documents, will be among those considered acceptable:
 - a. Falconer-Lewistown, Inc.
 - b. Globe Amerada Glass Company.

- c. Guardian Industries Corporation.
- d. Viracon, Inc.

2.02 GLASS TYPES

- A. Glass Types - General: Provide glass types fabricated of the glass products indicated.
 - 1. Exterior glass thickness: 6 mm (1/4 inch nominal), unless otherwise indicated.
 - 2. Where safety glazing is required by governing authorities, provide certified safety glazing per ANSI Z97.1. See NCSBC section 2406.4. Each pane to be identified per section 2406.3
 - 3. Cut or drill holes in laminated units.
- B. Glass Type I - 1: Sealed insulating units at fixed, sliding and storefront entry doors and sidelights.
 - 1. Total thickness: 1 inch, nominal.
 - 2. Exterior and Interior pane: Laminated glass.
 - a. Two-ply.
 - b. Thickness of plies: 6 mm.
 - c. All plies: Heat-strengthened float glass.
 - d. Color: Outer and inner ply: Clear.
 - e. Interlayer thickness: 0.05 inch.
 - f. see cover sheet for energy values.
- C. Glass Type SG - 2: Display case Polycarbonate sheet, with mar-resistant coating;
 - 1. Provide certified safety glazing, thickness: ¼ inch for use at display cases.
 - 2. Color: Clear.
 - 1. Acceptable glazing methods: Sealant, both sides.
- D. Glass Type SG - 3: Obscure glass at Unisex Restroom door; thickness: ¼ inch safety glass.

2.03 BASIC GLASS PRODUCTS

- A. Sealed Insulating Units: Factory-assembled multiple panes separated by and sealed to spacers forming air-tight, dehydrated air space(s).
 - 1. ASTM E 774, Class B.
 - 2. Spacer seals: Manufacturer's standard.
 - 3. Exception: For structural adhesive glazed units use only a dual seal system, using materials determined by structural adhesive manufacturer to be compatible with structural adhesive.
- B. Float Glass: Quality q3, unless otherwise indicated.
 - 1. Heat-strengthened: ASTM C 1048, Kind HS, Type I.
- C. Laminated Units: Multiple plies laminated together with interlayer, using heat and pressure, without air pockets or contaminants between plies.
 - 1. Interlayer for all-glass units: Polyvinyl butyral sheet, specifically designed for lamination and with demonstrated long-term ability to maintain physical and visual properties under installed conditions.
- D. Polycarbonate Sheet: Rigid, flat polycarbonate sheet; thicknesses as indicated.
 - 1. Flammability: Average extent of burning less than 1 inch, when tested in accordance with ASTM D 635, using the thickness of material to be used on the project.
 - 3. UV- and mar-resistant coating: Apply on all surfaces exposed to air.

2.04 INSTALLATION MATERIALS

- A. Installation Materials - General: Select products which have appropriate performance characteristics as recommended by glass and glazing materials manufacturers and which are compatible with all materials with which they will come into contact.

- B. Heel and Toe Bead Sealant: Noncuring, nonskinning, minimum 75 percent solids, butyl or polyisobutylene rubber, complying with 802.3, Type II ductile back bedding compound, as described in AAMA 800.

PART 3 – EXECUTION

3.01 INSTALLATION - GENERAL

- A. Comply with recommendations for installation contained in the FGMA "Glazing Manual" and "Sealant Manual" except when specifically not recommended or prohibited by the glass or glazing material manufacturer; comply with manufacturer's recommendations.
- B. Protect glazing from edge damage during handling and installation.
- C. Do not install glass that has edge damage or defects that reduce glass strength or performance or diminish appearance.

3.02 GLAZING IN FRAMES

- A. Use continuous heel or toe bead at all exterior glazing.
- B. Do not block weep holes.
- C. Structural Adhesive Glazing: Perform glazing in strict accordance with instructions of structural glazing adhesive manufacturer and additional requirements elsewhere in the contract documents.

3.03 PROTECTION AND CLEANING

- A. Cover exposed polycarbonate surfaces with heavy paper secured with tape, without touching glazing.
 - 1. Clean polycarbonate surfaces using only methods recommended by manufacturer.

END OF SECTION 08800

THIS PAGE LEFT BLANK INTENTIONALLY.

SECTION 09252 - CEMENTITIOUS BACKER BOARD

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Fiber cement backer board panels.

1.2 RELATED SECTIONS

- A. Section 06100 - Rough Carpentry: framing and bracing.
- B. Section 09260 - Gypsum Board: Vapor barrier material and installation requirements.

1.3 REFERENCES

- A. ANSI 108/A118/A136 - American National Standards for the Installation of Ceramic Tile.
- B. ANSI A108.11 - Installation of Cementitious Backer Units.
- C. ANSI A118.4 - Specifications for Latex Portland Cement Mortar
- D. ANSI A118.9- Cementitious Baker Units.
- E. ANSI A136.1 - Organic Adhesives for Installation of Ceramic Tile
- F. ASTM C1288 - Discrete Non-Asbestos Fiber-Cement Interior Substrate Sheets.

1.4 SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Installation methods.
- C. Verification Samples: For each finish product specified, two samples, minimum size 4 by 6 inches (100 by 150 mm) square, representing actual product, color, and patterns.

1.5 QUALITY ASSURANCE

- A. Installer Qualifications: Minimum of 2 years experience with installation of similar products.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Store boards flat on a smooth level surface. Protect edges and corners from chipping. Store sheets under cover and keep dry prior to installing.

1.7 PROJECT CONDITIONS

- A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.

1.8 WARRANTY

- A. Product Warranty: limited product warranty against manufacturing defects:
 - 1. 1/2 inch (13 mm) nominal cement board for 20 years.
- B. Workmanship Warranty: application limited warranty for 2 years.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturer:
 - 1. James Hardie Building Products, Inc.,
 - 2. National Gypsum
 - 3. Durock
- B. Requests for approval of equal substitutions will be considered in accordance with provisions of Section 01600.

2.2 BACKERBOARD

- A. Type: thickness varies
- B. Material shall meet the following building code compliance:
 - 1. Non-asbestos fiber-cement board to comply with ASTM C1288 and ANSI A118.9.
 - 2. Board shall meet the building code compliance National Evaluation Report No. NER 405.

2.3 FASTENERS

- A. Metal Framing fasteners
 - 1. Metal framing: 1-1/2 inches (32 mm) No. 8 by 0.375 inch (9.5 mm) HD self-drilling, corrosion resistant ribbed wafer head screws.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Do not begin installation until substrates have been properly prepared.
- B. If framing preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.2 WALL FRAMING

- A. Either vertical or horizontal, nominal 2 inches by 4 inches (51 mm by 102 mm) metal framing spaced a maximum of 24 inches (610 mm) on center with end joints staggered from adjacent courses in both vertical and horizontal applications.
- B. To comply with ANSI A108.11, either vertical or horizontal, nominal 2 inches by 4 inches (51 mm by 102 mm) metal framing spaced a maximum of 16 inches (406 mm) on center with end joints staggered from adjacent courses in both vertical and horizontal applications.
- C. Install a vapor barrier.
 - 1. Comply with building code regarding vapor barrier requirements.
 - 2. Repair any punctures or tears in vapor barrier prior to the installation of the board.

3.3 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

3.4 INSTALLATION

- A. Install in accordance with manufacturer's instructions. Install sheets with 1/8 inch (3 mm) gap between sheets.
- B. Place fasteners 8 inches (152 mm) on center no closer than 3/8 inch (9.5 mm) from board edges and 2 inches (51 mm) from board corners.
- C. Boards shall be placed with a minimum 1/4 inch (6 mm) clearance from the floor surfaces and other horizontal tile termination locations, including above tub edges. This gap shall be free of adhesive and grout and filled with a flexible sealant.
- D. Boards shall be placed with a minimum 1/8 inch (3 mm) clearance from wall and cabinet bases, and other horizontal tile termination locations, including above tub edges. This gap shall be free of adhesive and grout and filled with a flexible sealant.
- E. Joints shall be reinforced with 2 inches (51 mm) wide, high-strength, coated, alkali-resistant, glass fiber reinforcing tape embedded into the wet mastic or modified thinset mortar and allowed to dry thoroughly.
- F. For large tiled areas, movement/control joints shall be provided in accordance with ANSI A108, Section AN-3.7 or as indicated on drawings.
- G. Wall tiles complying with ANSI A137.1 are attached to the board with flexible Type I mastic adhesives complying with ANSI A136.1, or acrylic or latex-modified thinset mortars complying with ANSI A118.4, in accordance with ANSI A108.

END OF SECTION

THIS PAGE LEFT BLANK INTENTIONALLY.

SECTION 09260 - GYPSUM BOARD SYSTEMS

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Gypsum wallboard and ceiling board.
 - 2. Drywall finishing.

1.02 QUALITY ASSURANCE

- A. Regulatory Requirements: Where required, provide fire-rated assemblies as listed in the following:
 - 1. Underwriters Laboratories Inc.'s (UL) "Fire Resistance Directory."

PART 2 - PRODUCTS

2.01 GYPSUM BOARD

- A. Gypsum Wallboard and Ceiling Board: ASTM C 36; maximum lengths available to minimize end-to-end butt joints in each area receiving finished gypsum board.
 - 1. Edges: Tapered.
 - 2. Thickness: 5/8 inch, except as otherwise shown (fire-resistant type).
- B. Manufacturers: Products of the following manufacturers or approved equal, provided they comply with requirements of the contract documents, will be among those considered acceptable:
 - 1. Domtar Gypsum.
 - 2. Georgia-Pacific Corporation.
 - 3. Gold Bond Building Products, a National Gypsum Division.
 - 4. USG Corporation.

2.02 TRIM AND ACCESSORIES

- A. General: Except as otherwise specifically indicated, provide trim and accessories by manufacturer of gypsum board materials, made of galvanized steel or zinc alloy and configured for concealment in joint compound.

2.03 JOINT TREATMENT

- A. General: Provide products by manufacturer of gypsum boards. Comply with ASTM C 475 and with manufacturer's recommendations for specific project conditions.
- B. Joint Tape: Manufacturer's standard paper reinforcing tape.
- C. Setting Type Joint Compound: Chemical hardening type, for the following applications:
 - 1. Exterior use: Prefilling and topping.
- D. Drying Type Joint Compound: Vinyl-based type for interior use, and as follows:
 - 1. All-purpose type, for both embedding tape and as topping.

2.04 MISCELLANEOUS MATERIALS

- A. General: Provide miscellaneous materials as produced or recommended by manufacturer of gypsum products.

PART 3 - EXECUTION

3.01 INSTALLATION OF GYPSUM BOARD

- A. General: Comply with ASTM C 840 and GA-216 except where exceeded by other requirements.
 - 1. Wherever possible, install gypsum board to minimize butt end joints.
 - 2. Apply ceiling boards prior to installation of wallboards. Arrange to minimize butt end joints near center of ceiling area.
 - 3. Install wallboards in a manner which will minimize butt end joints in center of wall area. Stagger vertical joints on opposite sides of walls.
- B. Installation on Metal Framing:
 - 1. Single-layer application: Install gypsum board by the following method:
 - a. Screw attachment.

3.02 FINISHING

- A. General: Comply with ASTM C 840 and GA-216 except where exceeded by other requirements.
- B. Finish gypsum board in accordance with the following level of finish per GA-214, except where indicated otherwise on the drawings:
 - 1. Level 3: Embed tape in joint compound at all joints and interior angles. Provide two separate coats of compound at all joints, angles, fastener heads, and accessories. Provide smooth surfaces free of tool marks and ridges.

END OF SECTION 09260

SECTION 09900 - PAINTING

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Painting and finishing of exposed exterior items and surfaces.
 - 2. Painting and finishing of exposed interior items and surfaces.

1.02 DEFINITIONS

- A. DFM (dry film mils): Thickness, measured in mils, of a coat of paint in the cured state.

1.03 SUBMITTALS

- A. Product Data: Manufacturer's technical data sheets for each coating.
- B. Color and Texture Samples:
 - 1. Provide for each coating system, color, and texture and applied to representative substrate samples.
 - a. Prepare samples to show bare, prepared surface and each successive coat.
 - b. Label each sample with coating name and color.
 - 2. Miscellaneous substrates: 12-by-12-inch hardboard.
 - 3. Concrete: 8-inch square samples.
 - 4. Wood: 8-inch square samples for surfaces; 8-inch long samples for trim.
 - 5. Metal: 5-by-7-inch samples.

1.04 QUALITY ASSURANCE

- A. Materials: All coating materials required by this section shall be provided by a single manufacturer, unless otherwise required or approved.
- B. Applicator: Firm with successful experience in painting work similar in scope to work of this project.
 - 1. Maintain throughout duration of the work a crew of painters who are fully qualified to satisfy requirements of the specifications.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Delivery: Deliver materials in manufacturer's original containers bearing coating name and color, material composition data, date of manufacture, legal notices if applicable, and mixing, thinning, and application instructions.

1.06 PROJECT CONDITIONS

- A. Apply coatings only under the following environmental conditions:
 - 1. Provide continuous ventilation and heating to prevent accumulation of hazardous fumes and to maintain surface and ambient temperatures above 45 degrees F for 24 hours before, during, and for 48 hours after application of finishes, or longer if required to obtain fuel cure as indicated by manufacturer's instructions.

1.07 COORDINATION

- A. Coordination: Where special coatings will be applied over shop coatings specified in other sections, coordinate work of such other sections to ensure that only approved, compatible primers are applied.

1.08 MAINTENANCE STOCK

- A. At time of completing application, deliver stock of maintenance material to the owner. Furnish not less than one properly labeled and sealed 1-gallon can of each type of finish coat of each color, taken from lots furnished for the work.

PART 2 - PRODUCTS

2.01 MANUFACTURERS

- A. The brand-name products listed in the schedule at the end of this section and made by the following manufacturer of Low or No V.O.C. paints are the basis of the contract documents:
 - 1. **Sherwin Williams Company - Health Spec.**
- B. Products of the following manufacturers or approved equal, provided they comply with requirements of the contract documents, will be among those considered in accordance with standard substitution procedures:
 - 1. Benjamin Moore & Company - Pristine EcoSpec.
 - 2. The Glidden Company* - Lifemaster.

2.02 PRODUCTS

- A. Colors:
 - 1. For multicoat systems, apply each coat using a successively darker tint or shade, unless approved otherwise.
 - 2. Top coat colors: To be determined by owner/architect.
- B. **Lead Content:**
 - 1. **Not more than 0.06 percent lead** by weight (calculated as lead metal) in the total nonvolatile content of the paint or the equivalent measure of lead in the dried film.
 - 2. Exception: Where permitted by applicable regulations.

PART 3 - EXECUTION

3.01 INSPECTION

- A. Verify that surfaces and conditions are ready for work in accordance with coating manufacturer's recommendations.

3.02 SURFACE PREPARATION

- A. Apply coatings to surfaces that are clean and properly prepared in accordance with manufacturer's instructions. Remove dirt, dust, grease, oils, and foreign matter. Prepare surface for proper texture necessary to optimum coating adhesion and intended finished

appearance. Plan cleaning, preparation, and coating operations to avoid contamination of freshly coated surfaces.

1. Do not apply coatings to labels that identify equipment, fire-resistance ratings, etc.
2. Remove hardware, cover plates, and similar items before applying coatings.
3. Provide protection for non-removable items not scheduled for coating. After application of coatings, install removed items. Use only skilled workmen for removal and replacement of such items.
4. Protect surfaces not scheduled for coating. Clean, repair, or replace to the satisfaction of the Engineer any surfaces inadvertently spattered or coated.
5. Allow substrate to dry thoroughly. Test for moisture in accordance with coating manufacturer's recommendations before applying coatings.
6. Intricate fabricated shapes may be pickled in lieu of hand or power tool cleaning.
7. Before hand or power tool cleaning, remove visible oil, grease, soluble welding residue, and salts by solvent cleaning. After hand or power tool cleaning, re-clean surfaces if necessary.
8. Before touching up coatings damaged by handling or welding, re-prepare damaged surfaces.

3.03 MIXING AND THINNING

- A. Remove and discard any skin formed on surface of coatings in containers. Discard any containers where skin comprises 2 percent or more of the remaining material. Do not add thinner except as specifically recommended (not merely permitted) by the coating manufacturer for proper coating application under the circumstances prevailing at the project site when application equipment recommended by the coating manufacturer is employed. Use only the quantities and the types of thinner recommended.

3.04 APPLICATION

- A. General:
 1. Apply coatings in accordance with coating manufacturer's instructions and using application method best suited for obtaining full, uniform coverage of surfaces to be coated.
 2. Apply each coat to achieve the dry film thickness per coat recommended by the coating manufacturer. Application rates in excess of those recommended and fewer numbers of coats than specified will not be accepted.
 3. Completed coatings shall be free of defects such as runs, sags, variations in color, lap or brush marks, holidays, and skips.
 4. Apply coatings according to the schedule at the end of this section and as otherwise indicated. Coat all similar surfaces not specifically mentioned unless specifically exempted.
 5. Coat front and back of miscellaneous items such as covers, access panels, and grilles. Apply fully finish coats behind movable items of furniture and equipment before installation. Apply prime coat only behind non-movable items of furniture and equipment before installation.
 6. Sand gloss coats before applying subsequent coatings.
- B. Remove coatings not in compliance with this specification, re-clean and re-prepare surfaces as specified, and apply coatings to comply with the contract documents.
- C. Scheduling:
 1. Apply first coat of material to properly prepared surfaces without delay.
 - a. Apply successive coats within the time limits recommended by the manufacturer.

3.05 PRIME COATS

- A. General:
 - 1. Field apply bottom coats scheduled except where the contract documents require shop coating of ferrous metals.
 - 2. Ferrous metals that have not been shop primed shall be field primed promptly after arrival at the site or shall be stored away from the effects of weather.
 - 3. Re-prepare and retouch damaged prime coats using approved, compatible primer.
- B. Primers for Wood and Wood Products:
 - 1. Apply first coat to wood upon receipt at the site and before wood is exposed to sun or rain.
 - 2. Back-prime concealed surfaces and cut edges of exterior wood trim prior to installation.

3.06 FINISH COATS

- A. Number of Coats and Minimum Coating Thickness:
 - 1. Apply not less than the number of coats indicated.
 - 2. Apply each coat to achieve not less than the dry film thicknesses indicated per coat.
 - 3. Apply additional coats at no additional cost to the owner when necessary to achieve complete hiding, uniform texture, or uniform sheen and appearance.

3.07 CLEANING AND PROTECTION

- A. Cleaning:
 - 1. Clean work area on a daily basis; dispose of spent materials and empty containers. If requested, turn over the Engineer all empty coatings containers used during the course of each day.
 - 2. Remove all trace of coatings from adjacent surfaces not scheduled to be coated. Remove by appropriate methods that do not damage surfaces.
- B. Protection:
 - 1. Protect work against damage until fully cured. Provide signs identifying wet surfaces until surfaces are adequately cured.
 - 2. Shortly before final completion of the project, examine surfaces for damage to coatings and restore coatings to new, undamaged condition.
 - 3. Touch-up of minor damage will be acceptable where result is not visibly different from surrounding surfaces. Where result is different either in color, sheen, or texture, recoat entire surface.

3.08 SCHEDULE OF COATINGS FOR INTERIOR NONTRAFFIC SURFACES

- A. **Gypsum Wallboard: Walls.**
 - 1. Latex acrylic, Eggshell finish.
 - a. Bottom coat: Airless High-Build Flat Interior Primer / Finish; 1.1DFM.
 - b. Intermediate coat: Same as top coat.
 - c. Top coat: High Performance Waterborne Acrylic Eggshell Enamel (match existing)
- B. **Gypsum Wallboard: Ceilings.**
 - 1. Latex acrylic, Eggshell finish.
 - a. Bottom coat: Airless High-Build Flat Interior Primer / Finish; 1.1DFM.
 - b. Intermediate coat: Same as top coat.
 - c. Top coat: High Performance Waterborne Acrylic Eggshell Enamel (match existing)
- C. **Wood: trim, display cabinet, shelving.**
 - 1. Varnish, satin
 - a. Stain: Interior Oil Wood Finishing Stain, (color to be selected).
 - b. Bottom and intermediate coats: WoodPride 1908 Interior Polyurethane Satin Varnish.
 - c. Top coat: Interior Polyurethane Satin Varnish.

D. Wood: Doors & frames, windows, ceiling, trim, shelving.

1. Latex acrylic, Semi-Gloss finish.
 - a. Bottom coat: Airless High-Build Flat Interior Primer / Finish; 1.1DFM.
 - b. Intermediate coat: Same as top coat.
 - c. Top coat: High Performance Waterborne Acrylic Semi-gloss Enamel (match existing)

3.09 SCHEDULE OF COATINGS FOR EXTERIOR NONTRAFFIC SURFACES

A. Fiber-Cement: Lap siding & trim;

1. Acrylic / Latex, Satin, equal to Duration.
 - a. Bottom coat: Same as top coat.
 - b. Top coat: Exterior Acrylic Flat Finish; 1.5 DFM.

B. Fiber-Cement: Vertical siding & trim;

1. Acrylic / Latex, Satin, equal to Duration.
 - a. Bottom coat: Same as top coat.
 - b. Top coat: Exterior Acrylic Flat Finish; 1.5 DFM.

C. Plywood Bead board and Batten Strips

- a. Bottom coat: Same as top coat.
- b. Top coat: Exterior Acrylic Satin Finish; 1.5 DFM.

3.10 SCHEDULE OF PAINT COLORS

TO BE DETERMINED.

END OF SECTION 09900

THIS PAGE LEFT BLANK INTENTIONALLY.

SECTION 10170 – PLASTIC TOILET COMPARTMENTS

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Water-closet compartments and urinal screens (toilet partitions) metallic finish.
 - 2. Restroom changing table counters and bench.

1.02 SUBMITTALS

- A. Product Data.
- B. Shop Drawings.
- C. Panel Color Verification Samples: Submit 6-inch-square samples of each panel finish type and color to be installed.
- D. Manufacturer's Instructions.
- E. Maintenance Data.

1.03 QUALITY ASSURANCE

- A. Regulatory Requirements: Products and finished installations to be used by handicapped persons must comply with requirements of the 2012 NC Building Code, Chapter 11, Accessibility, and ICC A117.1-2009.

1.04 COORDINATION

- A. Use manufacturer's instructions and data to determine anchorage requirements for panel systems. In a timely manner, distribute to affected installers of related work those system components and anchorage devices provided by panel manufacturer for incorporation into other work.

PART 2 - PRODUCTS

2.01 PANEL SYSTEMS

- A. Compartments: Provide compartments fabricated of partitions and erected using the following panel systems at locations indicated on the drawings:
 - 1. Solid plastic, floor-anchored and overhead-braced.
- B. Screen Systems: Provide screens erected using the following panel systems at locations indicated on the drawings:
 - 1. Solid plastic, wall-hung, floor supported, and overhead braced.

2.02 PANEL MATERIALS

- A. Plastic Solid Plastic:
 - 1. Panel material: High-density polyethylene or polypropylene, of homogeneous composition and color throughout, minimum thickness of material 1 inch. Provide seamless panels with eased edges.
 - 2. Plastic Panel; Continuous mounting brackets in matching colors;
 - a. Accurate Partitions, color to match existing.
 - b. Sanymetal, color to match existing.
 - c. **Scranton Products.***: "color to match existing" for all Toilet partitions and for all changing tables or approved equal; **www.scrantonproducts.com**.
 - 3. Hardware, head rails, heat-sink, shoes, and accessories. Manufacturer's standard styles. The following materials will be acceptable:
 - a. Chromium-plated nonferrous cast alloy ("Zamac").
 - b. Extruded aluminum, anodized and polished and stainless steel shoes.

4. Manufacturers: Products of the following manufacturers or approved equal, provided they comply with requirements of the contract documents, will be among those considered acceptable (colors shall match those specified above):
 - a. **Scranton Products***: Santana/Comtec/Capitol.
 - b. The Sanymetal Products Company, Inc.
 - c. Accurate Partitions Corp. Lyons, IL or approved equal.

2.03 ACCESSORIES

- A. General: Provide hardware and accessories as necessary to properly install panel systems indicated.
 1. **Hinge**: Self-closing, continuous type hinge, surface-mounted; adjustable to permit door to rest at any angle or closed angle.
 2. Latch for non-handicapped compartments: Surface-mounted type, with emergency access feature.
Provide stop and keeper with rubber bumper.
 3. Latch for handicapped compartments: Surface-mounted sliding latch (for inner side of compartment doors), with emergency access feature, designed for use by handicapped persons.
 4. Provide **door pulls** on both sides of all doors, including handicapped compartments (for outer side of compartment doors): Suitable for use by handicapped persons.
 5. Combination coat hook with rubber bumper: Provide unit of sufficient length to prevent compartment door from striking installed toilet accessories. Locate a minimum of 16" below top of door.
 6. Leveling-and-anchorage devices: Rust-resistant steel devices as recommended by panel manufacturer for installation of panels in conditions indicated.
 7. **Metal shoes**: Stainless steel. Minimum shoe height: 3 inches.
 8. Fasteners: Tamper-resistant rust-proof, exposed fasteners as recommended by panel manufacturer for installation of panels and hardware in conditions indicated. Finish to match hardware.
 9. **Overhead bracing**: Antigrip headrail bracing fabricated from continuous extruded aluminum, clear anodized finish.
 10. **Brackets**: All panels shall be mounted with continuous panel brackets of aluminum, and anchored to continuous wall blocking.
 11. **Heat-Sink**: Provide solid aluminum strips at the bottom of all panels or Class A rated panels.

PART 3 - EXECUTION

3.01 INSTALLATION

- A. Perform installation in accordance with manufacturer's instructions, except where more restrictive requirements are shown, specified, or are necessary for project conditions.

END OF SECTION 10170

SECTION 10425 - SIGNS

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Interior aluminum plaques and aluminum letters.
- B. Provide signage as indicated on the signage schedules.

1.02 SUBMITTALS

- A. Product Data: Submit for each type of sign specified, including details of construction relative to materials, dimensions of individual components, profiles, and finishes.
- B. Shop drawings:
 - 1. Show fabrication and erection of signs. Include plans, elevations, and large-scale sections of typical members and other components. Show anchors, grounds, layout, reinforcement, accessories, and installation details.

PART 2 - PRODUCTS

2.01 MANUFACTURERS

- A. Metal Custom Room Signs: Products of the following manufacturers or approved equal, provided they comply with requirements of the contract documents, will be among those considered acceptable (colors shall match those specified):
 - 1. AOA Signs, Inc. (336) 679-3344
 - 2. Sign-A-Rama*; (919) 773-8014
 - 3. Best Manufacturing Co.
 - 4. or approved equal.

2.02 RAISED LETTER SIGNS

- A. Base Material: **Aluminum plate** with brushed and polished mill finish (Sign Plaques):
 - 1. Total Thickness: ½ and 1/4 inch.
 - 2. Height: 1.5 to 7.5" inches.
 - 3. Edges: Square room title with male/female caricatures on top.
- B. Raised Character Size and Style: Routed and painted aluminum:
 - 1. Comply with applicable provisions of 2012 NC Building Code, Chapter 11, Accessibility, including International Symbol of Accessibility (restrooms, Family), and ANSI/ICC A117.1, including Tactile Characters and Braille.
 - 2. Character Color: Black
 - 3. Character Thickness: 1/32 inch minimum raised letters.
 - 4. Height: 5/8 inch minimum.
 - 5. Edges: Square.
 - 6. Character Font: Helvetica.
 - 7. Character Case: Upper case only.

2.03 INDIVIDUAL METAL LETTERS

- A. Material: **Aluminum plate** with brushed mill finish:
 - 1. Thickness: 1/4 inch.
 - 2. Height: see drawings.
 - 3. Edges: Square.
- B. Character Style:
 - 1. Character Font: Helvetica.
 - 2. Character Case: Upper case only and solid arrows.
 - 3. Mount individual letters on post for exterior

- 4. Adhere individual metal letters interior

2.05 ACCESSORIES

- A. Mounting Hardware: Stainless steel or aluminum screws and double sided tape, permanent adhesive.
- B. Provide surface mounting for individual interior letters; 2-sets on the Beadboard panels.

2.06 SIGN SCHEDULE:

- A. Sign custom aluminum plaques shall read as follows:

<u>Location/Room No.</u>	<u>Copy</u>	<u>Quantity</u>
See plan	FAMILY ROOM**	1
See plan	KNOCK BEFORE ENTRY	1
See plan	Fire extinguisher is located inside	1
See plan	ELECTRICAL	1
See plan	JANITOR	1
See plan	Indiv. Metal letters as shown on drawings	

- * Provide the male or female caricature at signs noted above with aluminum figure, mount to wall 2" from the doorway or corners.
- ** Provide both caricatures (male & female) at signs noted above with aluminum figure, mount to wall 4" from the door opening.

PART 3 - EXECUTION

3.01 INSTALLATION

- A. General:
 - 1. Locate sign units and accessories where indicated, using mounting methods of the type described and in compliance with the manufacturer's instructions.
 - 2. Install signs level, plumb, and at the height indicated, with sign surfaces free from distortion or other defects in appearance.
 - 3. Install project sign in locations indicated and using mounting methods indicated.
- B. Aluminum Plaques and Individual Letters:
 - 1. Mount plaques using the standard method recommended by the manufacturer for the type of wall surface indicated (stainless steel or aluminum screws and double sided tape).
 - 2. Concealed mounting: Use double-sided foam tape and mount plaques at 60" above the floor adjacent to doors 2" from the latch side of the jamb for plaques and center individual letters as indicated.

3.02 CLEANING AND PROTECTION

- A. After installation, clean soiled sign surfaces according to the manufacturer's instructions. Protect units from damage until acceptance by the Owner.

END OF SECTION 10425

SECTION 10700 - ALUMINUM SUNSHADE

PART 1 – GENERAL

1.1 SUMMARY

- A. Section Includes: Louvered Sunshade.
- B. Related Requirements: Division 1 – General Requirements

1.2 REFERENCES

- A. The publications listed below form a part of this specification to the extent referenced. Publications are referenced within the text by the basic designation only.
- B. American Welding Society (AWS):
 - i. Standard D1.2 – Structural Welding Code – Aluminum
- C. American Architectural Manufacturers Association (AAMA):
 - i. Aluminum finishes AAMA 2605 Kynar

1.3 SUBMITTALS

- A. Submit within 15 days after contract award.
- B. Shop Drawings: Indicate size, material and finish. Include plan elevation pages to clearly outline sunshade locations. Include installation procedures, details of joints, attachments and clearances. Provide lead time for product and note possible conflicts with standard line.
- C. Color charts showing manufacturer's full range of colors from standard line.

PART 2 – PRODUCTS

2.1 APPROVED MANUFACTURERS

- A. Details based on Lawrence Fabric and Metal Structures. Other manufacturers of equal may be used as below
- B. Substitutions are acceptable assuming they comply with these specifications, are submitted based on Section 01600 – Substitution Requirements and have a minimum 10 years experience.

2.2 MATERIALS

- A. Framing: Aluminum tube with minimum nominal thickness .250 in.
- B. Infill: Aluminum airfoil.
- C. Connections: Wall plates and sunshade mounting brackets are to be aluminum. Optional continuous steel embed system, depending on wall conditions.
- D. Assembly Fasteners: Nuts, bolts, washers and screws to be stainless steel to suit application and per pre-engineered sunshade load requirements.
- E. Anchors and Supports: Anchors, nuts, bolts, washers and pipe spacers to be zinc plated or galvanized steel required to suit application and per pre-engineered sunshade load requirements.
- F. Finish: Powder-coat finish per ASTM D 3451, complying with finish manufacturer's written instructions for surface preparation including pretreatment, application, baking and minimum dry film thickness. Color to be selected from standard color line.

PART 3 – EXECUTION

3.1 FABRICATION

- A. Preassemble sunshades in the shop to greatest extent possible. Disassemble units only as necessary for shipping and handling limitations. Clearly mark units for reassembly and coordinated installation.
- B. Infill must be mechanically fastened in order to easily replace individual parts due to damage sustained during shipping or installation.

3.2 INSTALLATION

- A. Install sunshades per manufacturer's written instructions and as indicated on drawings.
- B. Locate and place sunshades level, plumb and at indicated alignment with adjacent work.
- C. Repair damaged finishes so no evidence remains of corrective work. Return items to the factory that cannot be refinished in the field. Make required alterations and refinish entire unit or provide new units.
- D. Protect galvanized and nonferrous-metal surfaces from corrosion or galvanic action by applying a coating of bituminous paint or elastomeric coating on surfaces that will be in contact with concrete, masonry, or dissimilar metals. Use of nylon washers and neoprene pads are approved.

END OF SECTION

SECTION 10810 - TOILET ACCESSORIES

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Paper Towel Dispenser and waste receptacles.
 - 2. Soap Dispenser
 - 3. Mirrors (2-year warranty).
 - 4. Grab bars.
 - 5. Toilet Paper Dispenser.
 - 7. Combination utility shelf / mop and broom holders.

1.02 SUBMITTALS

- A. Product Data.
- B. Shop Drawings.
- C. Manufacturer's Instructions.

PART 2 - PRODUCTS

2.01 MANUFACTURERS

- A. For each distinct type of toilet accessory, provide accessories fabricated by a single manufacturer.
- B. All model numbers specified are products of **Bobrick* Washroom Equipment, Inc.**
- C. Only equivalent products of the following other manufacturers complying with the following **Bobrick Washroom Equipment, Inc.** provided they comply with requirements of the contract documents or approved equal, will be considered acceptable:
 - 1. A & J Washroom Accessories
 - 2. American Specialties, Inc. (ASI)

2.02 TOILET ACCESSORIES

- A. Toilet Paper Dispensers:
 - 1. Basis of design: Model B-2892 Bobrick.
 - a. Classic series surface-mounted twin jumbo roll toilet tissue dispenser, holds 2-rolls 10" diameter, sliding access panel.
- B. Automatic Soap Dispenser
 - 1. Basis of design: Model U135EA, AJW.
- C. Grab Bar 36:
 - 1. Basis of design: B-6806.99 - 36".
 - a. Stainless steel, nonslip gripping surface and concealed mounting, Model B-5806.99, by Bobrick.
- D. Grab Bar 42:
 - 1. Basis of design: B-6806.99 - 42".
 - a. Stainless steel, nonslip gripping surface and concealed mounting, Model B-5806.99, by Bobrick.
- E. Grab Bar 18:
 - 1. Basis of design: B-5806.99 - 18".
 - a. Stainless steel, nonslip gripping surface and concealed mounting, Model B-5806.99, by Bobrick.
- F. Combination Utility Shelf/Mop and Broom Holder:
 - a. Basis of design: B-224 x 36" long.
 - b. Stainless steel with 4 mop holders.

- a. b. With 3-spring loaded rubber cam mop/broom holders
- H. Recessed Towel Dispenser and Waste Receptacle: paper towel dispenser, 15 gallon waste capacity bottom cabinet, locking doors/cabinets, recessed flush with wall except for waste receptacle, stainless steel; no sharp edges, seamless wall flanges, concealed piano hinges.
 - 1. Product: B-43944 manufactured by Bobrick.
 - 2. LinerMate accessory to be included part number 43944-134 (verify)
 - 3. Towel Mate accessory to be included
- J&K. Mirrors: Stainless steel framed, ¼" thick float glass mirror (provide a 2-year warranty from mirrored glass from staining or delaminating and frame rusting);
 - 1. Sizes: 18' x 30" and 18" x 60".
 - 2. Frame: Radius edges, with mitered and welded and ground corners, and tamperproof hanging system; burr free satin finish.
 - 3. Product: Model B-2908 1830 and B-2908 1860 manufactured by Bobrick.

2.03 MATERIALS

- A. Stainless steel: Type-304 stainless steel with satin finish, typical for all accessories.
- B. Mounting Devices and Fasteners: Provide toilet accessory manufacturer's recommended items for substrates and conditions indicated.

2.04 FABRICATION

- A. Manufacturer's Trademarks and Model Numbers: Permanently affix manufacturer's name and model number to unexposed surface of accessory.

PART 3 - EXECUTION

3.01 INSTALLATION

- A. Perform installation in accordance with manufacturer's instructions, except where more stringent requirements are shown or specified, and except where project conditions require extra precautions or provisions to ensure satisfactory performance of the work.
- B. Accessories Installed for Use by Handicapped Persons: Install as indicated on drawings and in accordance with the 2018 NC Building Code, Chapter 11, Accessibility, and ANSI A117.1.

END OF SECTION 10810

DIVISION 15A - PLUMBING

- 15010 Basic Plumbing Requirements
- 15140 Hangers and Supports
- 15250 Plumbing Piping Insulation
- 15410 Plumbing Piping
- 15430 Plumbing Specialties
- 15440 Plumbing Fixtures

SECTION 15010 - BASIC PLUMBING REQUIREMENTS

PART I - GENERAL

1.1 GENERAL CONDITIONS

- A. The stipulations and conditions stated in this Section, together with all provisions of the "Instructions to Bidders", "General Conditions", "Supplemental General Conditions", and "Special Conditions", hereinbefore set forth, shall apply to this and the other Sections of Division 15A.

1.2 GENERAL REQUIREMENTS

- A. The General Requirements hereinafter listed apply to the Plumbing Work Division. If there is any conflict between the General Requirements and the General Conditions, the General Conditions shall take precedence.

1.3 ALTERNATES

- A. Carefully examine all alternates at the back of this specification to determine if any work described under the Plumbing Section will be affected thereby.

1.4 INTENT

- A. The intent of these drawings and specifications are to describe the installation of a complete, fully adjusted and operational system. Therefore, any items shown on drawings and not specifically called for in the specifications, or any items specified and not specifically indicated or detailed on the drawings, or any items neither specified or shown, but which are reasonably incidental to and commonly required to make a complete job, will be furnished and installed by the Plumbing Contractor at his own expense.

1.5 DEFINITIONS

- A. The Plumbing Contractor shall provide all supervision, labor, material equipment, machinery, plant, and any and all other items necessary to complete the plumbing systems. All items of equipment are specified in the singular; however, the Plumbing Contractor shall provide the number of items of equipment as indicated on the drawings, and as required for complete systems.

Where the word "provide" is used, it shall mean "furnish and install complete and ready to use".

1.6 VISIT TO THE SITE

The Plumbing Contractor shall visit the site before submitting his bid so as to be thoroughly familiar with the job conditions and/or peculiarities. No extra payment will be allowed for anything which could have been anticipated from a visit to the site.

1.7 REGULATORY REQUIREMENTS

- A. All work under this Section shall be accomplished in strict accordance with State codes. Where these plans and specifications conflict with such codes, the codes shall govern.

Brunswick County (US17) Rest Area Renovations

The Plumbing Contractor shall notify the Architect or Engineer of such conflicts in writing prior to receipt of bids.

1.8 PERMITS AND FEES

- A. NA

1.9 DRAWINGS AND SPECIFICATIONS

- A. The Plumbing Drawings and Specifications are intended to cover all the work enumerated under the respective headings. The drawings are diagrammatic only. No Contractor shall take advantage of conflict or error between Drawings and Specifications, or between General Drawings and Mechanical, Plumbing and/or Electrical Drawings, but shall request a clarification of such from the Architect/Engineer, should this condition exist. If there is insufficient time to issue an Addendum for this clarification, the Plumbing Contractor shall figure on the most expensive of the items in conflict.
- B. The Plumbing Contractor shall refer to the Architectural and Structural Drawings and Specifications for the general construction of the building, for floors and ceiling heights, for locations of walls, partitions, beams, etc., and shall be guided accordingly for setting of all sleeves, inserts and equipment. The Plumbing Contractor shall not under any circumstances scale drawings for the location of equipment. The Plumbing Contractor shall verify the locations of all utility services.
- C. The Plumbing Contractor shall keep at least one set of corrected Shop and Design Drawings at the site. Drawings are to be current, denoting approved modifications and actual installed departure. Submit drawings to Architect/Engineer before final payment is made.

1.10 SUPERVISION

- A. The Plumbing Contractor performing the work specified shall be required to employ a qualified Superintendent or Foreman to continuously supervise the installation of their work, with authorization to act as agent. Contractors: He shall be capable of checking layouts, coordinating and supervising the work, establishing grades and levels, and locating chases, openings, hangers, inserts, sleeves, etc.

PART II - PRODUCTS

2.1 STANDARD PRODUCTS

- A. Unless otherwise indicated in writing by the Architect/Engineer, the materials to be provided under this Specification shall be standard products of manufacturers regularly engaged in the production of such equipment and shall be the manufacturer's latest design. All items of the same type or rating shall be identical.

2.2 SUBMITTAL

- A. The Plumbing Contractor shall submit, for approval, detailed shop drawings on all major equipment and where requested. No materials or equipment may be delivered to the job site or installed until the Plumbing Contractor has in his possession the approved shop drawing for the particular material or equipment. The Plumbing Contractor shall furnish the number of copies required by the General or Special Conditions of the contract, but no case less than six (6) copies.
- B. Submitted material shall be properly labeled indicating specific service for which material or equipment to be used, section and article number of specifications governing,

Brunswick County (US17) Rest Area Renovations

- Contractor's name and name of job.
- C. Approval of equipment will not relieve the Plumbing Contractor of compliance with the Specifications even if such approval is made in writing, unless the attention of the Engineer is called to the non-complying features by letter accompanying the submittal data. Approval of Submittal Data by the Engineer shall not be construed as a complete check of approval of detailed dimensions, weights, gauges, and similar details with the proposed articles. The conformance with the necessary coordination between the various other Contractors and suppliers shall be solely the responsibility of the Plumbing Contractor and with no additional expense to the Owner.

2.3 SUBSTITUTIONS

- A. Manufacturer's lists are to establish a standard of quality and not intended to limit the selection to these manufacturers. All materials and equipment which are essential and have not been specified or shown, shall be new and of the highest grade and quality and free from defect or other imperfections. It should be understood that where the words "furnished and installed" are used, it is intended that the Plumbing Contractor shall purchase and install all materials required.
- B. All materials and equipment proposed as substitutes for these specified shall require a ten (10) day prior approval from the Engineer prior to the bid date. No substitutions will be allowed after the ten (10) day period before the bid date.

2.4 PRODUCT HANDLING

- A. Equipment and materials shall be properly stored, adequately protected, and carefully handled to prevent damage before and during installation. Equipment and materials shall be handled, stored and protected in accordance with the manufacturer's recommendations and as approved by the Architect/Engineer. Equipment installed with a factory finish shall be fully protected during construction and shall be maintained free of dust, dirt, and foreign matter. Dents and other surface damage shall be repaired or replaced to the satisfaction of the Architect/Engineer at no additional cost to the Owner.
- B. The Plumbing Contractor shall clean up and remove from the job site all waste materials, packaging, crating, and refuse resulting from his work on a daily basis.

2.5 MATERIALS AND WORKMANSHIP

- A. The Plumbing Contractor shall perform a first class job, both in material and workmanship. None other will be accepted. Deviations from either will be corrected by the Plumbing Contractor at the Plumbing Contractor's expense.
- B. The material used throughout the work, except when otherwise noted, shall be new and of the best of its kind. No substitutes shall be used unless approved by the Architect/Engineer. All work shall be executed with a maximum speed consistent with safety and good workmanship.
- C. Any equipment furnished by the Plumbing Contractor that is larger than those indicated on the drawings and described in these Specifications or have different electrical characteristics, the increase in cost to the Electrical Contractor for larger wires, conduit, circuit breakers, switches, etc. or for changes in work already installed shall be borne by the instigating Contractor.

PART III - EXECUTION

3.1 EXCAVATION AND BACKFILL

- A. The Plumbing Contractor shall preform any and all trench and pit excavation and backfilling required for the installation of his work. Trenches shall be made with the sides

Brunswick County (US17) Rest Area Renovations

vertical and shall be shored where necessary for the protection of men and equipment. All excavation work shall be done in a careful manner to avoid damage to footers and foundations. The backfilling shall be placed in layers not exceeding 4 inches in depth, wetting each layer as it is placed, and thoroughly compacting each layer with mechanical tamper or other approved means. Any damage done during excavation and backfilling operations to roads, sidewalks, curbs, shrubs, sod, footers, foundations, etc. shall be replaced to its condition prior to construction at no expense to the Owner.

3.2 SCAFFOLDING, RIGGING AND HOISTING

- A. The Plumbing Contractor shall furnish all necessary scaffolding, staging, rigging and hoisting required for the completion of his work. All such scaffolding, etc., shall be removed from the premises when its use is no longer required on the job.

3.3 CUTTING AND PATCHING

- A. The Plumbing Contractor shall provide all cutting and patching necessary to install the work specified in this section. The patching shall match adjacent surfaces.
- B. No structural member shall be cut without the approval of the Engineer, and all such cutting shall be done in a manner directed by him.

3.4 EQUIPMENT SPACE AND ARRANGEMENT

- A. The equipment shall fit into the space allotted and shall allow adequate clearance for entry, installation, replacement, servicing, and maintenance. The Plumbing Contractor shall coordinate the work to ensure that equipment may be moved into place without altering building components or other installations. Access space shall not be less than the equipment manufacturer's requirements.
- B. These drawings indicate the extent and general arrangement of equipment, piping, and ductwork. If any departures are deemed necessary by the Plumbing Contractor, details of such departures and the reasons therefore shall be submitted to the Architect/Engineer for approval as soon as practicable and within 30 days after award of the contract. No departure shall be made without written approval of the Architect/Engineer.

3.5 DAMAGE TO WORK ALREADY IN PLACE

- A. The Plumbing Contractor shall assume full responsibility for any damage done by him, his agents or employees, to any work already in place. Any such damage done shall be repaired at the Contractor's expense by mechanics skilled at their respective trades to the approval of the Architect/Engineer.

3.6 JURISDICTION OF WORK

- A. It may become necessary for the Plumbing Contractor to furnish labor or materials which is not generally accepted as part of this trade. In cases of this type, he shall contract the work or shall furnish materials and employ workmen of the trade involved in order not to cause any delay or stoppage of work caused by infringement of trade agreements as to jurisdiction, alleged or actual.

3.7 COORDINATION WITH OTHER TRADES

- A. All work shall be coordinated with other trades involved in the construction project. All work shall be carefully laid out in advance to coordinate Architectural, Structural, Mechanical, Plumbing and Electrical features of construction. The Plumbing Contractor shall verify at the site all locations, grades, elevations, and utility service connections indicated. Any conflicts due to lack of proper coordination shall be brought to the attention

Brunswick County (US17) Rest Area Renovations

of the Architect/Engineer for resolution. The Plumbing Contractor shall make required changes or relocations at no additional cost to the Owner.

- B. Installation, inspection, and testing of work above ceilings shall be completed and approved by the Architect/Engineer prior to installation of the specified finished ceilings. However, ceiling suspension system may be installed as required for coordination.
- C. The Plumbing Contractor shall consult with the other trades at the start of the work and periodically thereafter, as required to properly coordinate the various items of work, and to avoid interferences. Should any interferences of any nature develop as the work progresses, such interferences shall be resolved and eliminated as directed. The cost of any work directed shall be borne by the Subcontractor or Contractors directed to do this work.

3.8 DIVISION OF WORK

- A. This paragraph is intended to show exactly the point of division of work between the Electrical Division and the Plumbing Division.
- B. All equipment covered in the Plumbing Division of the specifications shall be furnished, mounted, and aligned under the Plumbing Division. All individual motor starters, unless indicated as part of a motor control center, for this equipment shall be furnished and installed by the Plumbing Contractor.
- C. All final electrical connections to equipment covered in the Plumbing Division of the specifications shall be completed under the Plumbing Division.
- D. The Electrical Contractor shall provide a disconnect switch or junction box for each item of equipment under Division 16.
- E. Electrical equipment and wiring that is provided by the Plumbing Contractor shall be in accordance with the Electrical specification.

3.9 EQUIPMENT INSTALLATION

- A. Final connections to equipment, including pipe, duct, and controls, shall be provided under applicable sections of this Division, unless otherwise specified or indicated.
- B. Manufacturer's Instructions: Equipment shall be installed as recommended by the manufacturer to conform to the requirements of the particular application, in accordance with these drawings and specifications.

3.10 OPERATION AND MAINTENANCE MANUALS

- A. One complete manual as outlined herein shall be submitted for approval before conducting instruction sessions in operation, before systems or equipment tests are performed, and before final or beneficial occupancy.
- B. Manuals shall have rigid covers and index tabs for each major piece of equipment, auxiliaries, and systems. The following shall be inscribed on the cover: the words "OPERATION AND MAINTENANCE MANUAL", the name and location of the building, the name of the Section, such as "Plumbing" and the name of the Plumbing Contractor. Two copies of each approved manual shall be submitted to the Owner and one copy shall be submitted to the Architect/Engineer.
- C. Each piece of equipment shall be listed and identified with the same name, mark, number, or other identification as noted or scheduled in the Contract Documents.
- D. Manuals shall include the following:
 - 1. Complete operating installations, covering start-up and shutdown for all components installed.
 - 2. Legible copies of all shop drawings. Any comments incorporated in "as noted" approvals of shop drawings shall be recorded on the drawings included in the manuals.
 - 3. All equipment Maintenance and Service Manuals.\
- E. A complete parts list for each piece of equipment.
- F. All descriptive literature for the equipment.

Brunswick County (US17) Rest Area Renovations

- G. Operating characteristics, performance data, ratings, and curves for each piece of equipment.
- H. Internal wiring and control diagrams.
- I. All other information pertinent to the maintenance and servicing of equipment and systems provided in the project.
- J. Name, address, and telephone number for service on each manufacturer's equipment.

3.11 OPERATING INSTRUCTIONS

- A. After all equipment and services are in operation, and the Operation and Maintenance Manuals are available, an instruction and training session shall be conducted for the Owner's operating personnel.
- B. Instruction sessions shall be conducted during the Owner's normal working periods, and at times and locations satisfactory to the Owner.

3.12 EQUIPMENT START-UP

- A. No equipment shall be placed in operation until it has been inspected by a qualified representative of the manufacturer and Certified to be ready for operation. The manufacturer's representative shall supervise the start-up operation and shall be responsible for all adjustments required to meet design conditions. Such services shall be at no additional cost to the Owner.

3.13 GUARANTEE

- A. The Plumbing Contractor shall present to the Owner a written guarantee covering his work, including all equipment, material and workmanship. This guarantee shall be against all defects in any of the above work, and shall run for a period of one (1) year from the date of written acceptance of the Contractor's work.
- B. Any defective work, equipment, material and/or workmanship that develops within the guarantee period, which is not caused by ordinary wear or abuse by other persons, shall be replaced by the Plumbing Contractor without cost to the Owner.

3.14 FINAL INSPECTION

- A. When the entire Contract has been completed and the work is ready for final inspection, the Architect/Engineer or his duly authorized representative will make the inspection. At the time of inspection, the Plumbing Contractor shall demonstrate to the Architect/Engineer that the various systems and pieces of equipment have been adjusted to operate in accordance with the requirements of the Contract.

3.15 FINAL PAYMENTS

- A. All final payments are contingent upon all necessary Certificates and/or Approvals cited above, together with the written Guarantee being presented to the Owner.

END OF SECTION 15010

SECTION 15140 - HANGERS AND SUPPORTS

PART I - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawing and General Provisions of the Contract, including the General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes Hangers and Supports for Plumbing Systems Piping and Equipment.

PART II - PRODUCTS

2.1 PIPE HANGERS AND SUPPORTS

- A. Hangers: Galvanized carbon steel, adjustable, clevis
- B. Multiple or Trapeze Hangers: Steel channels with welded spacers and hanger rods.
- C. Vertical Support: Steel riser clamp
- D. Copper Pipe Support: Carbon steel ring, adjustable, copper plated.
- E. Shield for Insulated Piping 2 Inches and Smaller: 18 gauge galvanized steel shield over insulation in 180 degree segments, minimum 12 inches long at pipe support.
- F. Sheet metal saddles must be ½ the circumference of the insulation, turned up or rounded at the corners to avoid damage to the vapor barrier.

2.2 HANGER RODS

- A. Galvanized Steel Hanger Rods: Threaded both ends or continuous threaded.

2.3 FLASHING

- A. Metal Flashing: 26 gauge galvanized steel
- B. Flexible Flashing: 47 mil thick sheet butyl; compatible with roofing.
- G. Flashing shall be compatible with the roofing material and be coordinated with the General Contractor.

2.4 SLEEVES

- A. Sleeves for Pipes: Form with schedule 40, galvanized steel pipe
- B. Fire Stopping Insulation: Glass fiber type, non-combustible
- C. Caulk: Fire Barrier type sealant

2.5 MISCELLANEOUS MATERIALS

- A. Structural Steel: ASTM A 36/A 36M, steel plates, shapes, and bars, black and galvanized
- B. Bolts and Nuts: ASME B18.10 or ASTM A 183, steel, hex-head, track bolts and nuts
- C. Washers: ASTM F 844, steel, plain, flat washers
- D. Grout: ASTM C 1107, Grade B, non-shrink, non-metallic
 - 1. Characteristics include post-hardening, volume-adjusting, dry, hydraulic cement-

Brunswick County (US17) Rest Area Renovations

type grout that is non-staining, non-corrosive, non-gaseous and is recommended for both interior and exterior applications.

2. Design Mix: 5000-psi (34.5MPa), 28-day compressive strength
3. Water: Potable
4. Packaging: Pre-mixed and factory-packaged

2.6 ATTACHMENTS

- A. Mechanical Anchor Fasteners: Insert-type attachments with pull-out and shear capacities appropriate for supported loads and building materials where used. Permitted in concrete over four (4) inches thick.
- B. Weld: Type 22
- C. Beam clamps: Types 20, 21, 28 or 29
- D. Wood: Wood screws or lag bolts

PART III - EXECUTION

3.1 HANGERS AND SUPPORTS INSTALLATION

- A. Install hangers, supports, clamps, and attachments as required to properly support piping from building structure.
- B. Install building attachments within concrete or to structural steel. Install additional attachments at concentrated loads, including valves, flanges, guides, strainers, expansion joints, and at changes in direction of piping.
- C. Install hangers and support complete with necessary inserts, bolts, rods, nuts, washers and other accessories.
- D. Install hangers and supports to allow controlled movement of piping systems, permit freedom of movement between pipe anchors, and facilitate action of expansion joints, expansion loops, expansion bends and similar units.
- E. Install hangers and supports so that piping live and dead loading and stresses from movement will not be transmitted to connected equipment.
- F. Support horizontal piping as follows:

<u>PIPE SIZE</u>	<u>HANGER SPACING</u>	<u>MAXIMUM DIAMETER</u>
1/2 to 1-1/4 inch	6'-6"	3/8"
1-1/2 to 2 inch	10'-0"	3/8"
2-1/2 to 3 inch	10'-0"	1/2"
4 to 6 inch	10'-0"	5/8"
Waste Pipe	5'-0"	3/8"

- G. Install hangers to provide minimum 1/2 inch space between finished covering and adjacent work
- H. Place a hanger within 12 inches of each horizontal elbow.
- I. Use hangers with 1 1/2 inch minimum vertical adjustment
- J. Support riser piping independently of connected horizontal piping.
- K. Hangers shall be galvanized steel or copper.

3.2 FLASHING

- A. Provide flashing and counter-flashing where piping penetrates weather-proofed walls, floors and roofs.
- B. Flash vent and soil pipes projecting six (6) inches minimum above finished roof surface with lead worked one (1) inch minimum into hub. For pipes through outside walls, turn

Brunswick County (US17) Rest Area Renovations

flanges back into wall and caulk, metal counter-flash and seal.

3.3 SLEEVES

- A. Size sleeves large enough to allow for movement due to expansion and contraction. Provide for continuous insulation wrapping.
- B. Design hangers without disengagement of supported pipe
- C. Where piping penetrates floor, ceiling, or wall, close off space between pipe and adjacent work with fire stopping insulation and caulk seal air-tight. Provide close fitting metal collar or escutcheon covers at both sides of penetration.
- D. Install chrome plated steel or stainless steel escutcheons at finished surfaces.
- E. Pipe strapping will not be allowed.

END OF SECTION 15140

SECTION 15250 - PLUMBING PIPING INSULATION

PART I - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and General Provisions of Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes Plumbing Pipe Insulation.

1.3 QUALITY ASSURANCE

- A. Fire Performance Characteristics: Conform to the following characteristics for insulation including facings, cements, and adhesives, when tested according to ASTM E 84, by UL or other testing or inspecting organization acceptable to the authority having jurisdiction. Label insulation with appropriate markings of testing laboratory.
 - 1. Interior Insulation: Flame spread rating of 25 or less and a smoke developed rating of 50 or less.
 - 2. Exterior Insulation: Flame spread rating of 75 or less and a smoke developed rating of 150 or less.

1.4 SEQUENCING AND SCHEDULING

- A. Schedule insulation application after testing of piping systems.
- B. Schedule insulation application after installation and testing of heat trace tape.

PART II - PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturers:
 - 1. Flexible Elastomeric Cellular:
 - a. Armstrong World Industries, Inc.
 - b. Halstead Industrial Products
 - c. IMCOA
 - d. Rubatex Corporation

2.2 FLEXIBLE ELASTOMERIC CELLULAR

- A. Material: Flexible expanded closed-cell structure with smooth skin on both sides.
- B. Form: Tubular materials conforming to ASTM C 534, Type I.
- C. Thermal Conductivity: 0.30 average maximum at 75 degrees F.
- D. Coating: Water based latex enamel coating recommended by insulation manufacturer.

2.3 ADHESIVES

- A. Flexible Elastomeric Cellular Insulation Adhesive: Solvent-based, contact adhesive recommended by insulation manufacturer.
- B. Lagging Adhesive: MIL-A-3316C, non-flammable adhesive in the following Classes and Grades.
 - 1. Class 1, Grade A for bonding glass cloth and tape to un-faced glass fiber insulation, sealing edges of glass fiber insulation, and bonding lagging cloth to

Brunswick County (US17) Rest Area Renovations

- un-faced glass fiber insulation.
- 2. Class 2, Grade A for bonding glass fiber insulation to metal surfaces.

PART III - EXECUTION

3.1 PREPARATION

- A. Surface Preparation: Clean, dry, and remove foreign materials such as rust, scale, and dirt.

3.2 INSTALLATION - GENERAL

- A. Select accessories compatible with materials suitable for the service. Select accessories that do not corrode, soften, or otherwise attack the insulation or jacket in either the wet or dry state.
- B. Apply insulation material, accessories, and finishes according to the manufacturer's printed instructions.
- C. Keep insulation materials dry during application and finishing.
- D. Apply insulation continuously over fittings, valves and specialties.
- E. Apply insulation with a minimum number of joints.
- F. Interior Walls and Partitions Penetrations: Apply insulation continuously through walls and partitions, except fire rated walls and partitions.
- G. Fire Rated Walls and Partitions Penetrations: Terminate insulation at penetrations through fire rated walls and partitions. Seal insulation ends with vapor barrier coating. Seal around penetration with fire stopping or fire resistant joint sealer.
- H. Hangers and Anchors: Apply insulation continuously through hangers and around anchor attachments. Install saddles, shields, and inserts as specified.
 - 1. Inserts and Shields: Cover hanger inserts and shields with jacket material matching adjacent pipe insulation.

3.3 FLEXIBLE ELASTOMERIC CELLULAR INSULATION INSTALLATION

- A. Slip insulation on the pipe before making connections wherever possible. Seal joints with adhesive. Where the slip-on technique is not possible, cut one side longitudinally and apply to the pipe. Seal seams and joints with adhesive.
- B. Valves, Fittings, and Flanges: Cut insulation segments from pipe or sheet insulation. Bond to valve, fitting, and flange and seal joints with adhesive.
 - 1. Miter cut materials to cover soldered elbows and tees.
 - 2. Fabricate sleeve fitting covers from flexible elastomeric cellular insulation for screwed valves, fittings, and specialties. Miter cut materials. Overlap adjoining pipe insulation.

3.4 FINISHES

- A. Flexible Elastomeric Cellular Insulation: After adhesive has fully cured, apply 2 coats of protective coating to exposed insulation.

Brunswick County (US17) Rest Area Renovations

3.5 PIPE INSULATION SCHEDULES

<u>PIPING</u>	<u>THICKNESS TYPE</u>	<u>INSULATION IN INCHES</u>
Domestic Hot Water Supply	ELASTOMERIC	1/2
Domestic Hot Water Re-Circulating	ELASTOMERIC	1
Domestic Cold Water	ELASTOMERIC	1/2
"P" Trap at Handicapped Fixtures	ELASTOMERIC	1/2 *
(* provide pre-formed insulation kits for the drain and supply lines)		

END OF SECTION 15250

SECTION 15410 - PLUMBING PIPING

PART I - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and General Provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes plumbing piping systems to a point shown on the civil drawings. Systems include the following:
 - 1. Potable water distribution, including cold and hot water supply and hot water circulation.
 - 2. Sanitary Drainage and Vent Systems.

1.3 SYSTEM PERFORMANCE REQUIREMENTS

- A. Provide components and installation capable of producing piping systems with the following minimum working pressure ratings, except where indicated otherwise:
 - 1. Water Distribution Systems, Below Ground: 150 psig.
 - 2. Water Distribution Systems, Above Ground: 125 psig.
 - 3. Soil, Waste and Vent Systems: 10-foot head of water

PART II - PRODUCTS

2.1 SANITARY SEWER PIPING - BURIED

- A. Sch. 40 PVC Pipe: ASTM D2665. Fittings: PVC. Joints: ASTM D2564, solvent weld.

2.2 SANITARY SEWER PIPING - ABOVE GRADE

- A. Sch. 40 PVC Pipe: ASTM D2665. Fittings: PVC. Joints: ASTM D2564, solvent weld.

2.3 WATER PIPING - BURIED

- A. Copper Tubing: ASTM B88, Type K, annealed. Fittings: ANSI/ASME B16.29, wrought copper. Joints: ANSI/ASTM B32, solder, Grade 95TA.

2.4 WATER PIPING - ABOVE GRADE

- A. Copper Tubing: ASTM B88, Type L, hard drawn. Fittings: ANSI/ASME B16.23, cast brass, or ANSI/ASME B16.29, wrought copper. Joints: ANSI/ASTM B32, solder, Grade 95TA.

2.5 MANUFACTURERS

- A. Acceptable Manufacturers-Valves:
 - 1. Crane
 - 2. Grinnell
 - 3. Nibco
 - 4. Apollo

Brunswick County (US17) Rest Area Renovations

2.6 GATE VALVES

- A. 150 psig rated, bronze body, lever ball type, Apollo or equal.

PART III - EXECUTION

3.1 PREPARATION

- A. Ream pipe and tube ends. Remove burrs. Bevel plain end ferrous pipe.
- B. Remove scale and dirt, on inside and outside, before assembly.
- C. Prepare piping connections to equipment with flanges or unions.

3.2 INSTALLATION

- A. Provide non-conducting dielectric connections wherever jointing dissimilar metals.
- B. Route piping in orderly manner and maintain gradient.
- C. Install piping to conserve building space and not interfere with use of space.
- D. Group piping whenever practical at common elevations.
- E. Install piping to allow for expansion and contraction without stressing pipes, joints, or connected equipment.
- F. Provide clearance for installation of insulation and access to valves and fittings.
- G. Slope water piping and arrange to drain at low points
- H. Establish elevations of buried piping outside the building to ensure not less than 1 ft of cover.
- I. Where pipe support members are welded to structural building framing, scrape, brush clean, and apply one coat of zinc rich primer to welding.
- J. Prepare pipe, fittings, supports, and accessories not pre-finished, ready for finish painting.
- K. Establish invert elevations, slopes for drainage to 1/8 inch per foot minimum. Maintain gradients.
- L. Excavate in accordance with Sections 15010.
- M. Backfill in accordance with Sections 15010
- N. Install bell and spigot pipe with bell end upstream
- O. Copper piping 2" and larger shall be silver-soldered.
- P. Install valves with stems upright or horizontal, not inverted.

3.3 APPLICATION

- A. Install unions downstream of valves and at equipment or apparatus connections.
- B. Install brass male adapters each side of valves in copper piped system. Sweat solder adapters to pipe.
- C. Install gate or ball valves for shut-off and to isolate equipment, part of systems, or vertical risers.
- D. Install globe or ball valves for throttling, bypass, or manual flow control services.

3.4 DISINFECTION OF DOMESTIC WATER PIPING SYSTEM

- A. Prior to starting work, verify system is complete, flushed and clean.
- B. Inject disinfectant solution containing 100 ppm of available chlorine and allow to stand for 2 hours before flushing.
- C. Flush disinfectant from system until residual is equal to that of incoming water or 1.0 mg/L.
- D. Take samples from outlets and analyze in accordance with AWWA C601. Contractor shall engage an independent laboratory to conduct bacteriological and post chlorination tests certifying that the water meets the quality of drinking water. After acceptance by the Engineer of Record, "The Water Test Report for Use" is

Brunswick County (US17) Rest Area Renovations

required to be submitted to SCO prior to requesting the Occupancy Permit.

3.5 SERVICE CONNECTIONS

- A. Provide new sanitary sewer services. Before commencing work check invert elevations required for sewer connections, confirm inverts and ensure that these can be properly connected with slope for drainage and cover to avoid freezing.

END OF SECTION 15410

SECTION 15430 - PLUMBING SPECIALTIES

PART I - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and General Provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes Plumbing Specialties for water distribution systems; and soil, waste and vent systems.

1.3 SUBMITTALS

- A. General: Submit the following in accordance with Conditions of Contract and Division 1 Specification Sections.
- B. Submit product data including rated capacities of selected models and weights (shipping, installation, and operation). Indicate materials, finishes, dimensions, required clearances, and methods of assembly of components; and piping and wiring connections.

PART II - PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturers:
 - 1. Backflow Preventers:
 - a. Ames Co., Inc.
 - b. Hersey Products, Inc., Grinnell Corp.
 - c. Watts Regulator Co.
 - d. Wilkins Regulator Div., Zurn Industries, Inc.
 - 2. Water Pressure Regulators:
 - a. Spence Engineering Co., Inc.
 - b. Watts Regulator Co.
 - c. Wilkins Regulator Div., Zurn Industries, Inc.
 - 3. Specialties:
 - a. Josam Co.
 - b. Smith by Jay R. Smith Mfg. Co. Div., Smith Industries, Inc.
 - c. Watts Regulator Co.
 - d. Woodford Manufacturing Co. Div., WCM Industries, Inc.
 - e. Zurn by Hydromechanics Div., Zurn Industries, Inc.

2.2 CLEANOUTS

- A. Exterior Surfaced Areas: Round cast nickel-bronze access frame and non-skid cover.
- B. Exterior Un-Surfaced Areas: Line type with lacquered cast iron body and round epoxy coated gasketed cover.
- C. Interior Finished Floor Areas: Lacquered cast iron, two piece body, round with scoriated cover in service areas and round with depressed cover to accept floor finish in finished floor areas.
- D. Interior Finished Wall Areas: Line type with lacquered cast iron body and round epoxy coated gasketed cover, and round stainless steel access cover secured with machine screw.

2.3 WATER HAMMER ARRESTORS

- A. ANSI A112.26.1; sized in accordance with PDI WH-201, pre-charged suitable for operation in temperature range -100 to 300 degrees F and maximum 250 psig working pressure.

2.4 TRAP SEAL PRIMER VALVE:

- A. ASSE 1018; water supply fed type, fully automatic 125psig minimum working pressure, Bronze body with atmospheric vented drain chamber, ½ inch threaded or solder joint inlet and outlet connections, Chrome plated, or rough bronze finish. Unit shall be capable of being located on any active water line.

2.5 BACKFLOW PREVENTERS

- A. Reduced Pressure Back-flow Preventers: ANSI/ASSE 1013; bronze body with bronze and plastic internal parts and stainless steel springs; two independently operating, spring loaded check valves; diaphragm type differential pressure relief valve located between check valves; third check valve which opens under back pressure in case of diaphragm failure; non-threaded vent outlet; assembled with two gate valves, strainer, and four test cocks.

PART III - EXECUTION

3.1 PREPARATION

- A. Coordinate construction areas to receive drains to the required invert elevations.

3.2 INSTALLATION AND APPLICATION

- A. Install specialties in accordance with manufacturer's instructions to permit intended performance.
- B. Extend clean-outs to finished floor. Lubricate threaded clean-out plugs Teflon pipe dope. Ensure clearance at clean-out for rodding of drainage system.
- C. Encase exterior clean-outs in concrete flush with grade.
- D. Install water hammer arrestors complete with accessible isolation valve.

END OF SECTION 15430

SECTION 15440 – PLUMBING FIXTURES

PART I - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and General Provisions of Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes plumbing fixtures and trim, fittings, and accessories, appliances, appurtenances, equipment, and supports associated with plumbing fixtures.

1.3 SUBMITTALS

- A. General: Submit the following in accordance with Conditions of Contract and Division 1 Specification Sections.
- B. Product data for each type of plumbing fixture specified, including fixture and trim, fittings, accessories, appliances, appurtenances, equipment, supports, construction details, dimensions of components, and finishes.

PART II - PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturers (or approved equal):
 - 1. Fixtures and Trim:
 - a. American Standard, Inc.
 - b. Eljer; A Household International Co.
 - c. Kohler Co.
 - 2. Stainless Steel Sinks:
 - a. Elkay Manufacturing Co.
 - b. Just Manufacturing Co.
 - c. Kohler Co.
 - 3. Mop Basins:
 - a. Crane Plumbing/Fiat Products.
 - b. Florestone Products Co., Inc.
 - c. Swan Corp.
 - 4. Water Coolers:
 - a. Elkay Manufacturing Co.
 - b. Halsey Taylor
 - c. Haws Drinking Faucet Co.
 - d. Sunroc Corporation
 - e. Oasis
 - 5. Toilet Seats:
 - a. Bemis Mfg. Co.
 - b. Beneke Division: Sanderson Plumbing Products, Inc.
 - c. Church Seat Co.
 - d. Kohler Co.
 - e. Olsonite Corp.
 - 6. Flushometers:
 - a. Coyne & Delaney Co.
 - b. Sloan Valve Co.
 - c. Zurn Industries, Inc.; Flush Valve Operations.

Brunswick County (US17) Rest Area Renovations

7. Commercial/Industrial Cast-Brass Faucets:
 - a. American Standard, Inc.
 - b. Chicago Faucet Co.
 - c. Delta Faucet Co.
 - d. Eljer; A Household International Co.
 - e. T & S Brass and Bronze Works, Inc.
 - f. Cambridge Brass
 - g. Elkay Manufacturing Co.
 - h. Sloan
 - i. Speakman Co.
8. Commercial/Institutional Shower and Bathtub Valves and Trim:
 - a. Symmons Industries, Inc.
 - b. Bradley Corp.
 - c. Speakman Co.
 - d. Delta Faucet Co.

END OF SECTION 15440

DIVISION 15B: MECHANICAL

15500	Basic Mechanical Requirements
15501	Hangers and Supports
15513	Refrigerant Piping
15870A	Power Ventilators
15891A	Metal Ductwork
15910	Duct Accessories
15932	Air Outlets and Inlets

SECTION 15500 BASIC MECHANICAL REQUIREMENTS

PART I - GENERAL

1.1 GENERAL CONDITIONS

- A. The Stipulations and Conditions stated in this Section, together with all provisions of the "Instructions to Bidders", "General Conditions", "Supplemental General Conditions", and "Special Conditions", herein before set forth, shall apply to this and the other Sections of Division 15.

1.2 GENERAL REQUIREMENTS

- A. The General Requirements hereinafter listed apply to the Mechanical Work Division. If there is any conflict between the General Requirements and the General Conditions, the General Conditions shall take precedence.

1.3 ALTERNATES

- A. Carefully examine all Alternates at the back of this Specification to determine if any work described under the Mechanical Section will be affected thereby.

1.4 INTENT

- A. The intent of these Drawings and Specifications are to describe the installation of a complete, fully adjusted, and operational system. Therefore, any items shown on Drawings and not specifically called for in the Specifications, or any items specified and not specifically indicated or detailed on the Drawings, or any items neither specified or shown, but which are reasonably incidental to and commonly required to make a complete job, will be furnished and installed by the Mechanical Contractor at his own expense.

1.5 DEFINITIONS

- A. The Mechanical Contractor shall provide all supervision, labor, material equipment, machinery, plant, and any and all other items necessary to complete the mechanical systems. All items of equipment are specified in the singular; however, the Mechanical Contractor shall provide the number of items of equipment as indicated on the Drawings, and as required for complete systems.

Where the word "provide" is used, it shall mean "furnish and install complete and ready to use".

1.6 VISIT TO THE SITE

- A. The Mechanical Contractor shall visit the site before submitting his bid, so as to be thoroughly familiar with the job conditions and/or peculiarities. No extra payment will be allowed for anything that could have been anticipated from a visit to the site.

1.7 REGULATORY REQUIREMENTS

- A. All work under this Section shall be accomplished in strict accordance with State codes. Where these Plans and Specifications conflict with such codes, the codes shall govern. The Mechanical Contractor shall notify the Architect or Engineer of such conflicts in writing prior to receipt of bids.

1.8 PERMITS AND FEES

- A. The Mechanical Contractor shall make all necessary arrangements, obtain all necessary approval, obtain all permits and pay fees required for the installation of any of the work covered under the Mechanical Work Division of the Specifications. Any fees required by any utility companies or municipal authorities for the final connections for these services shall be paid by the Mechanical Contractor under whose work such services appear. Before the job is certified as substantially complete, a Certificate of Approval from all authorities involved must be obtained and turned over to the Architect/Engineer.

1.9 DRAWINGS AND SPECIFICATIONS

- A. The Mechanical Drawings and Specifications are intended to cover all the work enumerated under the respective headings. The drawings are diagrammatic only. No Contractor shall take advantage of conflict or error between Drawings and Specifications, or between general Drawings and Mechanical, Plumbing and/or Electrical Drawings, but shall request a clarification of such from the Architect/Engineer, should this condition exist. If there is insufficient time to issue an Addendum for this clarification, the Mechanical Contractor shall figure on the most expensive of the items in conflict.
- B. The Mechanical Contractor shall refer to the Architectural and Structural Drawings and Specifications for the general construction of the building, for floors and ceiling heights, for locations of walls, partitions, beams, etc., and shall be guided accordingly for setting of all sleeves, inserts and equipment. No Contractor shall under any circumstances scale Drawings for the location of equipment. The Mechanical Contractor shall verify the locations of all utility services.
- C. The Mechanical Contractor shall keep at least one (1) set of corrected Shop and Design Drawings at the site. Drawings are to be current, denoting approved modifications and actual installed departure. Submit drawings to Architect/Engineer before final payment is made.

1.10 SUPERVISION

- A. The Mechanical Contractor performing the work specified shall be required to employ a qualified superintendent or foreman to continuously supervise the installation of their work, with authorization to act as agent Contractors. He shall be capable of checking layouts, coordinating and supervising the work, establishing grades and levels and locating chases, openings, hangers, inserts, sleeves, etc.

PART II - PRODUCTS

2.1 STANDARD PRODUCTS

- A. Unless otherwise indicated in writing by the Architect/Engineer, the materials to be provided under this Specification shall be standard products of manufacturers regularly engaged in the production of such equipment and shall be the manufacturer's latest design. All items of the same type or rating shall be identical.

2.2 SUBMITTAL

- A. The Mechanical Contractor shall submit, for approval, detailed Shop Drawings on all major equipment and where requested. No materials or equipment may be delivered to the job site or installed until the Mechanical Contractor has in his possession the approved shop drawing for the particular material or equipment. The Mechanical Contractor shall furnish the number of copies required by the General or Special Conditions of the contract, but in no case less than six (6) copies.

Brunswick County (US17) Rest Area Renovations

- B. Submitted material shall be properly labeled indicating specific Service for which material or equipment to be used, Section and Article Number of Specifications governing, Contractor's name and name of job.
- C. Approval of equipment will not relieve the Mechanical Contractor of compliance with the specifications even if such approval is made in writing, unless the attention of the Engineer is called to the non-complying features by letter accompanying the submittal data. Approval of submittal data by the Engineer shall not be construed as a complete check of approval of detailed dimensions, weights, gauges and similar details with the proposed articles. The conformance with the necessary coordination between the various other contractors and suppliers shall be solely the responsibility of the Mechanical Contractor and with no additional expense to the Owner.

2.3 SUBSTITUTIONS

- A. Manufacturer's lists are to establish a Standard of Quality and not intended to limit the selection to these manufacturers. All materials and equipment which are essential and have not been specified or shown shall be new and of the highest grade and quality. Free from defect or other imperfections. It should be understood that where the words "furnished and installed" are used, it is intended that the Mechanical Contractor shall purchase and install all materials required.
- B. All materials and equipment proposed as substitutes for these specified shall require a ten (10) day prior approval from the Engineer prior to the bid date. No substitutions will be allowed after the ten (10) day period before the bid date.

2.4 PRODUCT HANDLING

- A. Equipment and materials shall be properly stored, adequately protected, and carefully handled to prevent damage before and during installation. Equipment and materials shall be handled, stored and protected in accordance with the manufacturer's recommendations and as approved by the Architect/Engineer. Equipment installed with a factory finish shall be fully protected during construction and shall be maintained free of dust, dirt, and foreign matter. Dents and other surface damage shall be repaired or replaced to the satisfaction of the Architect/Engineer at no additional cost to the Owner
- B. The Mechanical Contractor shall clean up and remove from the job site all waste materials, packaging, crating, and refuse resulting from his work on a daily basis.

2.5 MATERIALS AND WORKMANSHIP

- A. The Mechanical Contractor shall perform a first class job, both in material and workmanship. None other will be accepted. Deviations from either will be corrected by the Mechanical Contractor at the Mechanical Contractor's expense.
- B. The material used throughout the work, except when otherwise noted, shall be new and of the best of its kind. No substitutes shall be used unless approved by the Architect/Engineer. All work shall be executed with a maximum speed consistent with safety and good workmanship.
- C. Any equipment furnished by the Mechanical Contractor that is larger than those indicated on the Drawings and described in these Specifications or have different electrical characteristics, the increase in cost to the Electrical Contractor for larger wires, conduit, circuit breakers, switches, etc. or for changes in work already installed shall be borne by the instigating Contractor.

PART III - EXECUTION

3.1 EXCAVATION AND BACKFILL

- A. The Mechanical Contractor shall preform any and all trench and pit excavation and

Brunswick County (US17) Rest Area Renovations

backfilling required for the installation of his work. Trenches shall be made with the sides vertical and shall be shored where necessary for the protection of men and equipment. All excavation work shall be done in a careful manner to avoid damage to footers and foundations. The backfilling shall be placed in layers not exceeding four (4) inches in depth, wetting each layer as it is placed, and thoroughly compacting each layer with mechanical tamper or other approved means. Any damage done during excavation and back-filling operations to roads, sidewalks, curbs, shrubs, sod, footers, foundations, etc. shall be replaced to its condition prior to construction at no expense to the Owner.

3.2 SCAFFOLDING, RIGGING AND HOISTING

- A. The Mechanical Contractor shall furnish all necessary scaffolding, staging, rigging and hoisting required for the completion of his work. All such scaffolding, etc., shall be removed from the premises when its use is no longer required on the job.

3.3 CUTTING AND PATCHING

- A. The Mechanical Contractor shall provide all cutting and patching necessary to install the work specified in this Section. The patching shall match adjacent surfaces.
- B. No Structural member shall be cut without the approval of the Engineer and all such cutting shall be done in a manner directed by him.

3.4 EQUIPMENT SPACE AND ARRANGEMENT

- A. The equipment shall fit into the space allotted and shall allow adequate clearance for entry, installation, replacement, servicing and maintenance. The Mechanical Contractor shall coordinate the work to ensure that equipment may be moved into place without altering building components or other installations. Access space shall not be less than the equipment manufacturer's requirements.
- B. These drawings indicate the extent and general arrangement of equipment, piping, and ductwork. If any departures are deemed necessary by the Mechanical Contractor, details of such departures and the reasons therefore shall be submitted to the Architect/Engineer for approval as soon as practicable and within 30 days after Award of Contract. No departure shall be made without written Approval of the Architect/Engineer.

3.5 DAMAGE TO WORK ALREADY IN PLACE

- A. The Mechanical Contractor shall assume full responsibility for any damage done by him, his agents or employees, to any work already in place. Any such damage done shall be repaired at the Contractor's expense by mechanics skilled at their respective trades, to the approval of the Architect/Engineer.

3.6 JURISDICTION OF WORK

- A. It may become necessary for the Mechanical Contractor to furnish labor or material which is not generally accepted as part of this trade. In cases of this type, he shall contract the work, or shall furnish materials and employ workmen of the trade involved in order not to cause any delay or stoppage of work caused by infringement of trade agreements as to jurisdiction, alleged or actual.

3.7 COORDINATION WITH OTHER TRADES

- A. All work shall be coordinated with other trades involved in the construction project. All work shall be carefully laid out in advance to coordinate Architectural, Structural, Mechanical, Plumbing and Electrical features of construction. The Contractor shall verify at the site all locations, grades, elevations, and utility service connections indicated. Any

Brunswick County (US17) Rest Area Renovations

conflicts due to lack of proper coordination shall be brought to the attention of the Architect/Engineer for resolution. The Mechanical Contractor shall make required changes or relocations at no additional cost to the Owner.

- B. Installation, inspection, and testing of work above ceilings shall be completed and approved by the Architect/Engineer prior to installation of the specified finished ceilings. However, ceiling suspension system may be installed as required for coordination.
- C. The Mechanical Contractor shall consult with the other trades at the start of the work and periodically thereafter, as required to properly coordinate the various items of work, and to avoid interferences. Should any interferences of any nature develop as the work progresses, such interferences shall be resolved and eliminated as directed. The cost of any work directed will be borne by the subcontractor or contractors directed to do this work.

3.8 DIVISION OF WORK

- A. This paragraph is intended to show exactly the point of division of work between the Electrical Division and the Mechanical Division.
- B. All equipment covered in the Mechanical Division of the Specifications shall be furnished, mounted and aligned under the Mechanical Division. All individual motor starters, unless indicated as part of a motor control center, for this equipment shall be furnished and installed by the Mechanical Contractor.
- C. All final electrical connections to equipment covered in the Mechanical Division of the Specifications shall be completed under the Mechanical Division.
- D. The Electrical Contractor shall provide a disconnect switch or junction box for each item of equipment under Division 16.
- E. Electrical equipment and wiring that is provided by the Mechanical Contractor shall be in accordance with the Electrical specification.

3.9 EQUIPMENT INSTALLATION

- A. Final connections to equipment, including pipe, duct, and controls, shall be provided under applicable sections of this Division, unless otherwise specified or indicated.
- B. Manufacturer's Instructions: Equipment shall be installed as recommended by the manufacturer to conform to the requirements of the particular application, in accordance with these Drawings and Specifications.

3.10 OPERATION AND MAINTENANCE MANUALS

- A. One complete Manual as outlined herein shall be submitted for approval before conducting instruction sessions in operation, before systems or equipment tests are performed, and before final or beneficial occupancy.
- B. Manuals shall have rigid covers and index tabs for each major piece of equipment, auxiliaries, and systems. The following shall be inscribed on the cover: the words "OPERATION AND MAINTENANCE MANUAL", the name and location of the building, the name of the Section, such as "Heating" and the name of the Mechanical Contractor. Two (2) copies of each approved manual shall be submitted to the Owner and one (1) copy shall be submitted to the Architect/Engineer.
- C. Each piece of equipment shall be listed and identified with the same name, mark, number, or other identification as noted or scheduled in the Contract Documents.
- D. Manuals shall include the following:
 - 1. Complete Operating Installations, covering start-up and shutdown for all components installed.
 - 2. Legible copies of all Shop Drawings. Any comments incorporated in "as noted" approvals of Shop Drawings shall be recorded on the Drawings included in the Manuals.
 - 3. All equipment Maintenance and Service Manuals.
 - 4. A complete parts list for each piece of equipment.

Brunswick County (US17) Rest Area Renovations

5. All descriptive literature for the equipment.
6. Operating characteristics, performance data, ratings, and curves for each piece of equipment such as condensers, fans and air handling units.
7. Internal wiring and control diagrams.
8. Automatic temperature control diagrams, part descriptions and numbers, and sequences of operation. Drawings shall be neatly folded and inserted in a separate clear plastic binder. The plastic binders shall be bound in the back of each Manual.
9. Final Testing and Balancing Reports.
10. All other information pertinent to the maintenance and servicing of equipment and systems provided in the Project.
11. Name, address, and telephone number for service on each manufacturer's equipment.

3.11 OPERATING INSTRUCTIONS

- A. After all equipment and services are in operation, and the Operation and Maintenance Manuals are available, an instruction and training session shall be conducted for the Owner's operating personnel.
- B. Instruction sessions shall be conducted during the Owner's normal working periods, and at times and locations satisfactory to the Owner.

3.12 EQUIPMENT START-UP

- A. No equipment shall be placed in operation until it has been inspected by a qualified representative of the manufacturer and certified to be ready for operation. The manufacturer's representative shall supervise the start-up operation and shall be responsible for all adjustments are required to meet design conditions. Such services shall be at no additional cost to the Owner.

3.13 GUARANTEE

- A. The Mechanical Contractor shall present to the Owner a written Guarantee covering his work, including all equipment, material and workmanship. This Guarantee shall be against all defects in any of the above work, and shall run for a period of one (1) year from the date of written acceptance of the Contractor's work.
- B. Any defective work, equipment, material and/or workmanship that develops within the Guarantee period, which is not caused by ordinary wear or abuse by other persons, shall be replaced by the Mechanical Contractor without cost to the Owner.

3.14 FINAL INSPECTION

- A. When the entire Contract has been completed and the work is ready for final inspection, the Architect/Engineer or his duly authorized representative will make the inspection. At the time of inspection, the Mechanical Contractor shall demonstrate to the Architect/Engineer that the various systems and pieces of equipment have been adjusted to operate in accordance with the requirements of the Contract.

3.15 FINAL PAYMENTS

- A. All Final Payments are contingent upon all necessary Certificates and/or Approvals cited above, together with the written Guarantee being presented to the Owner.

END OF SECTION 15500

SECTION 15501 - HANGERS AND SUPPORTS

PART I - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawing and General Provisions of the Contract, including the General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- B. This Section includes Hangers and Supports for Mechanical Systems Piping and Equipment.

PART II - PRODUCTS

2.1 PIPE HANGERS AND SUPPORTS

- A. Hangers: Galvanized carbon steel, adjustable, clevis.
- B. Copper Pipe Support: Carbon steel ring, adjustable, copper plated.
- C. Shield for Insulated Piping 2 Inches and Smaller: 18 gage galvanized steel shield over insulation in 180 degree segments, minimum 12 inches long at pipe support.

2.2 HANGER RODS

- A. Steel Hanger Rods: Threaded both ends or continuous threaded.

2.3 FLASHING

- A. Metal Flashing: 26 gage galvanized steel.
- B. Flexible Flashing: 47 mil thick sheet butyl; compatible with roofing.

2.4 SLEEVES

- A. Sleeves for Pipes: Form with schedule 40, galvanized steel pipe
- B. Sleeves for Pipes Through Fire Rated and Fire Resistive Floors and Walls, and Fireproofing: Prefabricated fire rated sleeves including seals, UL listed.
- C. Sleeves for Round Ductwork: Form with galvanized steel.
- D. Sleeves for Rectangular Ductwork: Form with galvanized steel or wood.
- E. Fire Stopping Insulation: Glass fiber type, non-combustible.
- F. Caulk: Fire Barrier type sealant.

2.5 MISCELLANEOUS MATERIALS

- A. Structural Steel: ASTM A 36/A 36M, steel plates, shapes, and bars, black and galvanized.
- B. Bolts and Nuts: ASME B18.10 or ASTM A 183, steel, hex-head, track bolts and nuts.
- C. Washers: ASTM F 844, steel, plain, flat washers.

2.6 ATTACHMENTS

- A. Mechanical-Anchor Fasteners: Insert-type attachments with pull-out and shear capacities appropriate for supported loads and building materials where used. Permitted in concrete over 4 inches thick.

Brunswick County (US17) Rest Area Renovations

- B. Beam Clamps: Types 20, 21, 28 or 29
- C. Wood: Wood screws or lag bolts

PART III - EXECUTION

3.1 HANGERS AND SUPPORTS INSTALLATION

- A. Install hangers, supports, clamps, and attachments as required to properly support piping from building structure.
- B. Install building attachments within concrete or to structural steel. Install additional attachments at concentrated loads, including valves, flanges, guides, strainers, expansion joints, and at changes in direction of piping.
- C. Install hangers and support complete with necessary inserts, bolts, rods, nuts, washers, and other accessories.
- D. Install hangers and supports to allow controlled movement of piping systems, permit freedom of movement between pipe anchors, and facilitate action of expansion joints, expansion loops, expansion bends, and similar units.
- E. Install hangers and supports so that piping live and dead loading and stresses from movement will not be transmitted to connected equipment.
- F. Support horizontal piping as follows:

<u>PIPE SIZE</u>	<u>HANGER SPACING</u>	<u>MAXIMUM HANGER DIAMETER</u>
1/2 to 1-1/4 inch	6' - 6"	3/8"
1-1/2 to 2 inch	10' - 0"	3/8"

- G. Install hangers to provide minimum 1/2 inch space between finished covering and adjacent work.
- H. Place a hanger within 12 inches of each horizontal elbow.
- I. Use hangers with 1 1/2 inch minimum vertical adjustment.
- J. Support vertical piping at every floor.
- L. Support riser piping independently of connected horizontal piping.
- M. All pipe hangers shall be galvanized steel or copper.
- N. Pipe strapping, duct tape or zip ties will not be allowed.

3.2 EQUIPMENT BASES AND SUPPORTS

- A. Provide equipment bases of concrete.
- B. Provide templates, anchor bolts, and accessories for mounting and anchoring equipment.

3.3 EQUIPMENT SUPPORTS

- A. Fabricate structural steel stands to suspend equipment from structure above or support equipment above floor.
- B. Grouting: Place grout under supports for equipment, and make a smooth bearing surface.

3.4 METAL FABRICATION

- A. Cut, drill, and fit miscellaneous metal fabrications for pipe and equipment supports.
- B. Fit exposed connections together to form hairline joints. Field weld connections that cannot be shop welded because of shipping size limitations.
- C. Field Welding: Comply with AWS D1.1 procedures for manual shielded metal arc welding, appearance and quality of welds.

Brunswick County (US17) Rest Area Renovations

3.5 FLASHING

- A. Provide flexible flashing and metal counter-flashing where piping and ductwork penetrate weather or waterproofed walls, floors, and roofs.
- B. Provide curbs for mechanical roof installations 14 inches minimum high above roofing surface. Flexible sheet flash and counter-flash with sheet metal; seal watertight.

3.6 SLEEVES

- A. Size sleeves large enough to allow for movement due to expansion and contraction. Provide for continuous insulation wrapping.
- B. Design hangers without disengagement of supported pipe.
- C. Where piping penetrates floor, ceiling, or wall, close off space between pipe and adjacent work with fire stopping insulation and caulk seal air tight. Provide close fitting metal collar or escutcheon covers at both sides of penetration.
- D. Install chrome plated steel or stainless steel escutcheons at finished surfaces.

END OF SECTION 15501

SECTION 15513 – REFRIGERANT PIPING

PART I - GENERAL

1.1 GENERAL

- A. This section includes all pipe, pipe fittings, hangers, supports, etc. as may be required to provide a complete refrigerant piping system.
- B. Testing of all piping shall be made in the presence of a designated representative of the owner. No piping shall be covered or put into operation before such testing has been approved.
- C. The actual arrangement of the piping shall follow the general locations shown on the drawings such that clearances, line drainage, etc. shall be maintained.

PART II - PRODUCTS

2.1 PIPING

- A. Refrigerant piping shall be type “ACR” hard drawn copper conforming to ANSI B-31.5 or ASTM B280.

2.2 PIPE FITTINGS

- A. Copper pipe fittings shall be wrought metal solder joint type conforming to ANSI B16.22.

PART III - EXECUTION

3.1 PIPING

- A. The installation of piping and related items shall be made neatly and in such a manner as not to interfere with access to valves or equipment.
- B. All piping shall be reamed to remove all burrs, fins and foreign material. Pipe shall be thoroughly cleaned before soldering.
- C. “Sil-Fos” or silver solder shall be used with non-corrosive flux. During the soldering operation, the pipe shall be purged with nitrogen.
- D. Piping shall be arranged (and traps installed where necessary) to allow the proper return of oil to the compressor.

3.2 HANGERS AND SUPPORTS

- A. The spacing of hangers and supports shall not exceed five feet.
- B. Pipe covering protection saddles shall be used at all supports for insulated piping. Sheet metal shields shall be 10 gauge, one half the circumference of the insulation and minimum of twelve inches long.

3.2 TESTING

- A. All refrigerant equipment not tested at the factory shall be shut off from the rest of the system and tested. Piping systems shall be tested after installation is complete and before any insulation is applied. All controls and other apparatus that may be damaged by the test pressure shall be removed before tests are made.
- B. Refrigerant lines shall be tested at 150 psig with dry nitrogen. Pressure shall be maintained for 60 minutes without loss of pressure. Each joint shall be checked for leaks with a soap solution. Testing and repair shall continue until there is no loss of pressure. After a

Brunswick County (US17) Rest Area Renovations

satisfactory pressure test, high vacuum pumps shall be connected to the system and the system evacuated to a pressure of 0.20 inches of mercury with the ambient temperature at not less than 36 degrees F. After this has been attained, the vacuum shall be broken by charging the system with refrigerant as soon as possible.

END OF SECTION 15055

SECTION 15870 - POWER VENTILATORS

PART I - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and General Provisions of Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes Power Ventilators.

1.3 SUBMITTALS

- A. General: Submit the following in accordance with Conditions of Contract and Division 1 Specification Sections:
 - 1. Product data for selected models, including specialties, accessories, and the following:
 - a. Motor ratings and electrical characteristics plus motor and fan accessories.
 - b. Materials gauges and finishes.
 - 2. Shop drawings from manufacturer detailing equipment assemblies and indicating dimensions, weights, required clearances, components, and location and size of field connections.

PART II - PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturers:
 - 1. Carnes Company, Inc.
 - 2. Cook (Loren) Co.
 - 3. Greenheck Fan Corp.
 - 4. Penn Ventilator Co., Inc.

2.2 ROOF EXHAUSTERS

- A. Centrifugal Fan Unit: V-belt driven with spun aluminum housing; resilient mounted motor, ½ inch mesh, 16 gauge aluminum bird screen; square base to suit roof curb with continuous curb gaskets; secured with cadmium plated bolts and screws.
- B. Roof Curb: 16 inch high with continuously welded seams and factory installed door nailer strip.
- C. Disconnect Switch: Factory wired, non-fusible, in housing for thermal overload protected motor.
- D. Back Draft Damper: Gravity activated, aluminum multiple blade construction, felt edged with nylon bearings.
- E. Sheaves: Cast iron or steel, dynamically balanced, bored to fit shafts and keyed; variable and adjustable pitch motor sheave selected so required rpm is obtained with sheaves set at mid-position; fan shaft with self-aligning pre-lubricated ball bearings.

2.3 WALL EXHAUSTERS

- A. Centrifugal Fan Unit: V-belt driven with spun aluminum housing; resilient mounted motor, ½ inch mesh, 16 gauge aluminum bird screen; secured with cadmium plated bolts and

Brunswick County (US17) Rest Area Renovations

- screws.
- B. Disconnect Switch: Factory wired, non-fusible, in housing for thermal overload protected motor.
- C. Back Draft Damper: Gravity activated, aluminum multiple blade construction, felt edged with nylon bearings.
- D. Sheaves: Cast iron or steel, dynamically balanced, bored to fit shafts and keyed; variable and adjustable pitch motor sheave selected so required rpm is obtained with sheaves set at mid-position; fan shaft with self-aligning pre-lubricated ball bearings.

2.4 CEILING EXHAUST FANS

- A. Centrifugal Fan Unit: V-belt or direct drive with galvanized steel housing lined with ½ inch acoustic insulation, resilient mounted motor, gravity back draft damper in discharge.
- B. Disconnect Switch: Factory wired, non-fusible, in housing for thermal overload protected motor.
- C. Grille: Molded white plastic or aluminum with baked white enamel finish.
- D. Sheaves: Cast iron or steel, dynamically balanced, bored to fit shafts and keyed; variable and adjustable pitch motor sheaves selected so required RPM is obtained with sheaves set at mid-position; fan shaft with self-aligning pre-lubricated ball bearings.

2.5 IN-LINE CABINET EXHAUST FANS

- A. Centrifugal Fan Unit: V-belt or direct driven, with galvanized steel housing lined with ½ inch acoustic insulation, resilient mounted motor, gravity back draft damper in discharge.
- B. Disconnect Switch: Factory wired, non-fusible, in housing for thermal overload protected motor.
- C. Sheaves: Cast iron or steel, dynamically balanced, bored to fit shafts and keyed; variable and adjustable pitch motor sheaves selected so required RPM is obtained with sheaves set at mid-position; fan shaft with self-aligning pre-lubricated ball bearings.

2.6 ROOF SUPPLY FAN

- A. Fan Unit: Direct driven axial type, aluminum hood, bird screen, die formed aluminum propeller blades riveted to steel hub, resilient mounted motor square base to suit roof curb.
- B. Roof Curbs: 16 inch high, continuously welded seams, and factory door nailed strip. Roof curb shall have same manufacturer as fan and be supplied by Mechanical Contractor and installed by the General Contractor.
- C. Disconnect Switch: Factory wired, non-fusible, in housing for thermal overload protected motor.

PART III - EXECUTION

3.1 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Secure roof exhausters with lag screws to roof curb.

END OF SECTION 15870A

SECTION 15891 - METAL DUCTWORK

PART I - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and General Provisions of Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes low pressure ducts and plenums for heating, ventilating, and air conditioning systems

PART II - PRODUCTS

2.1 MATERIALS

- A. Steel Ducts: ASTM A525 or ASTM A527 galvanized steel sheet, lock-forming quality, having zinc coating of G-90 for each side in conformance with ASTM A90.
- B. Insulated Flexible Ducts: Flexible duct wrapped with flexible glass fiber insulation, enclosed by seamless aluminum pigmented plastic vapor barrier jacket; maximum 0.23 K value at 75 degrees F.
- C. Fasteners: Rivets, bolts, or sheet metal screws
- D. Sealant: Liquid non-hardening, water resistant, fire resistive, compatible with mating materials; liquid used alone or with tape, or heavy mastic.
- E. Hanger Rod: Steel, galvanized; threaded both ends, threaded one end, or continuously threaded.

2.2 LOW PRESSURE DUCTWORK

- A. Fabricate and support in accordance with SMACNA Low Pressure Duct Construction Standards and ASHRAE handbooks, except as indicated. Provide duct material, gages, re-inforcing and sealing for operating pressures indicated.
- B. No variation of duct configuration or sizes permitted except by written permission.
- C. Construct T's, bends, and elbows with radius of not less than 1½ times width of duct on center line. Where not possible and where rectangular elbows are used, provide turning vanes.
- D. Increase duct sizes gradually, not exceeding 15 degrees divergence wherever possible. Divergence upstream of equipment shall not exceed 30 degrees; convergence downstream shall not exceed 45 degrees.
- E. Connect flexible ducts to metal ducts with liquid adhesive.
- F. Use crimp joints with or without bead for joining round duct sizes 8 inch and smaller with crimp in direction of air flow.
- G. Use double nuts and lock washers on threaded rod supports.

2.3 FACTORY FABRICATED DUCTWORK

- A. Duct shall be of standard spiral lock seam or single-rib construction and shall be provided according to the gages given in the following table:

Brunswick County (US17) Rest Area Renovations

Diameter (inches)	Thickness (inches)
3 - 8	.032
9 - 14	.040
15 - 36	.050

- B. Duct shall be provided in continuous, unjoined lengths wherever possible. Except when interrupted by fittings, round duct sections.
- C. Fittings shall be round and shall have a wall thickness in accordance with the following table:

Fitting Body Diameters (inches)	Minimum Round Fitting Thickness (inches)
3-14	.040
15-26	.050
27-36	.063

- D. Elbows shall be of die-stamped, gored or pleated construction. The bend radius of stamped, gored and pleated elbows shall be 1.5 time the elbow diameter.
- E. All round elbows in diameter of 8 inches or less shall be of die-stamped or pleated construction.
- F. All round elbows in diameter of 9 inches through 14 inches shall be of gored or pleated construction.
- G. All round elbows in diameter greater than 14 inches shall be of gored construction.
- H. Diverging-flow fittings shall be constructed with a radiused entrance to all branch taps and with no excess material projecting from the body into the branch tap entrance.
- I. All take-off or branch entrances shall be by means of factory fabricated fittings.
- J. All fitting ends shall be sized to slip inside mating duct sections. They shall provide a tight fit and have a minimum 2-inch insertion length with a stop bead. No additional coupling shall be required for duct to fitting joints.

PART III - EXECUTION

3.1 INSTALLATION

- A. Factory Fabricated ductwork can be substituted for low-pressure field constructed ductwork.
- B. All factory fabricated spiral duct and fittings shall be installed in accordance with manufacturer's recommendations.
- C. Locate ducts with sufficient space around equipment to allow normal operating and maintenance activities.
- D. Connect diffusers or troffer boots to low pressure ducts with 5 feet maximum length of flexible duct. Hold in place with strap or clamp.
- E. During construction provide temporary closures of metal or taped polyethylene on open ductwork to prevent construction dust from entering ductwork system.

3.2 ADJUSTING AND CLEANING

- A. Clean duct system and force air at high velocity through duct to remove accumulated dust. To obtain sufficient air, clean half the system at a time. Protect equipment that may be harmed by excessive dirt with temporary filters or bypass during cleaning.
- B. Clean duct systems with high power vacuum machines. Protect equipment that may be harmed by excessive dirt with filters, or bypass during cleaning. Provide adequate access into ductwork for cleaning purposes.

END OF SECTION 15891

SECTION 15910 - DUCT ACCESSORIES

PART I - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and General Provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes the following:
 - 1. Not used
 - 2. Turning Vanes
 - 3. Duct Mounted Access Doors and Panels
 - 4. Flexible Connectors
 - 5. Flexible Ducts

1.3 SUBMITTALS

- A. General: Submit the following in accordance with Conditions of Contract and Division 1 Specification Sections.
- B. Product data including details for materials, dimensions of individual components, profiles, and finishes.
- C. Shop drawings from manufacturer detailing assemblies: Include dimensions, weights, loadings, required clearances, method of field assembly, components, and location and size of each field connection.

PART II - PRODUCTS

2.3 AIR TURNING DEVICES

- A. Multi-blade device with blades aligned in short dimension; steel or aluminum construction; with individually adjustable blades, mounting straps.

2.4 FLEXIBLE DUCT CONNECTIONS

- A. Fabricate in accordance with SMACNA Low Pressure Duct Construction Standards, and as indicated.
- B. Provide factory made spin-in starting collars for connections to trunk ducts.

2.5 DUCT ACCESS DOORS

- A. Fabricate in accordance with SMACNA Low Pressure Duct Construction Standards and as indicated.
- B. Review locations prior to fabrication.
- C. Fabricate rigid and close fitting doors of galvanized steel with sealing gaskets and quick fastening locking devices. For insulated ductwork, install minimum one-inch thick insulation with sheet metal cover.
- D. Access doors smaller than 12 inches square may be secured with sash locks.
- E. Provide two hinges and two sash locks for sizes up to 18 inches square, three hinges and two compression latches with outside and inside handles for sizes up to 24 x 48 inches. Provide an additional hinge for larger sizes.
- F. Access doors with sheet metal screw fasteners are not acceptable.

PART III - EXECUTION

3.1 INSTALLATION

- A. Install accessories in accordance with manufacturer's instructions.
- B. Provide balancing dampers at points on low pressure supply systems where branches are taken from larger ducts as required for air balancing. Use splitter dampers only where indicated.
- C. Provide flexible connections immediately adjacent to equipment in ducts associated with fans and motorized equipment.
- D. Provide duct access doors for inspection and cleaning before and after filters, coils, fans, automatic dampers, at fire dampers, and elsewhere as indicated. Provide minimum 8 x 8 inch size for hand access, 18 x 18 inch size for shoulder access, and as indicated.
- E. Provide duct test holes where indicated and required for testing and balancing purposes.

END OF SECTION 15910

SECTION 15932 - AIR OUTLETS AND INLETS

PART I - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and General Provisions of Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to work of this Section.

1.2 DESCRIPTION OF WORK

- A. Extent of air outlets and inlets work is indicated by Drawings and Schedules and by Requirements of this Section.
- B. Types of outlets and inlets required for this Project include the following:
 - 1. Ceiling Air Diffusers
 - 2. Wall Registers and Grilles
 - 3. Louvers

1.3 SUBMITTALS

- A. Product Data: Submit manufacturer's technical product data for air outlets and inlets including the following:
 - 1. Schedule of air outlets and inlets indicating drawing designation, room location, number furnished, model number, size and accessories furnished.
 - 2. Data sheet for each type of air outlet and inlet, and accessory furnished; indicating construction, finish and mounting details.
 - 3. Performance data for each type of air outlet and inlet furnished, throw and drop; and noise criteria ratings. Indicate selections on data.
- B. Shop Drawings: Submit manufacturer's assembly-type shop drawing for each type of air outlet and inlet, indicating materials and methods of assembly of components.

PART II - PRODUCTS

2.1 ACCEPTABLE MANUFACTURERS

- A. Diffusers & Grilles
 - 1. Titus, Inc.
 - 2. Metalaire, Inc.
 - 3. Carnes, Inc.
 - 4. E. H. Price
- B. Louvers
 - 1. Arrow United Industries, Inc.
 - 2. Louvers & Dampers, Inc.
 - 3. Penn Ventilator Co., Inc.
 - 4. Ruskin Mfg. Co.
 - 5. Safe-Air Inc.
 - 6. Vent Products Co., Inc.
 - 7. NCA
 - 8. Cesco Products

2.2 RECTANGULAR CEILING DIFFUSERS

- A. Rectangular, extruded aluminum, multi-core type diffuser to discharge air in 360 degree pattern.
- B. Provide inverted T-bar type frame. In plaster ceilings, provide plaster frame and ceiling

Brunswick County (US17) Rest Area Renovations

- frame.
- C. Fabricate of aluminum with baked enamel off-white finish.
- D. Provide opposed blade damper with damper adjustable from diffuser face.

2.3 CEILING GRID CORE EXHAUST AND RETURN REGISTERS/GRILLES

- A. Fixed grilles of 1/2 x 1/2 x 1 inch egg crate.
- B. Provide inverted T-bar type frame. In plaster ceilings, provide plaster frame and ceiling frame.
- C. Fabricate of aluminum with baked enamel off-white finish.
- D. Where not individually connected to exhaust fans, provide integral, gang-operated opposed blade dampers with removable key operator, operable from face.

2.4 WALL SUPPLY REGISTERS/GRILLES

- A. Streamlined and individually adjustable blades, depth of which exceeds 3/4 inch maximum spacing with spring or other device to set blades, horizontal face, double deflection.
- B. Fabricate 1 1/4 inch margin frame with countersunk screw mounting and gasket.
- C. Fabricate of aluminum extrusions with 20 gauge minimum frames and 22 gauge minimum blades, with baked enamel off-white finish.
- D. Provide integral, gang-operated opposed blade dampers with removable key operator, operable from face.

2.6 LOUVERS

- A. Provide 4-inch deep louvers with blades on 45 degree slope with center baffle and return bend, heavy channel frame, bird screen with 1/2 inch square mesh.
- B. Fabricate of 12-gauge extruded aluminum, welded assembly, with factory baked enamel finish. Color selection from manufacturer standard.
- C. Furnish with interior screw holes in jambs for installation.

2.7 ROOF HOODS

- A. Fabricate air inlet or exhaust hoods in accordance with SMACNA Low Pressure Duct Construction Standards.
- B. Fabricate of aluminum, minimum 16 gauge base and 18 gauge hood; suitably reinforced; with removable hood; bird screen with 1/2 inch square mesh and factory prime coat baked enamel finish.
- C. Mount unit on minimum 12-inch high curb base with insulation between duct and curb.
- D. Make hood outlet area minimum of twice throat area.

PART III - EXECUTION

3.1 INSTALLATION

- A. Install items in accordance with manufacturer's instructions.
- B. Check location of outlets and inlets and make necessary adjustments in position to conform with architectural features, symmetry and lighting arrangement.
- C. Install diffusers to ductwork with air-tight connection.
- D. Provide balancing dampers on duct take-off to diffusers, and grilles and registers, regardless of whether dampers are specified as part of the diffuser, or grille and register assembly.
- E. Paint ductwork visible behind air outlets and inlets matte black.

END OF SECTION 15932

DIVISION 16: ELECTRICAL

16010	Basic Electrical Requirements
16050	Basic Electrical Materials and Methods
16100	Raceways, Boxes and Cabinets
16120	Wires and Cables
16140	Wiring Devices
16190	Supporting Devices

SECTION 16010 - BASIC ELECTRICAL REQUIREMENTS

PART I - GENERAL

1.1 GENERAL CONDITIONS

- A. The Stipulations and Conditions stated in this Section, together with all provisions of the "Instructions to Bidders", "General Conditions", "Supplemental General Conditions" and "Special Conditions", hereinbefore set forth, shall apply to this and the other Sections of Division 16.

1.2 GENERAL REQUIREMENTS

- A. The General Requirements hereinafter listed apply to the Electrical Work Division. If there is any conflict between the General Requirements and the General Conditions, the General Conditions shall take precedence.

1.3 ALTERNATES

- A. Carefully examine all alternates at the back of this Specification and on the Drawings to determine if any work described under the Electrical Section will be affected thereby.

1.4 INTENT

- A. The intent of these Drawings and Specifications are to describe the installation of a complete, fully adjusted, and operational system. Therefore, any items shown on Drawings and not specifically called for in the Specifications, or any items specified and not specifically indicated or detailed on the Drawings, or any items neither specified or shown, but which are reasonably incidental to and commonly required to make a complete job, will be furnished and installed by the Electrical Contractor at his own expense.

1.5 DEFINITIONS

- A. The Electrical Contractor shall provide all supervision, labor, material equipment, machinery, plant, and any and all other items necessary to complete the Electrical systems. All items of equipment are specified in the singular; however, the Electrical Contractor shall provide the number of items of equipment as indicated on the drawings, and as required for complete systems.

Where the word "provide" is used, it shall mean "furnish and install complete and ready to use".

1.6 VISIT TO THE SITE

- A. The Electrical Contractor shall visit the site before submitting his bid so as to be thoroughly familiar with the job conditions and/or peculiarities. No extra payment will be allowed for anything which could have been anticipated from a visit to the site.

1.7 REGULATORY REQUIREMENTS

- A. All work under this section shall be accomplished in strict accordance with State codes. Where these plans and specifications conflict with such codes, the codes shall govern.
- B. The Electrical Contractor shall notify the Architect or Engineer of such conflicts in writing prior to receipt of bids.

Brunswick County (US17) Rest Area Renovations

- C. References to the National Electrical Code (NEC), Underwriters Laboratories, Inc. (UL), and National Fire Protection Association (NFPA) are a minimum installation requirement.
- D. The following regulatory shall be used as minimum standards:

AEIC	American Association of Edison Illuminating Companies
ANSI	American National Standards Institute
ASTM	American Society for Testing and Materials
ICEA	Insulated Cable Engineers Association
IEEE	Institute of Electrical and Electronic Engineers
NCCM	N.C. Construction Manual w/G.S. as listed
NCSBC	N.C. State Building Code
NEC	National Electrical Code
NEMA	National Electrical Manufacturers Association
NESC	National Electrical Safety Code
NFPA	National Fire Protection Association
U/L	Underwriters' Laboratories, Inc.
OSHA	Occupational Safety and Health Standards
ASHRAE/IES	90.1 energy code

1.8 TEST STANDARDS

- A. All material and equipment shall be listed, labeled or certified by a nationally recognized testing laboratory to meet Underwriters Laboratories, Inc., or third party agencies accredited by the North Carolina Building Code Councils latest edition or amendment.

1.9 PERMITS AND FEES

- A. NA

1.10 DRAWINGS AND SPECIFICATIONS

- A. The Electrical Drawings and Specifications are intended to cover all the work enumerated under the respective headings. The Drawings are diagrammatic only. No Contractor shall take advantage of conflict or error between Drawings and Specifications, or between General Drawings and Mechanical, Plumbing and/or Electrical Drawings, but shall request a clarification of such from the Architect/Engineer, should this condition exist. If there is insufficient time to issue an Addendum for this clarification, the Electrical Contractor shall include in his bid the most expensive of the items in conflict.
- B. The Electrical Contractor shall refer to the Architectural and Structural Drawings and Specifications for the general construction of the building, for floors and ceiling heights, for locations of walls, partitions, beams, etc., and shall be guided accordingly for setting of all sleeves, inserts and equipment. No Contractor shall under any circumstances scale drawings for the location of equipment. The Electrical Contractor shall verify the locations of all utility services and electrical equipment.
- C. The Electrical Contractor shall keep at least one set of corrected Shop and Design Drawings at the site. Drawings are to be current, denoting approved modifications and actual installed departure. Submit Drawings to Architect/Engineer before final payment is made.

1.11 SUPERVISION

- A. The Electrical Contractor performing the work specified shall be required to employ a qualified superintendent or foreman to continuously supervise the installation of their work, with authorization to act as agent. He shall be capable of checking layouts, coordinating and supervising the work, establishing grades and levels and locating chases, openings, hangers, inserts, sleeves, etc.

PART II - PRODUCTS

2.1 STANDARD PRODUCTS

- A. Unless otherwise indicated in writing by the Architect/Engineer, the materials to be provided under this Specification shall be standard products of manufacturers regularly engaged in the production of such equipment and shall be the manufacturer's latest design. All items of the same type or rating shall be identical.

2.2 SUBMITTAL

- A. The Electrical Contractor shall submit, for approval, detailed Shop Drawings on all major equipment and where requested. No materials or equipment may be delivered to the job site or installed until the Electrical Contractor has in his possession the approved Shop Drawing for the particular material or equipment. The Electrical Contractor shall furnish the number of copies required by the General or Special Conditions of the contract, but no case less than six (6) copies.
- B. Submitted material shall be properly labeled indicating specific service for which material or equipment is to be used, Section and Article Number of Specifications governing, Contractor's name and name of job.
- C. Approval of equipment will not relieve the Electrical Contractor of compliance with the Specifications even if such approval is made in writing, unless the attention of the Engineer is called to the non-complying features by letter accompanying the submittal data. Approval of submittal data by the Engineer shall not be construed as a complete check of approval of detailed dimensions, weights, gauges, and similar details with the proposed articles. The conformance with the necessary coordination between the various other Contractors and suppliers shall be solely the responsibility of the Electrical Contractor and with no additional expense to the Owner.

2.3 SUBSTITUTIONS

- A. Manufacturer's lists are to establish a standard of quality and not intended to limit the selection to these manufacturers. All materials and equipment which are essential and have not been specified or shown shall be new and of the highest grade and quality free from defect or other imperfections. It should be understood that where the words "furnished and installed" are used, it is intended that the Electrical Contractor shall purchase and install all materials required, unless otherwise noted.
- B. All materials and equipment proposed as substitutes for these specified shall require a ten (10) day prior approval from the Engineer prior to the bid date. No substitutions will be allowed after the ten (10) day period before the bid date.
- C. All products shall be furnished in compliance with NC General Statute 133-3.

2.4 PRODUCT HANDLING

- A. Equipment and materials shall be properly stored, adequately protected, and carefully handled to prevent damage before and during installation. Equipment and materials shall be handled, stored and protected in accordance with the manufacturer's recommendations and as approved by the Architect/Engineer. Equipment installed with a factory finish shall be fully protected during construction and shall be maintained free of dust, dirt and foreign matter. Dents and other surface damage shall be repaired or replaced to the satisfaction of the Architect/Engineer at no additional cost to the Owner.
- B. The Electrical Contractor shall clean up and remove from the job site all waste materials, packaging, crating, and refuse resulting from his work on a daily basis.

2.5 MATERIALS AND WORKMANSHIP

- A. The Electrical Contractor shall perform a first class job, both in material and workmanship. None other will be accepted. Deviations from either will be corrected by the Electrical Contractor at the Electrical Contractor's expense.
- B. The material used throughout the work, except when otherwise noted, shall be new and of Specification grade and the best of its kind. No substitutes shall be used unless approved by the Architect/Engineer. All work shall be executed with a maximum speed consistent with safety and good workmanship.
- C. Any equipment furnished by the Mechanical Contractor or any other Contractor that is larger than those indicated on the Drawings and described in these Specifications or have different Electrical characteristics, the increase in cost to the Electrical Contractor for larger wires, conduit, circuit breakers, switches, etc. or for changes in work already installed shall be borne by the instigating Contractor.

PART III - EXECUTION

3.1 EXCAVATION AND BACKFILL

- A. The Electrical Contractor shall preform any and all trench and pit excavation and backfilling required for the installation of his work. Trenches shall be made with the sides vertical and shall be shored where necessary for the protection of men and equipment. All excavation work shall be done in a careful manner to avoid damage to footers and foundations. The backfilling shall be placed in layers not exceeding 4 inches in depth, wetting each layer as it is placed and thoroughly compacting each layer with Mechanical tamper or other approved means. Any damage done during excavation and backfilling operations to roads, sidewalks, curbs, shrubs, sod, footers, foundations, etc. shall be replaced to its original condition prior to construction at no expense to the owner. All work will be approved by the Engineer.

3.2 SCAFFOLDING, RIGGING AND HOISTING

- A. The Electrical Contractor shall furnish all necessary scaffolding, staging, rigging and hoisting required for the completion of his work. All such scaffolding, etc., shall be removed from the premises when its use is no longer required on the job.

3.3 CUTTING AND PATCHING

- A. The Electrical Contractor shall provide all cutting and patching necessary to install the work specified in the 16000 Sections. The patching shall match adjacent surface material and finishes.
- B. No Structural member shall be cut without the approval of the Engineer and all such cutting shall be done in a manner directed by him.
- C. Cutting or Holes:
 - 1. Locate holes in advance where they are proposed in the Structural Sections such as ribs or beams. Obtain the approval of the Engineer prior to drilling through Structural Sections.
 - 2. Cut holes through concrete and masonry in new and existing structures with a diamond core drill or concrete saw. Pneumatic hammer, impact electric, hand or manual hammer type drills are not allowed.

3.4 WATERPROOFING

- A. At floor, exterior wall, and roof conduit penetrations, completely seal clearances around the conduit and make watertight. All work subject to approval of the Engineer.

3.5 EQUIPMENT SPACE AND ARRANGEMENT

- A. The equipment shall fit into the space allotted and shall allow adequate clearance for entry, installation, replacement, servicing, and maintenance. The Electrical Contractor shall coordinate the work to ensure that equipment may be moved into place without altering building components or other installations. Access space shall not be less than the equipment manufacturer's requirements. Working clearances shall be not less than N.E.C or other regulatory requirements.
- B. These drawings indicate the extent and general arrangement of equipment. If any departures are deemed necessary by the Electrical Contractor, details of such departures and the reasons therefore shall be submitted to the Architect/Engineer for approval as soon as practicable and within 30 days after Award of the Contract. No departure shall be made without written approval of the Architect/Engineer. Any delay on the Contractor's part to provide such submittal will not constitute an extension of the Contract time.

3.6 DAMAGE TO WORK ALREADY IN PLACE

- A. The Electrical Contractor shall assume full responsibility for any damage done by him, his agents or employees, to any work already in place. Any such damage done shall be repaired at the Contractor's expense by Mechanics skilled at their respective trades, to the approval of the Architect/Engineer.

3.7 JURISDICTION OF WORK

- A. It may become necessary for the Electrical Contractor to furnish labor or materials which are not generally accepted as part of this trade. In cases of this type, he shall contract the work or shall furnish materials and employ workmen of the trade involved in order not to cause any delay or stoppage of work caused by infringement of Trade Agreements as to jurisdiction, alleged or actual.

3.8 COORDINATION WITH OTHER TRADES

- A. All work shall be coordinated with other trades involved in the construction project. All work shall be carefully laid out in advance to coordinate Architectural, Structural, Mechanical, Plumbing and Electrical features of construction. The Contractor shall verify at the site all locations, grades, elevations and utility service connections indicated. Any conflicts due to lack of proper coordination shall be brought to the attention of the Architect/Engineer for resolution. The Electrical Contractor shall make required changes or relocations at no additional cost to the Owner.
- B. Installation, inspection, and testing of work above ceilings shall be completed and approved by the Architect/Engineer prior to installation of the specified finished ceilings. However, a Ceiling Suspension System may be installed as required for coordination.
- C. The Electrical Contractor shall consult with the other trades at the start of the work and periodically thereafter, as required to properly coordinate the various items of work, and to avoid interferences. Should any interferences of any nature develop as the work progresses, such interferences shall be resolved and eliminated as directed. The cost of any work directed shall be borne by the Subcontractor or Contractors directed to do this work.

3.9 DIVISION OF WORK

- A. These paragraphs are intended to show exactly the point of division of work between the Electrical Division and the Mechanical Division or any other division.
- B. All equipment covered in the Mechanical Division or any other Division of the Specifications shall be furnished, mounted, and aligned under the respective Division. All starters, controls and wiring for this equipment, including final connection to the same,

Brunswick County (US17) Rest Area Renovations

shall be furnished and installed under that Division.

- C. Divisions of the Specifications shall be completed under the respective Division.
- D. Under Division 16, the Contractor shall be responsible for providing all line side power wiring, conduit, disconnect switches, and junction boxes as shown on the electrical drawings.

3.10 EQUIPMENT INSTALLATION

- A. Manufacturer's Instructions: Equipment shall be installed as recommended by the manufacturer to conform to the requirements of the particular application, in accordance with these Drawings and Specifications.

3.11 OPERATION AND MAINTENANCE MANUALS

- A. Prepare maintenance manuals in accordance with Division 1 Section "PROJECT CLOSEOUT". In addition to the requirements specified in Division 1, include the following information for equipment items:
 - 1. Description of function, normal operating characteristics and limitations, performance curves, engineering data and tests, and complete nomenclature and commercial numbers of replacement parts.
 - 2. Manufacturer's printed Operating Procedures to include start-up, break-in, and routine and normal Operating Instructions; regulation, control, stopping, shutdown, and emergency instructions and summer and winter operating instructions.
 - 3. Maintenance procedures for routine preventative maintenance and troubleshooting; disassembly, repair, and re-assembly; aligning and adjusting instructions.
 - 4. Servicing Instructions and Lubrication Charts and Schedules.

3.12 RECORD DOCUMENTS

- A. Prepare record documents in accordance with the requirements in Division 1 Section "PROJECT CLOSEOUT". In addition to the requirements specified in Division 1, indicate installed conditions for:
 - 1. Major raceway systems, size and location, for both exterior and interior; locations of control devices; distribution and branch electrical circuitry; and fuse and circuit breaker size and arrangements.
 - 2. Equipment locations (exposed and concealed) dimensioned from prominent building lines.
 - 3. Approved substitutions, Contract modifications and actual equipment and materials installed.

3.13 GUARANTEE

- A. The Electrical Contractor shall present to the Owner a written guarantee covering his work, including all equipment, material and workmanship. This guarantee shall be against all defects in any of the above work, and shall run for a period of one (1) year from the date of written acceptance of the Contractor's work.
- B. Any defective work, equipment, material and/or workmanship that develops within the Guarantee period, which is not caused by ordinary wear or abuse by other persons, shall be replaced by the Electrical Contractor without cost to the Owner.

3.14 FINAL INSPECTION

- A. When the entire Contract has been completed and the work is ready for final inspection, the Architect/Engineer or his duly authorized representative will make the inspection. At

Brunswick County (US17) Rest Area Renovations

the time of inspection, the Electrical Contractor shall demonstrate to the Architect/Engineer that the various systems and pieces of equipment have been adjusted to operate in accordance with the requirements of the Contract.

- B. An authorized Inspector from the North Carolina State Construction Office shall inspect the project during construction and upon completion of the construction phase. It shall be the responsibility of the Electrical Contractor to notify the Inspector as the work progresses.

3.15 FINAL PAYMENTS

- A. All Final Payments are contingent upon all necessary Certificates and/or Approvals cited above, together with the written Guarantee being presented to the Owner.

DOCUMENTATION

- A. All tests shall be completely documented indicated time of day, temperature, and all pertinent test information.
- B. All required documentation of readings shall be submitted to the engineer prior to, and as one of the prerequisites for, final acceptance of the project.

END OF SECTION 16010

SECTION 16050 - BASIC ELECTRICAL MATERIALS AND METHODS

PART I - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and General Provisions of Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes limited Scope, General Construction Materials and Methods for Application with Electrical Installations as follows:
 1. Miscellaneous metals for support of electrical materials and equipment.
 2. Joint sealers for sealing around electrical materials and equipment; and for sealing penetrations in fire and smoke barriers, floors, and foundation walls.

1.3 DEFINITIONS

- A. The following definitions apply to excavation operations:
 1. Additional Excavation: Where excavation has reached required subgrade elevations, if unsuitable bearing materials are encountered, continue excavation until suitable bearing materials are reached. The Contract Sum may be adjusted by an appropriate Contract Modification.
 2. Sub-Base: As used in this Section refers to the compacted soil layer used in pavement systems between the subgrade and the pavement base course material.
 3. Sub-Grade: As used in this Section refers to the compacted soil immediately below the slab or pavement system.
 4. Unauthorized excavation consists of removal of materials beyond indicated sub-grade elevations or dimensions without specific direction from the Architect.

1.4 SEQUENCE AND SCHEDULING

- A. Coordinate the shut-off and disconnection of electrical service with the Owner and the utility company.

PART II - PRODUCTS

2.1 SOIL MATERIALS

- A. Sub-Base Material: Naturally or artificially graded mixture of natural or crushed gravel, crushed stone, crushed slag, or natural or crushed sand.
- B. Drainage Fill: Washed, evenly graded mixture of crushed stone, or crushed or uncrushed gravel, with 100 percent passing a 1½ inch sieve, and not more than 5 percent passing a No. 4 sieve.
- C. Backfill and Fill Materials: Materials complying with ASTM D2487 soil classification groups GW, GP, GM, SM, SW, and SP; free of clay, rock, or gravel larger than 2 inches in any dimension; debris; waste; frozen materials; and vegetable and other deleterious matter.

Brunswick County (US17) Rest Area Renovations

2.2 MISCELLANEOUS METALS

- A. Steel plates, shapes, bars, and bar grating: ASTM A 36.
- B. Cold-Formed Steel Tubing: ASTM A 500.
- C. Hot-Rolled Steel Tubing: ASTM A 501.
- D. Steel Pipe: ASTM A 53, Schedule 40, welded.
- E. Fasteners: Zinc-coated, type, grade and class as required.

PART III - EXECUTION

3.1 EXAMINATION

- A. Examine substrates, areas and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting installation and application of joint sealers. Do not proceed with installation until unsatisfactory conditions have been corrected.

3.2 EXCAVATION

- A. Slope sides of excavations to comply with local codes and ordinances. Shore and brace as required for stability of excavation.
- B. Install sediment and erosion control measures in accordance with local codes and ordinances.
- C. Dewatering: Prevent surface water and subsurface or groundwater from flowing into excavations and from flooding project site and surrounding area.
 - 1. Do not allow water to accumulate in excavations. Remove water to prevent softening of bearing materials.
 - 2. Provide and establish and maintain temporary drainage ditches and other diversions outside excavation limits to convey surface water to collecting or run-off areas. Do not use trench excavations as temporary drainage ditches.
- D. Material Storage: Stockpile satisfactory excavated materials where directed, until required for backfill or fill. Place, grade, and shape stockpiles for proper drainage.
 - 1. Locate and retain soil materials away from edge of excavations. Do not store within drip line of trees indicated to remain.
 - 2. Remove and legally dispose of excess excavated materials and materials not acceptable for use as backfill or fill.
- E. Trenching: Excavate trenches for electrical installations as follows:
 - 1. Excavate trenches to the uniform width, sufficiently wide to provide ample working room and a minimum of 6 to 9 inches clearance on both sides of raceways and equipment.
 - 2. Excavate trenches to depth indicated or required.
 - 3. Limit the length of open trench to that in which installations can be made and the trench backfilled within the same day.
 - 4. Where rock is encountered, carry excavation below required elevation and backfill with a layer of crushed stone or gravel prior to installation of raceways and equipment. Provide a minimum of 6 inches of stone or gravel cushion between rock bearing surface and electrical installations.
- F. Cold Weather Protection: Protect excavation bottoms against freezing when atmospheric temperature is less than 35 degrees F (1 degree 2 C).
- G. Backfilling and Filling: Place soil materials in layers to required subgrade elevations for each area classification listed below, using materials specified in Part 2 of this Section.
 - 1. Under walks and pavements, use a combination of sub-base materials and excavated or borrowed materials.
 - 2. Under building slabs, use drainage fill materials.
 - 3. Under piping and equipment, use subbase materials where required over rock bearing surface and for correction of unauthorized excavation.

Brunswick County (US17) Rest Area Renovations

4. For raceways less than 30 inches below surface of roadways, provide 4-inch thick concrete base slab support. After installation of raceways, provide a 4-inch thick concrete encasement (sides and top) prior to backfilling and placement of roadway sub-base.
5. Other areas, use excavated or borrowed materials.
- H. Backfill excavations as promptly as work permits, but not until completion of the following:
 1. Inspection, testing, approval, and locations of underground utilities have been recorded.
 2. Removal of concrete formwork.
 3. Removal of shoring and bracing and backfilling of voids.
 4. Removal of trash and debris.
- I. Placement and Compaction: Place backfill and fill materials in layers of not more than eight (8) inches in loose depth for material compacted by heavy equipment, and not more than four (4) inches in loose depth for material compacted by hand operated tampers.
- J. Before compaction, moisten or aerate each layer as necessary to provide optimum moisture content. Compact each layer to required percentage of maximum dry density or relative dry density for each area classification specified below. Do not place backfill or fill material on surfaces that are muddy, frozen, or contain frost or ice.
- K. Place backfill and fill materials evenly adjacent to structures, piping, and equipment to required elevations. Prevent displacement of raceways and equipment by carrying material uniformly around them to approximately same elevation in each lift.
- L. Compaction: Control soil compaction during construction, providing minimum percentage of density specified for each area classification indicated below.
 1. Percentage of Maximum Density Requirements: Compact soil to not less than the following percentages of maximum density for soils which exhibit a well-defined moisture density relationship (cohesive soils), determined in accordance with ASTM D 1557 and not less than the following percentages of relative density, determined in accordance with ASTM D 2049, for soils which will not exhibit a well-defined moisture density relationship (cohesion-less soils).
 2. Areas Under Structures, Building Slabs and Steps, Pavements: Compact top 12 inches of material, or 95 percent relative density for cohesionless material.
 - a. Areas Under Walkways: Compact top 6 inches of subgrade and each layer of backfill or fill material to 90 percent maximum density for cohesive material or 95 percent relative density for cohesionless material.
 - b. Other Areas: Compact top 6 inches of subgrade and each layer of backfill or fill material to 85 percent maximum density for cohesive soils, and 90 percent relative density for cohesionless soils.
 3. Moisture Control: Where subgrade or layer of soil material must be moisture conditioned before compaction, uniformly apply water. Apply water in minimum quantity necessary to achieve required moisture content and to prevent water appearing on surface during, or subsequent to, compaction operations.
 4. Subsidence: Where subsidence occurs at electrical installation excavations during the period 12 months after Substantial Completion, remove surface treatment (i.e., pavement, lawn, or other finish), add backfill material, compact to specified conditions, and replace surface treatment. Restore appearance, quality, and condition of surface or finish to match adjacent areas.

3.3 ERECTION OF METAL SUPPORTS AND ANCHORAGE

- A. Cut, fit, and place miscellaneous metal fabrications accurately in location, alignment, and elevation to support and anchor electrical materials and equipment.
- B. Field Welding: Comply with AWS "Structural Welding Code".

END OF SECTION 16050

SECTION 16100 - RACEWAYS, BOXES AND CABINETS

PART I - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and General Provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes Raceways, Fittings, Boxes, Enclosures and Cabinets for Electrical Wiring.

PART II - PRODUCTS

2.1 METAL CONDUIT AND TUBING

- A. Rigid Steel Conduit: ANSI C80.1
- B. Intermediate Metal Conduit: ANSI C80.6
- C. Electrical Metallic Tubing and Fittings: ANSI C80.3 with compression-type fittings.
- D. Flexible Metal Conduit: Zinc coated steel
- E. Liquid tight Flexible Metal Conduit: Flexible steel conduit with PVC jacket.
- F. Fittings: NEMA FB 1, compatible with conduit/tubing materials.
- G. Non-Metallic Rigid Conduit: Schedule 40 pvc as where shown on the drawings.
- H. "MC" type cable shall not be used.

2.2 OUTLET AND DEVICE BOXES

- A. Sheet Metal Boxes: NEMA OS 1
- B. Cast Metal Boxes: NEMA FB 1, type FD, cast alloy box with gasketed cover

2.3 PULL AND JUNCTION BOXES

- A. Small Sheet Metal Boxes: NEMA OS 1.
- B. Cast Metal Boxes: NEMA FB 1, cast aluminum with gasketed cover.
- C. Pull Boxes: Code gauge steel with screw type removable cover. NEMA rated for the condition.

PART III - EXECUTION

3.1 EXAMINATION

- A. Examine surfaces to receive raceways, boxes, enclosures, and cabinets for compliance with installation tolerances and other conditions affecting performance of the raceway system. Do not proceed with installation until unsatisfactory conditions have been corrected.

3.2 MINIMUM CONDUIT SIZE: (unless indicated otherwise) on the drawings conduit shall be sized as follows:

- A. Indoors: The minimum conduit size shall be 1/2".
 - 1. Flexible metal conduit may be used for tap connection to recessed lighting fixtures.

Brunswick County (US17) Rest Area Renovations

- B. Outdoors: Branch circuit conduit installed below grade to exterior equipment shall be one (1) inch minimum unless noted otherwise.

3.3 WIRING METHODS: Unless noted otherwise on the drawings the following materials shall be used:

- A. Outdoors: Use the following wiring methods:
 - 1. Exposed: Rigid or intermediate metal conduit.
 - 2. Underground: Galvanized Rigid Conduit.
 - 3. Connection to Vibrating Equipment (including transformers and hydraulic, pneumatic, or electric solenoid or motor-driven equipment): Liquid tight flexible metal conduit.
 - 4. Boxes and Enclosures: NEMA Type 3R or Type 4.
- B. Indoors: Use the following wiring methods:
 - 1. Connection to Vibrating Equipment (including transformers and hydraulic, pneumatic, or electric solenoid or motor-driven equipment): Flexible metal conduit, except in wet or damp locations use liquid tight flexible metal conduit.
 - 2. Damp or Wet Locations: Rigid steel conduit.
 - 3. Exposed: Electrical metallic tubing above 8 feet and rigid metallic conduit below eight (8) feet.
 - 4. Concealed: Electrical metallic tubing.
 - 5. Boxes and Enclosures: NEMA Type 1, except in damp or wet locations use NEMA Type 3R, unless otherwise noted.

3.4 INSTALLATION

- A. Telephone/Data/Cable TV outlet boxes shall be 2 gang with appropriate trim and cover. Coordinate cover plates with Owner.
- B. Provide insulated bushings for all conduit ends.
- C. Conceal rigid conduit and EMT, unless otherwise indicated, within finished walls, ceilings, above attic space and below floors.
- D. Keep raceways at least 6 inches (150 mm) away from parallel runs of flues and steam or hot water pipes. Install horizontal raceway runs above water and steam piping.
- E. Install raceways level and square and at proper elevations. Provide adequate headroom.
- F. Complete raceway installation before starting conductor installation.
- G. Use temporary closures to prevent foreign matter from entering raceway.
- H. Protect stubs from damage where conduits rise through floor slabs. Arrange so curved portion of bends is not visible above the finished slab.
- I. Where non-metallic conduit is shown to be used below the slab provide rigid conduit to turn up into the building space or at all exterior walls, poles or equipment.
- J. Use raceway fittings compatible with raceway and suitable for use and location. For intermediate steel conduit, use threaded rigid steel conduit fittings, except as otherwise indicated.
- K. Run concealed raceways with a minimum of bends in the shortest practical distance considering the type of building construction and obstructions, except as otherwise indicated. Where the number of bends exceed the total number required by the N.E.C., provide pull boxes as required by code.
- L. Install raceways parallel to or at right angles to surfaces or structural members, and follow the surface contours as much as practical.
 - 1. Run parallel or banked raceways together, on common supports where practical.
 - 2. Make bends in parallel or banked runs from same centerline to make bends parallel. Use factory elbows only where they can be installed parallel; otherwise, provide field bends for parallel raceways.
- M. Join raceways with fittings designed and approved for the purpose and make joints tight.
 - 1. Use bonding jumpers where joints cannot be made tight.
 - 2. Use insulating bushings to protect conductors.
 - 3. Provide expansion joint fittings where required for the raceway used.

Brunswick County (US17) Rest Area Renovations

- N. IMC and GRC shall terminate with either a double locknut/bushing set or in a threaded hub.
- O. Where conduit type "LB" fittings are used all conduits on conduits over 2" in size shall be "MOGAL" type.
- P. "EMT" connectors shall be steel plated hexagonal compression type only. Do not use pot metal, set-screw, or indenter type connectors.
- Q. Where concentric, eccentric, or oversized knockouts are encountered, a grounding-type insulated bushing shall be provided.
- R. Where conduits of any type pass over a building expansion joint, a standard "expansion joint" fitting, compatible with the type raceway, shall be provided.
- S. Terminations: Where raceways are terminated with locknuts and bushings, align the raceway to enter squarely and install the locknuts with dished part against the box. Where terminations cannot be made secure with one locknut, use two locknuts, one inside and one outside the box.
- T. Where terminating in threaded hubs, screw the raceway or fitting tight into the hub so the end bears against the wire protection shoulder. Where chase nipples are used, align the raceway so the coupling is square to the box and tighten the chase nipple so no threads are exposed.
- U. Install pull cords in all empty raceways. Use monofilament plastic line having not less than 200-lb (90 kg) tensile strength. Leave not less than 12 inches (300 mm) of slack at each end of the pull cord.
- V. Telephone and Signal System Raceways 2 Inch Trade Size and Smaller: In addition to the above requirements, install in maximum lengths of 150 feet (45 m) and with a maximum of two 90-degree bends or equivalent. Install pull or junction boxes where necessary to comply with these requirements. Pull boxes shall be a minimum of 10" square x 6" deep with removable cover.
- W. Install raceway sealing fittings at suitable, approved, accessible locations and fill them with UL-listed sealing compound. For concealed raceways, install each fitting in a flush steel box with a blank cover plate having a finish similar to that of adjacent plates or surfaces. Install raceway sealing fittings at the following points and elsewhere as indicated:
 - 1. Where conduits enter or leave hazardous classified locations.
 - 2. Where otherwise required by the NEC.
- X. Stub-Up Connections: Extend conduits through concrete floor a minimum of 6" for connection to freestanding equipment. Extend conductors to equipment with flexible metal conduit. Where equipment connections are not made under this Contract verify the length of the flexible connectors.
- Y. Flexible Connections: Use maximum of 6 feet (1830 mm) of flexible conduit for recessed and semi-recessed lighting fixtures; for equipment subject to vibration, noise transmission, or movement; and for all motors. Use liquid tight flexible conduit in wet or damp locations. Install separate ground conductor.
- Z. Provide grounding connections for raceway, boxes and components. Tighten connectors and terminals according to tightening torques specified in UL Standard 486A.
- AA. All underground raceways shall be identified by "UNDERGROUND LINE MARKING TAPE" located directly above the raceway at 6" below finished grade. Tape shall be permanent, bright-colored, continuous, magnetic strip, printed, plastic tape compounded for direct burial not less than 6" wide and 4 mils thick. Printed legend shall be indicative of the service it is marking. Provide sufficient tape not less than 2/3 of the width of the item marked for the full length of the Raceway.
- BB. Where underground raceways are required to turn up into cabinets, equipment, etc., and on to poles, the elbow required and the sub-up out of the slab or earth shall be rigid steel.
- CC. Where shown to be used on the drawings PVC non-metallic conduit used exterior to the building for grouped circuits it shall be encased in a minimum of 3" of 3000 psi rated concrete. Concrete encased non-metallic ducts shall be supported on plastic separators coordinated with duct size and spacing. Separators shall be spaced close enough to prevent sagging and deforming of ducts. Secure separators to the earth and to ducts to

Brunswick County (US17) Rest Area Renovations

prevent floating during placement of concrete. Do not use steel or tie wires in such a way to form conductive or magnetic loops around ducts or duct groups.

- DD. The Raceway System shall not be relied on for grounding continuity. A green grounding conductor, properly sized per NEC Table 250-122, shall be run in all power raceways.
- EE. Where non-metallic conduit is allowed on the drawings all bends and off-sets shall be made by approved mechanical benders per the manufacturers instruction. Any conduit not in compliance will be removed.

3.5 PROTECTION

- A. Provide final protection and maintain conditions, in a manner acceptable to manufacturer and Installer, to ensure that coatings, finishes, and cabinets are without damage or deterioration at Substantial Completion.
 - 1. Repair damage to galvanized finishes with zinc-rich paint recommended by manufacturer.
 - 2. Repair damage to paint finishes with matching touch-up coating recommended by the manufacturer.

3.6 CLEANING

- A. Upon completion of installation of system, including outlet fittings and devices, inspect exposed finish. Remove burrs, dirt and construction debris and repair damaged finish, including chips.

END OF SECTION 16100

SECTION 16120 - WIRES AND CABLES

PART I - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and General Provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes Building Wires and Cables and Associated Splices, Connectors and Terminations for Wiring Systems rated 600 Volts and Less.

PART II - PRODUCTS

2.1 BUILDING WIRES AND CABLES

- A. UL-listed building wires and cables with conductor material, insulation type, cable construction, and rating as specified in Part 3 "Applications" Article.
- B. Rubber Insulation: Conform to NEMA WC 3.
- C. Thermoplastic Insulation: Conform to NEMA WC 5.
- D. Cross-Linked Polyethylene Insulation: Conform to NEMA WC 7.
- E. Ethylene Propylene Rubber Insulation: Conform to NEMA WC 8.
- F. Solid conductor for 10 AWG and smaller: Stranded conductor for larger than 10 AWG.

2.2 CONNECTORS AND SPLICES

- A. UL-listed factory fabricated wiring connectors of size, ampacity rating, material, and type and class for application and for service indicated.

PART III - EXECUTION

3.1 EXAMINATION

- A. Examine raceways and building finishes to receive wires and cables for compliance with installation tolerances and other conditions. Do not proceed with installation until unsatisfactory conditions have been corrected.

3.2 APPLICATIONS

- A. Feeders and Branch Circuits: Type THHN\THWN or XHHW, copper conductor, in raceway.

3.3 INSTALLATION

- A. All conductors shall be copper.
- B. Minimum conductor size for power and lighting circuits shall be #12 AWG. Maximum conductor size shall be 500 KCMIL AWG.
- C. All power and lighting circuits #10 awg and smaller shall be solid copper conductors. Conductor sizes #8 awg and larger shall be Class "B" stranded copper conductors.
- D. Pull conductors into raceway simultaneously where more than one is being installed in same raceway.

Brunswick County (US17) Rest Area Renovations

1. Use pulling compound or lubricant where necessary; compound used must not deteriorate conductor or insulation.
 2. Use pulling means, including fish tape, cable, rope, and basket weave wire/cable grips that will not damage cables or raceway.
- E. Conductor Splices: Keep to minimum.
- F. Wiring at Outlets: Install with at least 8 inches of slack conductor at each outlet.
- G. Connect outlets and components to wiring and to ground as indicated. Tighten to UL Standard 486A.
- H. Power and Lighting circuits shall have individual neutral conductors.
- I. All power circuits noted for computer equipment with isolated grounding shall be individually installed in a separate conduit with separate phase, neutral conductor, grounding conductor, and isolated grounding conductor, unless noted otherwise.
- J. In no case shall any wire installed to a device exceed the U.L. rating of the device.

3.4 SPLICING

- A. Joints in solid conductors shall be using Idea "wire nuts", 3M Company "scotch lock", or "T&B" "PIGGY" connectors in junction boxes, outlet boxes and lighting fixtures.
- B. "Sta-kon" or other permanent type crimp connectors shall not be used for branch circuit connections.
- C. Joints in stranded conductors shall be spliced by approved mechanical connectors. Solderless mechanical connectors similar to "NSI" multi-cable connector blocks for splices and taps, provided with UL approved insulating covers, may be used instead of mechanical connectors plus tape.
- D. Conductors in all cases, shall be continuous from outlet to outlet unless "taps" are required and shall be made only within outlet, junction boxes, troughs and gutters.

3.5 VOLTAGE DROP

- A. Where conductor length from the panel to the first outlet on a 120 volt circuit exceeds 100 feet, the branch circuit conductors from the panel to the first outlet shall be not smaller than #10 awg.

3.6 FIELD QUALITY CONTROL

- A. Testing: Upon installation of wires and cables and before electrical circuitry has been energized, demonstrate product capability and compliance with requirements.
1. Procedures: Perform each Visual and Mechanical Inspection and Electrical Test stated in NETA Standard ATS, Section 7.3.1. Certify compliance with test parameters.
- B. Correct malfunctioning products at site, where possible, and re-test to demonstrate compliance; otherwise, remove and replace with new units and re-test.

3.7 ELECTRICAL TESTING

- A. Feeder Insulation Resistance Testing:
1. All current carrying phase conductors and neutrals shall be tested as installed, and before connections are made, for insulation resistance and accidental grounds. This shall be done with a 500-volt test instrument. The procedures listed below shall be followed:
 2. Minimum readings shall be one million (1,000,000) or more ohms for # 6 AWG wire and smaller, 250,000 ohms or more for #4 wire or larger, between conductor and the grounding conductor.
 3. After all devices and equipment are installed and all connections completed to each panel, the Contractor shall disconnect the neutral feeder conductor from the neutral bar and take a test reading between the neutral bar and the grounded enclosure. If this reading is less than 250,000 ohms, the Contractor shall

Brunswick County (US17) Rest Area Renovations

disconnect the branch circuit neutral wires from the neutral bar. Test each neutral conductor separately until the low readings are found. The Contractor shall correct troubles, reconnect and re-test until at least 250,000 ohms from the neutral bar to the grounded panel can be achieved with only the neutral feeder disconnected.

4. The Contractor shall send a letter to the Engineer certifying that the above has been done and tabulating the test readings for each panel. This shall be done at least four (4) days prior to final inspection.
5. At the final inspection, the Contractor shall furnish a test instrument and show the Engineers that the panels comply with the above requirements. He shall also furnish a hook-on type ammeter and a voltmeter and take current and voltage readings as directed by the representatives.

END OF SECTION 16120

SECTION 16140 - WIRING DEVICES

PART I - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and General Provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes various types of receptacles, connectors, switches and finish plates.

1.3 SUBMITTALS

- A. Submit the following according to the Conditions of the Contract and Division 1 Specification Sections.
- B. Product data for each product specified.

PART II - PRODUCTS

2.1 WIRING DEVICES

- A. Comply with NEMA Standard WD 1-101968, "General Purpose Wiring Devices".
- B. Enclosures: NEMA 1 equivalent, except as otherwise indicated.
- C. Color: Selected by Architect.
- D. Duplex receptacles shall be of the grounding type arranged for back and side wiring, with separate single or double grounding terminals. Receptacles shall be straight blade, rated 20 amp, 125 volt and the face configuration shall conform to the NEMA Standard No. WD-1, NEMA WD-6, DSCC W-C-596G & UL 498, and shall be approved third party listed. Self-grounding or automatic type grounding receptacles are not acceptable in lieu of receptacles with separate grounding screw lugs and a direct green insulated conductor connection to the equipment grounding system. Receptacles shall be specification grade mounted vertically.
- E. Receptacles, Straight-Blade, Special Features: Comply with the basic requirements specified above for straight-blade receptacles of the class and type indicated, and with the following additional requirements:
 - 1. Ground Fault Circuit Interrupter (GFCI) Receptacles: UL Standard 943, "Ground Fault Circuit Interrupters" with integral NEMA 5-20R duplex receptacle. Design units for installation in a 2¼ inch (70-mm) deep outlet box without an adapter.
- F. Receptacles, Industrial Heavy-Duty: Conform to NEMA Standard PK 4 "Plugs, Receptacles and Cable Connectors of the Pin and Sleeve type for Industrial Use".
- G. Plug Sets: Match voltage and current ratings and number of conductors to requirements of the equipment being connected.
- H. Single pole and three or four-way toggle type as indicated on the drawings. Switches shall be of the grounding type with hex-head grounding screw rated 20 amp 120/277V AC only. Lighted handle switches shall have neon lights of the correct voltage rating where indicated on the drawings. All switches shall have quiet operating mechanisms without the use of mercury switches. All switches shall be listed by an approved third-party agency, approved for the voltage and amperage indicated. Color selected by Architect.
- I. Motion Sensor Switches
 - 1. Single Pole-single switching
 - 2. Single Pole-double switching

Brunswick County (US17) Rest Area Renovations

3. Switches shall be combination ultrasonic and passive infrared.
 4. 100 square foot coverage, 180 degree.
 5. 120 volt: 800 watt incandescent, 1000 watt fluorescent.
 6. 277 volt, 1800 watt fluorescent.
 7. 5 year warranty.
- J. Wall Plates: Single and combination types that mate and match with corresponding wiring devices. Features include the following:
1. Material for Finished Spaces: 0.04 inch thick, type 302, satin finished stainless steel, intermediate jumbo size except as otherwise indicated.
 2. Material for Unfinished Spaces: Galvanized cast ferrous steel, standard size.
 3. Provide a quantity of 2% spare cover plates for each type of device cover used to the Owner.

PART III - EXECUTION

3.1 INSTALLATION

- A. Install devices and assemblies plumb and secure.
- B. Install wall plates when painting is complete.
 1. Arrangement of Devices: Except as otherwise indicated, mount flush, with long dimension vertical and grounding terminal of receptacles on top. Group adjacent switches under single, multi-gang wall plates.
- C. Protect devices and assemblies during painting.
- D. Adjust locations at which floor service outlets are installed to suit the indicated arrangement of partitions and furnishings.
- E. Field verify the actual location of all outlet devices above equipment or counter tops before rough-in and installation. Any outlet installed in conflict with equipment or conditions that could have been avoided, will be corrected at the Contractor's expense.
- F. Provide weatherproof cast aluminum cover plates for all devices exterior to the building or in "wet" locations, Hubbell WP26M or equal.
- G. GFCI protection shall be provided for all receptacles exterior to the building, in restrooms or where required by Code.
- H. Locate all receptacles in rated walls with 24" minimum horizontal separation. This includes devices located opposite each other in the walls.

3.2 IDENTIFICATION

- A. Switches: Where 3 or more switches are ganged and elsewhere where indicated, identify each switch with approved legend engraved on wall plate.
- B. Receptacles: Identify the panelboard and circuit number from which served. Use machine-printed, pressure-sensitive, abrasion-resistant label tape on face of plate and durable wire markers or tags within outlet boxes.

3.3 FIELD QUALITY CONTROL

- A. Testing: Test wiring devices for proper polarity and ground continuity. Operate each operable device at least six (6) times.
- B. Test ground-fault circuit interrupter operation with both local and remote fault simulations according to manufacturer recommendations.
- C. Replace damaged or defective components.

Brunswick County (US17) Rest Area Renovations

3.4 CLEANING

- A. General: Internally clean devices, device outlet boxes and enclosures. Replace stained or improperly painted wall plates or devices.

END OF SECTION 16140

SECTION 16190 - SUPPORTING DEVICES

PART I - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and General Provisions of Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes secure support from the building structure for Electrical items by means of Hangers, Supports, Anchors, Sleeves, Inserts, Seals and Associated Fastenings.

1.3 SUBMITTALS

- A. General: Submit the following in accordance with Conditions of Contract and Division 1 Specification Sections.
- B. Product data for each type of product specified.

PART II - PRODUCTS

2.1 COATINGS

- A. Coating: Supports, support hardware and fasteners shall be protected with zinc coating or with treatment of equivalent corrosion resistance using approved alternative treatment, finish and inherent material characteristic. Products for use outdoors shall be hot-dip galvanized.

2.2 MANUFACTURED SUPPORTING DEVICES

- A. Raceway Supports: Clevis hangers, riser clamps, conduit straps, threaded C clamps with retainers, ceiling trapeze hangers, wall brackets and spring steel clamps.
 - 1. Expansion Anchors: Carbon steel wedge or sleeve type.
 - 2. Toggle Bolts: All steel spring-head type.
- B. Conduit Sealing Bushings: Factory-fabricated watertight conduit sealing bushing assemblies suitable for sealing around conduit or tubing passing through concrete floors and walls. Construct seals with steel sleeve, malleable iron body, neoprene sealing grommets or rings, metal pressure rings, pressure clamps and cap screws.
- C. U-Channel Systems: 16-gage steel channels, with 9/16-inch diameter holes, at a minimum of 8 inches on center, in top surface. Provide fittings and accessories that mate and match with U-channel and are of the same manufacturer.

2.3 FABRICATED SUPPORTING DEVICES

- A. General: Shop or field fabricated supports or manufactured supports assembled from U-Channel components.
- B. Steel Brackets: Fabricated of angles, channels and other standard structural shapes. Connect with welds and machine bolts to form rigid supports.
- C. Pipe Sleeves: Provide pipe sleeves of one of the following:
 - 1. Sheet Metal: Fabricate from galvanized sheet metal; round tube closed with snap-lock joint, welded spiral seams, or welded longitudinal joint. Fabricate sleeves from the following gage metal for sleeve diameter noted:

Brunswick County (US17) Rest Area Renovations

- a. 3-inch and smaller: 20-gage
- b. 4-inch to 6-inch: 16-gage
2. Steel Pipe: Fabricate from Schedule 40 galvanized steel pipe.
3. Plastic Pipe: Fabricate from Schedule 80 PVC plastic pipe.

PART III - EXECUTION

3.1 INSTALLATION

- A. Install supporting devices to fasten electrical components securely and permanently in accordance with NEC requirements.
- B. Coordinate with the building structural system and with other electrical installation.
- C. Raceway Supports: Comply with the NEC and the following requirements:
 1. Strength of each support shall be adequate to carry present and future load multiplied by a safety factor of at least four. Where this determination results in a safety allowance of less than 200 lbs, provide additional strength until there is a minimum of 200 lbs safety allowance in the strength of each support.
 2. Install individual and multiple (trapeze) raceway hangers and riser clamps as necessary to support raceways. Provide U-bolts, clamps, attachments and other hardware necessary for hanger assembly and for securing hanger rods and conduits.
 3. Support parallel runs of horizontal raceways together on trapeze-type hangers.
 4. Support individual horizontal raceways by separate pipe hangers. Spring steel fasteners may be used in lieu of hangers only for 1 inch and smaller raceways serving lighting and receptacle branch circuits above suspended ceilings only. For hanger rods with spring steel fasteners, use ¼ inch diameter or larger threaded steel. Use spring steel fasteners that are specifically designed for supporting single conduits or tubing.
 5. Space supports for raceway's types not covered by the above in accordance with NEC.
 6. Support exposed and concealed raceway within 1 foot of an unsupported box and access fittings. In horizontal runs, support at the box and access fittings may be omitted where box or access fittings are independently supported and raceway terminals are not made with chase nipples or threadless box connectors.
 7. In vertical runs, arrange support so the load produced by the weight of the raceway and the enclosed conductors is carried entirely by the conduit supports with no weight load on raceway terminals.
 8. In interior spaces provide a minimum of ¼ inch space for all conduits installed on the exterior building walls. Approved "clamp-back" or strut devices shall be used.
- D. Miscellaneous Supports: Support miscellaneous electrical components as required to produce the same structural safety factors as specified for raceway supports. Install metal channel racks for mounting cabinets, panelboards, disconnects, control enclosures, pull boxes, junction boxes, transformers and other devices.
- E. In open overhead spaces, cast boxes threaded to raceways need not be supported separately except where used for fixture support; support sheet metal boxes directly from the building structure or by bar hangers. Where bar hangers are used, attach the bar to raceways on opposite sides of the box and support the raceway with an approved type of fastener not more than 24 inches from the box.
- F. Conduit Seals: Install bushing seals for conduit penetrations of slabs on grade and exterior walls below grade. Tighten sleeve seal screws until sealing grommets have expanded to form watertight seal.
- G. Fastening: Unless otherwise indicated, fasten electrical items and their supporting hardware securely to the building structure, including but not limited to conduits, raceways, cables, cable trays, bus ways, cabinets, panelboards, transformers, boxes, disconnect switches and control components in accordance with the following:

Brunswick County (US17) Rest Area Renovations

1. Fasten by means of wood screws or screw-type nails on wood, toggle bolts on hollow masonry units, concrete inserts or expansion bolts on concrete or solid masonry and machine screws, welded threaded studs, or spring-tension clamps on steel. Do not weld conduit, pipe straps or items other than threaded studs to steel structures. In partitions of light steel construction, use sheet metal screws.
2. Power actuated fasteners are not allowed.

END OF SECTION 16190

County: BRUNSWICK

Line #	Item Number	Sec #	Description	Quantity	Unit Cost	Amount
BUILDING ITEMS						
0001	6975000000-N	SP	GENERIC REST AREA ITEM REST AREA BUILDING - ELECTRICAL	Lump Sum	L.S.	
0002	6975000000-N	SP	GENERIC REST AREA ITEM REST AREA BUILDING - GENERAL CONSTRUCTION	Lump Sum	L.S.	
0003	6975000000-N	SP	GENERIC REST AREA ITEM REST AREA BUILDING - MECHANICAL	Lump Sum	L.S.	
0004	6975000000-N	SP	GENERIC REST AREA ITEM REST AREA BUILDING - PLUMBING	Lump Sum	L.S.	

0934/Jun22/Q4/D27900000000/E4

Total Amount Of Bid For Entire Project :