



STATE OF NORTH CAROLINA
DEPARTMENT OF TRANSPORTATION

PAT MCCRORY
GOVERNOR

ANTHONY J. TATA
SECRETARY

May 13, 2015

NOTICE TO PROSPECTIVE BIDDERS
ADDENDUM NO. 3

BID OPENING: MAY 21, 2015 AT 11:00 A.M.
CONTRACT ID: DG00243
WBS ELEMENT NO.: 3707.3.23
FEDERAL AID NO.: 000S-425
COUNTY: ALAMANCE
TIP NO.: ER-2973
DESCRIPTION.: BUILDING CONSTRUCTION, SITE WORK AND LANDSCAPE PLANTINGS AT
THE I-85/40 REST AREAS, NORTH BOUND AND SOUTH BOUND

RFI #02 had 3 questions. Questions and answers are found below:

1. Permeable Paver Spec's- On Page 27 under the Materials and Construction calls for one of the following to be installed: eco-venetian stone, Subterra or Eco Priora. The next paragraph states that the primary permeable paver is a 12" x 12" fieldstone. None of the 3 pavers mentioned (**eco-venetian, subterra or priora**) are 12" x 12". Can you please verify that you are specifying one of these 3 pavers? **The 12" x 12" paver is noted only in general terms. The acceptable pavers/manufacturers listed (or an approved equal) is our priority. Different manufacturers/distributors may have pavers varying in color, size, and patterns. We ask a sample be submitted (through the process of construction) for final approval.**
2. Plan Sheet LH-01: "Matching cobblestone pavers set in radial pattern" are you looking for a concrete paver circle kit? Or salt and pepper granite cobblestones? If not, please specify the type of product you are looking for. **We are not looking for a specific "salt and pepper granite cobblestones" , but a paver that may come in a pre-determined radial pattern (kit) that closely matches the primary permeable paver. Color, size, and texture may vary slightly. We ask a sample be submitted (through the process of construction) for final approval.**
3. Do you have a plant material source? **You (the contractor) delineate a source for the plant material and we inspect and approve the plant material based on industry and departmental standards.**

Addenda shall be attached to the proposal and acknowledged on the appropriate page in the proposal package in order for bids to be considered responsive.

The bid date and time remain the same.

I am sorry for the inconvenience.

Best Regards,

A handwritten signature in black ink, appearing to read "Carolyn T. Huskins". The signature is written in a cursive style with a large initial 'C'.

Carolyn T. Huskins
Division Proposal Engineer

CTH/cth

ec: Plan Rooms

Plan Holders

Posted to web