



STATE OF NORTH CAROLINA
DEPARTMENT OF TRANSPORTATION

BEVERLY EAVES PURDUE
GOVERNOR

EUGENE A. CONTI, JR.
SECRETARY

December 10, 2010

To: Bidders

From: Philip Lanier

RE: Product Submittal from URETEK ICR, 486STAR

URETEK ICR provided a submittal for 486STAR Polyurethane Foam Grout via email on Wednesday December 8, 2010. Although this product is not classified as hydrophobic, as required in the "Concrete Pavement Leveling and Undersealing", it appears to meet the material and performance intent of this specification, and will be considered acceptable for usage on "Concrete Pavement Leveling and Undersealing."

Sincerely,

A handwritten signature in cursive script that reads "Philip Lanier".

Philip Lanier

Assistant Airport Development Engineer

MAILING ADDRESS:

NC DEPARTMENT OF TRANSPORTATION
DIVISION OF AVIATION
1560 MAIL SERVICE CENTER
RALEIGH NC 27699-1560

TELEPHONE: 919-840-0112
Fax: 919-840-0645

<http://www.ncdot.org/aviation/>

LOCATION:

RDU AIRPORT
1050 MERIDAN DRIVE
RDU NC 27623