

Leak Test Calculations - English

Given: Pressure = 150 psi, Length = 4275 feet, Diameter = 10 inches

Where: W = allowable leakage in gallons/hr

$$W = \frac{4275 \times 10 \times \sqrt{150}}{133,200} = 3.931 \text{ gal/hour}$$