

TECHNICIAN'S CHECKLIST

SECTION 1605

EROSION CONTROL ROADSIDE DEVELOPMENT - TEMPORARY SILT FENCE

PROJECT: _____

TECHNICIAN: _____

REVIEW DATE: _____

REVIEWER: _____

ACTION	YES	NO	N/A	COMMENTS
Check the environmental permits to ensure that silt fence is placed in the proper location and in accordance with the permit drawings and provisions. Ensure the silt fence materials meet the requirements of Sections 1605 and Section 1056. Class A silt fence is only permitted in conjunction with woven wire. Use CI B silt fence otherwise.				
Ensure silt fence is being installed in advance of the need to contain sediment.				
Make any necessary additions in silt fence.				
Ensure that materials are installed according to plan details. (See Roadway Standard Drawing No.1605.01)				
Remove silt accumulation when silt reaches half the height of the silt fence and dispose of waste properly.				
Measure the silt removed for payment.				
Remove silt fence when the permanent controls have been established.				