

**TECHNICIAN'S CHECKLIST**  
**SECTION 802**  
**DISPOSAL OF WASTE AND DEBRIS**

PROJECT: \_\_\_\_\_

TECHNICIAN: \_\_\_\_\_

REVIEW DATE: \_\_\_\_\_

REVIEWER: \_\_\_\_\_

ACTION	YES	NO	N/A	COMMENTS
The Technician must be familiar with requirements of Sections 105-16, 107-12, 107-13, 108-7, and 802 of the Standard Specifications as well as the Reclamation Plan, all permits and DENR regulations.				
Have the Contractor and the property owner(s) submitted and had approved by the Engineer a Waste Area Development, Use and Reclamation Plan for each waste area proposed?				
The Technician and Engineer should consider any possible damage or detrimental effects to the project if disposal within the right of way is permitted. Furthermore, an agreement for equitable compensation should be made where the Contractor has requested to waste material on the right of way when not detailed in the original bid documents.				
The Technician should make an on-site inspection of the proposed site after the Reclamation Plan has been approved and before wasting operations begin to try to anticipate any problems that may arise.				
The Technician should make frequent checks of the site to ensure that the requirements in the Specifications and the Reclamation Plan are being met and to ascertain any detrimental effects that may be occurring to abutting or adjacent property or streams; operations should be suspended until corrective measures are taken if inadequacies are found.				
The Technician should ensure that the waste area is properly shaped to blend with adjacent topography before seeding and mulching is performed.				
Ensure that staged seeding and mulching is performed and final seeding and mulching is performed as soon as possible.				
Ensure that each waste area is topdressed if applicable.				
Ensure that all pay items as defined in the Specifications (Section 802-3) are measured and properly recorded in appropriate pay record books.				
Establish a permanent stand of vegetation prior to acceptance of the project.				