

**TECHNICIAN'S CHECKLIST**  
**SECTION 866**  
**FENCE**

PROJECT: \_\_\_\_\_  
 REVIEW DATE: \_\_\_\_\_

TECHNICIAN: \_\_\_\_\_  
 REVIEWER: \_\_\_\_\_

ACTION	YES	NO	N/A	COMMENTS
Ensure the Materials & Tests Unit is advised upon the arrival of materials that are to be tested.				
All material should be sampled, tested, and approved before installation.				
Check plans to make sure that the fence has been staked as specified on the plans.				
For Controlled Access Fence, ensure the Right-of-Way Markers are not disturbed.				
Check alignment, length of posts, spacing of posts, and depth of posts in ground or concrete as they are erected.				
The type of fence should be indicated in the pay record book.				
Use the required gauge and number of ties.				
Place fabric on the correct side of the posts.				
Space the wire correctly on the posts.				
Check installation of splicing sleeves.				
Place brace posts where needed.				
Install additional barbed wire where needed.				
Shape concrete around posts and remove excess concrete.				
Ensure the concrete is cured.				
Clean and repair damage with an approved paint.				
Ensure hinges on gates are turned as shown on plans.				