- Q PILE  $\sim$  6-#5 V1 BARS @  $3\frac{1}{4}$ " CTS. ON A  $3\frac{1}{8}$ " RADIUS ¬ Q CAP #4 S1 BAR 14'' Ø PLAN ₩5 V1 BAR 3" TO S1 BAR -**||**---#4 S1 BAR — 14'' Ø X ¾'' ዊ PIPE PILE PLATE DETAIL - CLASS A CONCRETE PLUG IF APPLICABLE - PP 14 X 0.50 GALVANIZED STEEL PILE © PILE SPLICE ¬ **BOTTOM OF** CONCRETE PLUG PP 14 X 0.50 GALVANIZED - SEE PIPE PILE PLATE DETAIL ( IF APPLICABLE ) STEEL PILE -**ELEVATION** PIPE PILE SPLICE DETAIL PP 14 X 0.50 GALVANIZED STEEL PILE ( OPEN OR CLOSED END ) ASSEMBLED BY: DATE : CHECKED BY : DATE: 8/05 REV. 5/I/06R REV. IO/I/II REV. I2/I7 MAA/KMM MAA/GM MAA/THC DRAWN BY : TLA CHECKED BY: GM

## **NOTES**

PIPE PILES SHALL BE IN ACCORDANCE WITH SECTION 1084 OF THE STANDARD SPECIFICATIONS.

GALVANIZE STEEL PIPE PILES IN ACCORDANCE WITH SECTION 1076 OF THE STANDARD SPECIFICATIONS UNLESS METALLIZING IS REQUIRED. GALVANIZING OR METALLIZING PIPE PILE PLATES IS NOT REQUIRED.

PIPE PILE PLATES, IF REQUIRED, SHALL BE IN ACCORDANCE WITH SECTION 450 OF THE STANDARD SPECIFICATIONS.

REMOVE AND REPLACE OR REPAIR TO THE SATISFACTION OF THE ENGINEER PILES THAT ARE DAMAGED, DEFORMED OR COLLAPSED DURING INSTALLATION OR DRIVING.

PILE SPLICES SHALL BE IN ACCORDANCE WITH THE STANDARD SPECIFICATIONS AND AWS D1.1.

FOR CLOSED END PIPE PILES, REMOVE ALL SOIL AND WATER FROM INSIDE THE PILES JUST PRIOR TO PLACING REINFORCING STEEL AND CONCRETE FOR THE CONCRETE PLUG.

FOR OPEN END PIPE PILES, REMOVE ENOUGH SOIL AND WATER FROM INSIDE THE PILES TO CONSTRUCT THE CONCRETE PLUG WITHOUT FOULING THE CONCRETE.

FORM THE CONCRETE PLUG SUCH THAT THE REINFORCING STEEL OR CONCRETE DOES NOT MOVE AND THE CLEARANCE FROM THE REINFORCING STEEL TO THE INSIDE OF THE PILE IS MAINTAINED AFTER CONCRETE PLACEMENT. DO NOT PLACE CONCRETE IN THE BENT CAP UNTIL THE CONCRETE PLUG HAS ATTAINED A MINIMUM COMPRESSIVE STRENGTH OF 1500 PSI.

THE REINFORCING STEEL, CLASS A CONCRETE, AND GALVANIZING ARE CONSIDERED INCIDENTAL TO THE CONTRACT UNIT PRICE BID PER LINEAR FOOT FOR PP 14 X 0.50 GALVANIZED STEEL PILES.

BILL OF MATERIAL FOR ONE PP 14 X 0.50 GALVANIZED STEEL PILE					
BAR	NO.	SIZE	TYPE	LENGTH	WEIGHT
S1	6	#4	1	3'-5"	14
V1	6	#5	2	6'-8''	42

CLASS A CONCRETE

5'-0" MINIMUM PLUG 0.2 CY

56

REINFORCING STEEL =

BAR TYPES

— 1'-3" LAP 5'-10'' ALL BAR DIMENSIONS ARE OUT TO OUT.

PROJECT NO.\_ COUNTY STATION: \_\_\_

> STATE OF NORTH CAROLINA DEPARTMENT OF TRANSPORTATION

> > STANDARD

14" STEEL PIPE PILE

SHEET NO. REVISIONS NO. BY: DATE: DATE:

DOCUMENT NOT CONSIDERED FINAL UNLESS ALL SIGNATURES COMPLETED

STD. NO. SPP1