The 2002 Standard Specifications shall be revised as follows:

Replace the first sentence of Section 1072-9(D) of the Standard Specifications with the following:

Furnish all structural steel for main beam and girder members (for girder members see plans) and for diaphragus **G** b sframes connecting horizontally curved members meeting the **D** furnial Charpy V-Notch Tests specified in the supplementary requirements in AASHTO M270 for zone 1.