



NOTES

1. BOND 0.5 INCH DIAMETER, 28 STRAND (MINIMUM) CLASS II COPPER CONDUCTOR TO THE MAIN GROUND ROD BY AN IRREVERSIBLE MECHANICAL CRIMP METHOD.
2. ALL CONNECTIONS TO GROUND RODS SHOULD BE MADE WITH AN IRREVERSIBLE MECHANICAL CRIMP METHOD.
3. BOND #4 AWG SOLID BARE COPPER WIRE TO REBAR CAGE AND THE MAIN GROUND ROD BY AN IRREVERSIBLE MECHANICAL CRIMP.
4. ENSURE CAMERA HOUSING, CAMERA, AND PAN -TILT UNIT ARE BONDED TO POLE.
5. REMOVE BONDING JUMPER BETWEEN EQUIPMENT CABINET GROUND BUSS AND NEUTRAL BUSS.
6. THE CONTRACTOR MAY, UPON APPROVAL OF THE ENGINEER, INSTALL A 30-FOOT SECTIONAL GROUND ROD WHEN CONDITIONS WILL NOT ALLOW FOR THE INSTALLATION OF THE 3 - RADIAL GROUND RODS.
7. INSTALL MARKER TAPE DIRECTLY ABOVE ALL GROUNDING ELECTRODES AND CONDUCTORS AT A DEPTH OF 12 INCHES.

<p>750 N. Greenfield Pkwy., Garner, NC 27529</p>	<p>CCTV CAMERA INSTALLATION FOR METAL POLE</p> <p>TYPICAL DETAIL</p>		<p>SEAL</p>							
	<p>PLAN DATE: JANUARY 2018</p> <p>REVIEWED BY:</p>	<p>PREPARED BY:</p> <p>REVIEWED BY:</p>		<p>SIGNATURE</p> <p>DATE</p>						
<p>SCALE</p> <p>0</p>	<p>REVISIONS</p> <table border="1"> <tr> <th>NO.</th> <th>DESCRIPTION</th> <th>INIT.</th> <th>DATE</th> </tr> <tr> <td>1</td> <td>2018 STANDARD SPECIFICATIONS UPGRADE TO IRREVERSIBLE MECHANICAL CRIMP</td> <td>A.J.S.</td> <td>11/2017</td> </tr> </table>	NO.	DESCRIPTION	INIT.	DATE	1	2018 STANDARD SPECIFICATIONS UPGRADE TO IRREVERSIBLE MECHANICAL CRIMP	A.J.S.	11/2017	<p>CADD Filename:</p>
NO.	DESCRIPTION	INIT.	DATE							
1	2018 STANDARD SPECIFICATIONS UPGRADE TO IRREVERSIBLE MECHANICAL CRIMP	A.J.S.	11/2017							